



MILLER
CONSULTING
ENGINEERS

SUPPLEMENTAL STRUCTURAL CALCULATIONS

**Legacy Holiday Park Chiller Replacement
815 NE Davis Street, Portland, Oregon
Johnson Controls**

**February 15, 2017
Project No. 161480**

6 pages

Principal Checked: N



***** LIMITATIONS *****

Miller Consulting Engineers, Inc. was retained in a limited capacity for this project. This design is based upon information provided by the client, who is solely responsible for accuracy of same. No responsibility and or liability is assumed by or is to be assigned to the engineer for items beyond that shown on these sheets.

Building Code: 2014 Oregon Structural Specialty Code

Soils Report: No

Soils Report by:

N/A

Dated: N/A

Soil Bearing: 1500 PSF

Retaining Walls: No

Equivalent Fluid Pressure (active): N/A

PCF

Passive bearing:

N/A

PCF

Friction: N/A

Structural System: Component

Vertical System:

Lateral Sys:

Basic Design Loads:	Element				
	Load Type				
	Value (PSF)				
	Load Type				
	Value (PSF)				
	Deflection Criteria				

Lateral Design Parameters:

Wind Design: ASCE 7-10

Exposure

B

Wind Speed (3 sec Gust):

130

MPH

Importance Factors

$I_W =$

1.00

(ice w/ wind)

$I_E =$

1.25

(seismic)

$I_S =$

1.10

(snow)

$I_I =$

1.25

(ice)

Risk Cat:

III

Seismic Design

Seismic design parameters are based on published values from the USGS web site.

See page 3
of original calculations

Latitude:

Longitude:

2% PE in 50 years, 0.2 sec SA = Ss

2% PE in 50 years, 1.0 sec SA = S1

(Site class B parameters are indicated on this page, for actual site class used in design, refer to seismic design summary)

Design Summary:

The following supplemental calculations are for the attachment of a new lighter evaporation tower to the existing steel beam sleepers. See original calculations dated 12/22/2016 for loading. No change to the gravity or lateral load resisting system of the structure.



MILLER
CONSULTING
ENGINEERS

9570 SW Barbur Blvd.
Suite One Hundred
Portland, OR 97219

(503)246-1250

FAX: 246-1395

Project Name: Legacy Holiday Park Chiller Replacement

Project #: 161480

Location: 815 NE Davis Street, Portland, Oregon

Client: Johnson Controls

BY: MRS

Ck'd: M

Date: 02/15/17

Page 1 of 6

Check connection from mechanical unit to steel beams^(E)

T = 64# SEISMIC 1 fastener

= 953# WIND ← CONTROLS

V = 117# SEISMIC

= 427# WIND ← CONTROLS

SEE NEXT PG. FOR DESIGN

USE (8) 1/2" ϕ BOLTS

ATTACH STEEL BEAMS TO CONCRETE

ALL SHEAR IS TAKEN OUT IN (E) CONCRETE ANCHORS (10 per sleeper)

$T_{EQ} = 105\# \times 4 \text{ connectors} \times 1.4 \text{ ult} \times \Omega = 2.5 = 1470\#$ (TOTAL)

$T_{WIND} = 1176\# \times 4 \text{ connectors} \times 1.6 \text{ ult} = 7526\#$ ← controls
3 anchors = 2509#

SEE PG, 5 FOR CONCRETE ANCHOR DESIGN



MILLER
CONSULTING
ENGINEERS

9570 SW Barbur Blvd
Suite One Hundred
Portland, OR 97219-5412

(503)246-1250
Fax: 246-1395

Project Name Legacy Holiday Park Chiller Replacement Project # 161480

Location 815 NE Davis Street, Portland, Oregon

Client Johnson Controls

By MRS Ck'd [Signature] Date 2/15/17 Page 2 of

Steel Fastener Design - AISC 13th Addition

Type: Bolt
 Grade: A307
 Threads are included in the shear plane
 Diameter: 0.5 in
 Loading: ASD

T =	0.95	k, tension
V =	0.43	k, shear
A =	0.196	in ²
dr =	0.417	in
ft =	4.9	ksi = 0.95 / 0.196
fv =	2.2	ksi = 0.43 / 0.196
Ω =	0.5	

Fastener Capacity Summary:

Fnt =	45	ksi, Table J3.2
Fnv =	24	ksi, Table J3.2
Tc =	4.41	k = 45 * 0.196 * 0.5
Vc =	2.35	k = 24 * 0.196 * 0.5
ft/(Fnt*0.5) =	0.22	< 1.0 OK
fv/(Fnv*0.5) =	0.18	< 20%, effects of combined stresses need not be investigated

Combined effects are not applicable.

F'nt =	N/A	ksi, Eq. J3-3, page 16.1-109
T'c =	N/A	k, reduced tension capacity

Use 0.5" diameter A307 bolt



MILLER
 CONSULTING
 ENGINEERS

9570 SW Barbur Blvd
 Suite One Hundred
 Portland, OR 97219-5412

(503)246-1250
 Fax: 246-1395

Project Name Legacy Holiday Park Chiller Replacement Project # 161480

Location 815 NE Davis Street, Portland, Oregon

Client Johnson Controls

By MRS Ck'd mm Date 2/15/17 Page 3 of 3

Check (c) steel beam

$$T = 1176\# \times 4 \text{ connections} / (3) \text{ anchors} = 1568\#$$

$$f_b = \frac{1568\# \times \frac{3.33 - 0.232}{2}}{S = (16 \times 0.359'') (0.359'')^2 / 6} = 19909 \text{ psi} < \frac{36000}{1.67} = 21556 \text{ psi}$$

(E) S6x12.5 BEAM IS
ADEQUATE

Check angle leg

$$T = 1568\# \times 2'' = 3136\#$$

$$S = (1/4'')(2'')^2 / 6 = 0.17 \text{ in}^3$$

$$f_b = 18816 \text{ psi} < \frac{36000 \text{ psi}}{1.67} = 21557 \text{ psi} \text{ ok}$$

USE L2x2x1/4

Check WELD

$$M = 1568\# \times 2''/2 = 761\#$$

$$T = 1568\#$$

SEE PG. 6

USE 3/16" WELD EA. SIDE



MILLER
CONSULTING
ENGINEERS

9570 SW Barbur Blvd
Suite One Hundred
Portland, OR 97219-5412

(503)246-1250
Fax: 246-1395

Project Name Legacy Holiday Park Chiller Replacement Project # 161480

Location 815 NE Davis Street, Portland, Oregon

Client Johnson Controls

By MRS Ck'd [Signature] Date 2/15/17 Page 4 of



Profis Anchor 2.7.1

www.hilti.us

Company:
Specifier:
Address:
Phone / Fax:
E-Mail:

Page:
Project:
Sub-Project / Pos. No.:
Date:

Specifier's comments:

1 Input data

Anchor type and diameter: HIT-HY 200 + HAS 5/8

Effective embedment depth: $h_{ef,appl} = 5.906$ in. ($h_{ef,min} = 12.500$ in.)

Material: 5.8

Evaluation Service Report: ESR-3197

Issued / Valid: 6/1/2016 / 3/1/2018

Proof: Design method ACI 318-11 / Chem

Stand-off installation: $e_b = 0.000$ in. (no stand-off); $t = 0.500$ in.

Anchor plate: $l_x \times l_y \times t = 6.000$ in. \times 6.500 in. \times 0.500 in.; (Recommended plate thickness: not calculated)

Profile: no profile


Base material: cracked concrete, 4000, $f'_c = 4000$ psi; $h = 16.000$ in., Temp. short/long: 32/32 °F

Installation: hammer drilled hole, Installation condition: Dry

Reinforcement: tension: condition B, shear: condition B; no supplemental splitting reinforcement present
edge reinforcement: none or \leq No. 4 bar



Geometry [in.] & Loading [lb, in.lb]



Input data and results must be checked for agreement with the existing conditions and for plausibility!
PROFIS Anchor (c) 2003-2009 Hilti AG, FL-9494 Schaan. Hilti is a registered trademark of Hilti AG, Schaan.



Profis Anchor 2.7.1

www.hilti.us

Company:
Specifier:
Address:
Phone / Fax:
E-Mail:

Page:
Project:
Sub-Project / Pos. No.:
Date:

2 Proof / Utilization (Governing Cases)

		Design values [lb]		Utilization		
Loading	Proof	Load	Capacity	β_N / β_V [%]	Status	
Tension	Bond Strength	2509	2524	100 / -	OK	
Shear	-	-	-	- / -	-	
Loading		β_N	β_V	ζ	Utilization $\beta_{N,V}$ [%]	Status
Combined tension and shear loads		-	-	-	-	-

3 Warnings

- Please consider all details and hints/warnings given in the detailed report!

Fastening meets the design criteria!


4 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.

Input data and results must be checked for agreement with the existing conditions and for plausibility!
PROFIS Anchor (c) 2003-2009 Hilti AG, FL-9494 Schaan. Hilti is a registered trademark of Hilti AG, Schaan.

EQUAL RECTANGLES (weld on both outside faces)

Vy =		lb (asd)
Mx =		ft-lb (asd)
Vx =	1568	lb (asd)
My =	261	ft-lb (asd)
Weld size (w) =	0.1875	in = 3/16 " fillet weld
Length of weld (b1) =	2	in
Depth of post (d1) =	0.75	in
d =	1.02	in
A =	0.54	in ²
Ix =	0.11	in ⁴
Sx =	0.22	in ³
Iy =	0.18	in ⁴
Sy =	0.18	in ³
F _w /Ω =	21000	psi
Vc =	11340	lb
Mcx =	385	ft-lb
Mcy =	315	ft-lb
Capacity =	0.97	< 1.00 OK
Use 0.1875" fillet weld		



Check shear welds

$$(E) = 1/8 - 1/32" = 0.09375" \times l = 3" = 0.28 \text{ in}^2$$

$$V_c = 21000 \text{ psi} \times 0.28 \text{ in}^2 = 5880 \# \text{ per weld}$$

$$V_{\text{TOTAL}} = 474 \# \times 8 = 3792 \# < 5880 \#$$

(E) WELDS ARE ADEQUATE



MILLER
CONSULTING
ENGINEERS

9570 SW Barbur Blvd
Suite One Hundred
Portland, OR 97219-5412

(503)246-1250
Fax: 246-1395

Project Name Legacy Holiday Park Chiller Replacement Project # 161480
Location 815 NE Davis Street, Portland, Oregon
Client Johnson Controls
By MRS Ck'd [Signature] Date 2/15/17 Page 6 of 6