



August 10, 2018

Project: Hornbeck Res.  
7900 SE Madison St.  
Portland, OR 97215

Subject: Girder Truss support

IVR # 4066135

**Structural Memo:**

To whom it may concern:

- ◆ I reviewed the loads from the girder trusses for this project. Double 2x4 studs supporting each girder truss is acceptable.

Sincerely,  
Julie Havelka, PE  
Summit Engineering, LLC  
971-251-0194  
Julie@summitengineeringllc.com



EXP. 6-30-2019