



Office of the
Building Inspector
of the City of Portland,
Oregon

Portland, Oregon, May 22, 1908.

Honorable Harry Lane,
Mayor of the City of Portland,
City Hall.

Dear Sir:-

In accordance with your request, I have this day carefully examined the lintels in a building being built on 4th Street between Everett and Flanders, for Chinese occupants.

I find that the appearance of these lintels is due to the fact that they were not braced as the concrete was poured ; and, therefore, took a set due to the weight of the concrete.

I have examined said lintels carefully, and find that they are now perfectly set and are able safely to take care of the loads upon them.

Thanking you for calling my attention to the above, and hoping that this letter will explain any questions which may come up, I remain

Very sincerely yours,

W. J. Spencer
Building Inspector.

WIS/FIB