

About Your Building


Building Name	13th Street Lofts
Address	239 NW 13th Avenue
Portland Building ID	1N1E33DA-3300-B1
EnergyStar Score	Not Available

Reference Data

Electricity	Jan 2018 - Dec 2018
Gas	Jan 2018 - Dec 2018
Bldg. Size	29,279 s.f.
Bldg. Type	Office

How Your Building Compares

The chart to the right compares your building's annual energy use intensity (EUI) with national and local standards. EUI is a common energy metric that measures your building's energy use per square foot by dividing total annual energy use by the size of your building. Your building's EUI is compared to the CBECS* median and ASHRAE Standard 100** target for offices as well as the City of Portland's 2019 disclosed energy performance data for commercial buildings***, where available.



Energy Efficiency Diagnostics for Your Building

Category	Status
Heating and Ventilation Efficiency	Typical
Cooling Efficiency	Poor
HVAC Reheat	No apparent problems
Gas Baseload	Typical
Light and Plug Loads	High
External/Process Load	High
Portfolio Manager Data Consistency	Orderly

FirstView generates automated diagnostics by analyzing the shape of your building's Energy Signature and comparing it to data for buildings of similar size and type. [Click here](#) to learn more.

Energy Efficiency Findings and Recommendations for Your Building

Based on your building's energy use patterns, you may be able to reduce energy use by focusing on improvements in the following areas:

- This building may be a good candidate for cooling system improvements. Excess outside air rates, high outside air infiltration, poor control settings, and 24-hour fan schedules may be present.
- This building has an elevated electrical baseload. Barring process electrical loads, savings may be available via lighting upgrades, updates to EnergyStar rated appliances, and/or plug load management. Buildings with electric water heaters may also benefit from an upgrade to heat pump water heaters.

Find more detailed information about your building's energy use on the following page.


* [CBECS](#) is a national building survey commonly used to represent the energy use of typical existing building stock in the United States.

** [ASHRAE Standard 100](#) details energy use targets for specific building types and climate zones which are derived from CBECS data.

*** The City of Portland's Commercial Building Energy [Reporting data](#) for 2019 includes median building performance for various building types.



Your Building's Energy Signature by Energy Type and Temperature

The chart below shows your building's actual energy usage at various temperatures alongside its Energy Signature as modeled by FirstView. The data points and Energy Signature lines are separated according to electric and natural gas usage with the purple line representing total energy usage. The Energy Signature shows your building's expected energy consumption at various temperatures, and is used to help determine the end-use breakdown in the How Energy is Used in Your Building chart



How Energy is Used in Your Building

The chart below shows your building's total energy use at a range of outside temperatures and is split into four end-use categories: heating (electric and gas), cooling, electric baseload (e.g. plugs, lights, and equipment), and thermal baseload (e.g. gas used for water heating). This offers insights into energy consumption patterns, including how your building's energy use is allocated. FirstView identifies end-uses with high usage compared to similar buildings in the diagnostics on page 1. [Click here](#) to learn more.



■ Heating ■ Cooling ■ Gas Baseload ■ Electric Baseload