

About Your Building


Building Name Arlington Club
Address 811 SW Salmon St.
Portland Building ID 1S1E03BB-6000-B1
EnergyStar Score Not Available

Reference Data

Electricity Jan 2019 - Dec 2019
Gas Jan 2019 - Dec 2019
Bldg. Size 45,000 s.f.
Bldg. Type Social/Meeting Hall

How Your Building Compares

The chart to the right compares your building’s annual energy use intensity (EUI) with national and local standards. EUI is a common energy metric that measures your building’s energy use per square foot by dividing total annual energy use by the size of your building. Your building’s EUI is compared to the CBECS* median and ASHRAE Standard 100** target for public assembly buildings as well as the City of Portland’s 2019 disclosed energy performance data for commercial buildings***, where available.



Energy Efficiency Diagnostics for Your Building

Category	Status
Heating and Ventilation Efficiency	Typical
Cooling Efficiency	Good
HVAC Reheat	No apparent problems
Gas Baseload	High
Light and Plug Loads	Typical
External/Process Load	No apparent problems
Portfolio Manager Data Consistency	Orderly

FirstView generates automated diagnostics by analyzing the shape of your building’s Energy Signature and comparing it to data for buildings of similar size and type. [Click here](#) to learn more.

Energy Efficiency Findings and Recommendations for Your Building

Based on your building’s energy use patterns, you may be able to reduce energy use by focusing on improvements in the following areas:

- This building has a high gas baseload, which may be associated with cooking, domestic hot water (DHW) use, or excessive reheat during warmer months. Potential issues may include: high DHW setpoints, poor water heater efficiency, gas process loads, and/or HVAC reheat.

Find more detailed information about your building’s energy use on the following page.


* [CBECS](#) is a national building survey commonly used to represent the energy use of typical existing building stock in the United States.

** [ASHRAE Standard 100](#) details energy use targets for specific building types and climate zones which are derived from CBECS data.

*** The City of Portland’s Commercial Building Energy [Reporting data](#) for 2019 includes median building performance for various building types.

Your Building's Energy Signature by Energy Type and Temperature

The chart below shows your building's actual energy usage at various temperatures alongside its Energy Signature as modeled by FirstView. The data points and Energy Signature lines are separated according to electric and natural gas usage with the purple line representing total energy usage. The Energy Signature shows your building's expected energy consumption at various temperatures, and is used to help determine the end-use breakdown in the How Energy is Used in Your Building chart



How Energy is Used in Your Building

The chart below shows your building's total energy use at a range of outside temperatures and is split into four end-use categories: heating (electric and gas), cooling, electric baseload (e.g. plugs, lights, and equipment), and thermal baseload (e.g. gas used for water heating). This offers insights into energy consumption patterns, including how your building's energy use is allocated. FirstView identifies end-uses with high usage compared to similar buildings in the diagnostics on page 1. [Click here](#) to learn more.

