# **Development Services**

## From Concept to Construction







#### APPEAL SUMMARY

Status: Decision Rendered	
Appeal ID: 14922	Project Address: 3705 SE Tibbetts St
Hearing Date: 4/12/17	Appellant Name: Tyler FuQua
<b>Case No.</b> : B-013	Appellant Phone: 5037089956
Appeal Type: Building	Plans Examiner/Inspector: Not sure
Project Type: residential	Stories: 1 Occupancy: Family Construction Type: Wood
Building/Business Name:	Fire Sprinklers: No
Appeal Involves: Alteration of an existing structure	LUR or Permit Application No.: 17-139062-RS
Plan Submitted Option: pdf [File 1]	Proposed use: living space

#### APPEAL INFORMATION SHEET


## Appeal item 1

Code Section	R311.7.4.2
Requires	That existing stairs in a basement must have a 9" min run.
Proposed Design	The existing stairs at this house have a run of at least 8" with a slip resistant nosing on each of the steps. We are hoping to be allowed to keep these stairs as is for they meet all of the other requirements (head height, rise, etc.) Having to redo these already safe stairs would add significant cost to a smaller remodel job.
Reason for alternative	These stairs have been in place for years and have been proven to be safe. The head room is up to code and that is probably the biggest concern. The basement has two egress windows.

#### APPEAL DECISION

Allow existing basement stairs with 8 inch tread depth: Denied: Appellant may contact Dave Tebeau (503-823-6802) for additional information.

Pursuant to City Code Chapter 24.10, you may appeal this decision to the Building Code Board of Appeal within 180 calendar days of the date this decision is published. For information on the appeals process and costs, including forms, appeal fee, payment methods and fee waivers, go to www.portlandoregon.gov/bds/appealsinfo, call (503) 823-7300 or come in to the Development Services Center.



# EXISTING STAIR CONDITION SCALE: 3/4" = 1'-0"