

Development Services

From Concept to Construction

Phone: 503-823-7300 Email: bds@portlandoregon.gov 1900 SW 4th Ave, Portland, OR 97201

More Contact Info (<http://www.portlandoregon.gov/bds/article/519984>)



APPEAL SUMMARY

Status: Decision Rendered

Appeal ID: 20536	Project Address: 7759 NE Mary Olson Way
Hearing Date: 6/19/19	Appellant Name: Camden Knoff
Case No.: B-019	Appellant Phone: 952-656-2689
Appeal Type: Building	Plans Examiner/Inspector: Geoffrey Pena
Project Type: commercial	Stories: 1 Occupancy: S-1 Construction Type: II-B
Building/Business Name: United Airlines Hangar	Fire Sprinklers: Yes - Sprinklers in support areas. Foam in hangar bay
Appeal Involves: Alteration of an existing structure	LUR or Permit Application No.: Acceptance of alternate form of detection in hangar
Plan Submitted Option: pdf [File 1] [File 2] [File 3]	Proposed use: Maintenance hangar

APPEAL INFORMATION SHEET

Appeal item 1

Code Section	OSSC 412.4.6. NFPA 409: 6.2.8.2.1
Requires	<p>OSSC 412.4.6 requires that fire suppression systems for aircraft hangars are designed in accordance with NFPA 409.</p> <p>NFPA 409 (2011 edition) section 6.2.8.2.1 requires the detectors for the actuation of deluge foam-water sprinkler systems are rate-of-rise, fixed-temperature, or rate-compensation types.</p> <p>Therefore the only form of detection permitted to activate foam suppression in the hangar bay is heat detection.</p>
Proposed Design	<p>The proposed alternate method is to use IR flame detectors in lieu of heat detectors to activate the foam suppression system in the hangar bay.</p> <p>Flame detection is a commonly utilized form of hangar bay detection and is the only form approved by the DoD in their UFC codes.</p> <p>Flame detectors will be located around the perimeter of the hangar bay so that any point underneath the aircraft is in view of multiple detectors. Two detectors activated simultaneously will be required to initiate the foam suppression system.</p>
Reason for alternative	Heat detection is not an ideal form of detection for this project. The roof deck of the hangar bay is approximately 60 ft above the floor. Activation for the heat detectors may be delayed due to the time taken for a fire to become large enough for heat to accumulate at the ceiling. Additionally, NFPA 72 provides minimal guidance on heat detector spacing requirements for ceiling heights >30 ft. Heat detector spacing at this height may be impractically closely spaced and hard to enforce

without prescriptive requirements. Finally, maintenance of individual heat detectors spaced throughout the hangar deck 60 ft above the ground would be extremely challenging for maintenance personnel and increases the risk of the system not being in constantly functional operation.


Providing flame detection in the hangar bay in lieu of heat detection is an equivalent and potentially superior option than heat detection. Flame detectors are already commonly used in DoD hangars. They are located near the floor level around the perimeter of the hangar bay and "see" the fire in its early stages. Flame detectors are easy to access and therefore maintain. Additionally flame detectors have a proven record of reliability and are not prone to false activation. The design will require simultaneous activation of two heat detectors in order to decrease the risk of accidental foam discharge.

APPEAL DECISION

Use of infra red flame detectors in lieu of heat detectors for foam suppression system: Granted provided detection system installation is per NFPA 72 and manufacturer's installation instructions. Appellant may contact John Butler (503 823-7339) with questions.

The Administrative Appeal Board finds with the conditions noted, that the information submitted by the appellant demonstrates that the approved modifications or alternate methods are consistent with the intent of the code; do not lessen health, safety, accessibility, life, fire safety or structural requirements; and that special conditions unique to this project make strict application of those code sections impractical.

Pursuant to City Code Chapter 24.10, you may appeal this decision to the Building Code Board of Appeal within 180 calendar days of the date this decision is published. For information on the appeals process and costs, including forms, appeal fee, payment methods and fee waivers, go to www.portlandoregon.gov/bds/appealsinfo, call (503) 823-7300 or come in to the Development Services Center.





1. REFER TO FA001 FOR GENERAL NOTES, DESIGN CRITERIA, ABBREVIATIONS AND SYMBOLS.
2. WHERE WIRING IS REMOVED FROM EXISTING CONDUIT THAT CONTAINS ADDITIONAL WIRING THAT IS TO REMAIN, EITHER ALL WIRING SHALL BE REMOVED FROM CONDUIT, OR NEW CONDUIT SHALL BE PROVIDED.


- 1 REMOVE EXISTING FIRE ALARM DEVICES AND NOTIFICATION APPLIANCES IN THIS AREA AS REQUIRED TO COMPLY WITH NEW ARCHITECTURAL LAYOUT, CEILINGS AND FEATURES. SEE ARCHITECTURAL DRAWINGS FOR NEW FLOOR PLAN.
- 2 REMOVE EXISTING RELEASING PANEL, RF TRANSMITTER, AND FIRE ALARM CONTROL UNIT.

[illegible]

Date	Time	Location	Description

 BURNS MCDONNELL		
9400 WARD PARKWAY KANSAS CITY, MO 64114		
BMCD LICENSE NO: ARF-11103		
date 10/23/18	detailed N. OLSON	
designed C. KNOFF	checked A. MOORE	
		
7759 NE MARY OLSON WAY PORTLAND, OR 97218 USA		
UAL - PDX HANGAR MODIFICATIONS FIRE ALARM DEMOLITION PLAN		
project 110438	contract CONTRACT	
drawing	rev.	
FA100 — 0		
sheet	of	sheets
file		

4/11/2019 11:30:40 AM
COPYRIGHT © 2018 BURNS & MCDONNELL





- NOTES:**
- REFER TO FA001 FOR GENERAL NOTES, DESIGN CRITERIA, ABBREVIATIONS AND SYMBOLS.
 - PROVIDE ALL NEW ADDRESSABLE DEVICES INCLUDING BUT NOT LIMITED TO SMOKE DETECTORS, MONITOR MODULES, PULL STATIONS, AND CONTROL MODULES, THROUGHOUT THE FACILITY. ALL DEVICES SHALL BE UL LISTED WITH THE RSFACU. EXISTING CONDUIT MAY BE REUSED WHERE IN COMPLIANCE WITH THE SPECIFICATIONS.
 - REVISE AND PROVIDE NAC CIRCUITS AND ADDITIONAL NOTIFICATION DEVICES AS REQUIRED FOR ADJUSTED FLOOR PLAN IN SUPPORT AREAS.
 - WALL MOUNTED NOTIFICATION APPLIANCES ARE PERMITTED IN AREAS WITH CONGESTED CEILINGS, SUCH AS MECHANICAL ROOMS.
 - LOCATE ADDRESSABLE MODULES FOR DEVICES IN THE HANGAR BAY IN A CONDITIONED AREA OUTSIDE THE HANGAR BAY.

- KEYED NOTES:**
- PROVIDE SMOKE DETECTION ABOVE RSFACU AND NAC PANELS.
 - ~~PROVIDE NEW ADDRESSABLE HEAT DETECTORS IN THE HANGAR BAY AND TUG POCKET TO MEET THE SPACING REQUIREMENTS OF NFPA 72 AND THE MANUFACTURER'S RECOMMENDATIONS. HEAT DETECTORS SHALL BE DIVIDED INTO AN EAST AND WEST ZONE AS PER THE EXISTING SYSTEM.~~
 - CONNECT NEW RSFACU TO EXISTING TAMPER SWITCHES ON FOAM CONCENTRATE SHUTOFF BUTTERFLY VALVES (QTY 6) FOR A FULLY SUPERVISED SYSTEM.
 - PROVIDE QUANTITY OF NAC PANELS AS REQUIRED TO MEET DESIGN CRITERIA.
 - EXACT QUANTITY AND LOCATIONS OF EXISTING FIRE SUPPRESSION SYSTEM DEVICES TO BE FIELD VERIFIED. PROVIDE ADDITIONAL DEVICES AS REQUIRED BY THESE DRAWINGS.
 - MONITOR RPZ BACKFLOW PREVENTER IN UNDERGROUND FIRE/DOMESTIC SERVICE LINE.

FIRE ALARM HATCH LEGEND

NO HATCH	NOTIFICATION APPLIANCES ARE NOT REQUIRED.
	PROVIDE CEILING MOUNTED HORNS AS REQUIRED TO ACHIEVE DESIGN CRITERIA.
	PROVIDE CEILING MOUNTED HORNS AND CLEAR STROBES AS REQUIRED TO ACHIEVE DESIGN CRITERIA.
	RECONNECT ALL EXISTING NAC CIRCUITS IN HANGAR BAY TO THE NEW FIRE ALARM SYSTEM FOR GENERAL ALARM AND FOAM RELEASE. PROVIDE NEW NOTIFICATION APPLIANCES IN HANGAR BAY AND TUG POCKET AS REQUIRED FOR ADJUSTED FLOOR PLAN TO MEET DESIGN REQUIREMENTS. NOTIFICATION APPLIANCES IN HANGAR BAY AND TUG BAY SHALL BE NEMA 4 RATED.



0 8' 16' 32'
SCALE IN FEET

no.	date	by	ckd	description
0	04/12/19	CK	AM	ISSUED FOR PERMIT

Will remove note and replace with note related to flame detection

**BURNS
MCDONNELL**

9400 WARD PARKWAY
KANSAS CITY, MO 64114

BMCD LICENSE NO: ARF-11103

date	10/23/18	detailed	N. OLSON
designed	C. KNOFF	checked	A. MOORE

UNITED

7759 NE MARY OLSON WAY
PORTLAND, OR 97218
USA

**UAL - PDX HANGAR MODIFICATIONS
FIRE ALARM PLAN**

project	110438	contract	CONTRACT
drawing	FA101 - 0	rev.	
sheet	of	sheets	
file			

CIRCUIT LEGEND:

SIGNALING LINE CIRCUIT (CLASS A)

INITIATING DEVICE CIRCUITS

VISIBLE NOTIFICATION APPLIANCE CIRCUIT (CLASS A)


POWER CIRCUIT

NOTES:

1. REFER TO FA001 FOR GENERAL NOTES, DESIGN CRITERIA, ABBREVIATIONS, AND SYMBOLS.
2. THE FIRE ALARM RISER SHOWS THE INTENT OF THE FIRE ALARM INFRASTRUCTURE. NOT ALL DEVICES ARE SHOWN. SUBCONTRACTOR SHALL PROVIDE THE QUANTITY OF DEVICES AS REQUIRED TO COMPLY WITH NFPA 72, NFPA 409, AND CONTRACT DOCUMENTS.
3. EACH FLOW AND TAMPER SWITCH SHALL BE INSTALLED USING DUAL MODULES.


KEYED NOTES:

- 1 RED, LOCKABLE BREAKER LABELED "FIRE ALARM" PROVIDED BY DIVISION 26.
- 2 QUANTITY AND LOCATION BY SUBCONTRACTOR'S DESIGN TO MEET DESIGN CRITERIA.
- 3 REFER TO FIRE SUPPRESSION DRAWINGS FOR QUANTITY AND / OR LOCATIONS OF DEVICE(S).
- 4 REFER TO FIRE ALARM PLANS FOR QUANTITY AND / OR LOCATIONS OF DEVICE(S).
- 5 PROVIDE ADDRESSABLE INPUT AND / OR OUTPUT MODULE(S) AS REQUIRED TO ACHIEVE THE FUNCTIONALITY INDICATED IN THE FIRE ALARM MATRIX. BOOSTER PANEL "TBL" (TROUBLE) AND "ACT" (ACTIVATION) SIGNAL SHALL BE INSTALLED USING DUAL MODULES IF POSSIBLE.
- 6 PROVIDE ADDITIONAL BOOSTER PANELS CONNECTED TO THE RSFACU AS REQUIRED PER SUBCONTRACTOR'S DESIGN. WHERE ADDITIONAL BOOSTER PANELS ARE REQUIRED LOCATE AS INDICATED ON PLAN.
- 7 24 VDC TO RSFACU OR NAC PANEL
- 8 PROVIDE REMOTE TEST STATION, INDICATING LIGHT AND SIGN NEAR HVAC UNIT MODULE ON SMOKE DETECTION WHERE INDICATION LIGHT ON THE SMOKE DETECTOR IS NOT VISIBLE FROM FLOOR.
- 9 PROVIDE RETURN IN-DUCT SMOKE DETECTORS FOR DIRECT SHUT DOWN FOR THE FOLLOWING UNIT: AHU-1. SHUT DOWN THROUGH THE EMCS/DDC IS NOT PERMITTED. REFERENCE MECHANICAL DRAWINGS FOR EXACT LOCATION.
- 10 CONNECT TO PORT AES RECEIVERS USING AES MESH RADIO SYSTEM. MONITORING CALL LIST SHALL BE MODIFIED SO THAT PORT DISPATCH IS THE FIRST CALL. A NICET CERTIFIED STAFF SIGNATURE IS REQUIRED FOR THE FIRE ALARM PERMITTING PROCESS.
- 11 MOUNT RADIO TRANSCEIVER ANTENNA PER MANUFACTURER'S RECOMMENDATION. ANTENNA SHALL BE MOUNTED ON FAC INSIDE THE BUILDING.

[illegible]

1 FIRE ALARM ONE-LINE DIAGRAM

SCALE: 12" = 1'-0"



2 TYPICAL MOUNTING DETAIL

SCALE: 12" = 1'-0"

SCALE: 12" = 1'-0"



9400 WARD PARKWAY
KANSAS CITY, MO 64114

BMCD LICENSE NO: ARF-11103

date 10/23/18	detailed N. OLSON
designed C. KNOFF	checked A. MOORE



7759 NE MARY OLSON WAY
PORTLAND, OR 97218
USA

UAL - PDX HANGAR MODIFICATIONS

project 110438	contract CONTRACT
drawing	rev.
FA601 — 0	
sheet	of
file	sheets

RELEASING SERVICE FIRE ALARM CONTROL UNIT (RSFACU) FUNCTIONAL MATRIX																		
	ANNUNCIATION AT LOCAL PANEL			NOTIFICATION									AUXILIARY FUNCTION					
	AUDIO-VISIBLE FIRE ALARM INDICATION BY DEVICE	AUDIO-VISIBLE TROUBLE INDICATION BY DEVICE	AUDIO-VISIBLE SUPERVISORY INDICATION BY DEVICE	MANUAL PULL STATION ALARM SIGNAL TO AIRPORT COMMUNICATIONS CENTER	SMOKE DETECTION ALARM SIGNAL TO AIRPORT COMMUNICATIONS CENTER	FIRE SUPPRESSION ACTIVATION ALARM SIGNAL TO AIRPORT COMMUNICATIONS CENTER	HEAT DETECTION ALARM SIGNAL TO AIRPORT COMMUNICATIONS CENTER	COMMON TROUBLE SIGNAL TO AIRPORT COMMUNICATIONS CENTER	COMMON SUPERVISORY SIGNAL TO AIRPORT COMMUNICATIONS CENTER	FOAM SYSTEM DISABLED SUPERVISORY SIGNAL TO AIRPORT COMMUNICATIONS CENTER	FIRE ALARM AUDIBLE NOTIFICATION	FIRE ALARM VISIBLE NOTIFICATION	ACTIVATE EXISTING BLUE BEACONS IN HANGAR BAY	SHUT-DOWN ASSOCIATED AIR HANDLING EQUIPMENT	RELEASE FOAM / WATER FLOW CONTROL VALVE (EAST HANGAR BAY)	RELEASE FOAM / WATER FLOW CONTROL VALVE (WEST HANGAR BAY)	RELEASE HOSE STATION FLOW CONTROL VALVE	RELEASE FOAM / WATER MONITOR FLOW CONTROL VALVE
MATRIX SHOWS THE FUNCTIONALITY OF ALL NEW DEVICES. EXISTING DEVICES SHALL BE RECONNECTED TO THE NEW RSFACU WHERE INDICATED TO PERFORM THEIR ORIGINAL FUNCTIONALITY.																		
ALARM SIGNALS																		
MANUAL FIRE ALARM STATIONS	X			X							X	X						
SMOKE DETECTOR OVER RSFACU, AND, NAC PANELS	X				X						X	X						
FOAM DELUGE SYSTEM ALARM PRESSURE SWITCH	X					X					X	X						
HEAT DETECTION IN HANGAR BAY (EAST SIDE)	X					X	X				X	X	X		X		X	X
HEAT DETECTION IN HANGAR BAY (WEST SIDE)	X					X	X				X	X	X			X	X	X
FOAM RELEASE STATION	X					X					X	X	X				X	X
PRESSURE SWITCH ON FOAM / WATER RISER	X					X							X					
TROUBLE SIGNALS																		
AC POWER FAILURE		X						X										
LOW BATTERY		X						X										
OPEN CIRCUIT FAULT		X						X										
GROUND FAULT		X						X										
NOTIFICATION APPLIANCE CIRCUIT SHORT		X						X										
COMPONENT COMMON TROUBLE		X						X										
SUPERVISORY SIGNALS																		
COMPONENT COMMON SUPERVISORY			X						X									
GENERAL VALVE SUPERVISORY			X						X									
FOAM / WATER AND CONCENTRATE CONTROL VALVE SUPERVISORY			X							X								
IN DUCT SMOKE DETECTOR			X						X					X				

no.

date

by

ckd

description

0

04/12/19

CK

AM

ISSUED FOR PERMIT

BURNS

MCDONNELL

9400 WARD PARKWAY
KANSAS CITY, MO 64114

BMCD LICENSE NO: ARF-11103

date

10/23/18

detailed

N. OLSON


designed

C. KNOFF

checked

A. MOORE

UNITED



7759 NE MARY OLSON WAY
PORTLAND, OR 97218
USA

UAL - PDX HANGAR MODIFICATIONS

FIRE ALARM MATRIX

project

110438

contract

CONTRACT

drawing

FA602 — 0

rev.

sheet

of

sheets

file

A

B

C

D

E

F

G

K

AUTOMATIC



Shown with Q9033A
Aluminum Mounting Arm

Multispectrum IR Flame Detector X3301



DESCRIPTION



The X3301 is a multispectrum infrared (MIR) flame detector. It provides unsurpassed detection of fires from light to heavy hydrocarbon fuels combined with the highest degree of false alarm rejection. The detector has Division and Zone explosion-proof ratings and is suitable for use in indoor and outdoor applications.

The X3301 contains three IR sensors with their associated signal processing circuitry. The standard output configuration includes fire alarm, fault and auxiliary relays, with an isolated 0 to 20 mA output model with optional HART communication.

The detector provides superior performance in applications that are at the extremes, and where background infrared radiation is a normal condition:

- Hangars
- Offshore production platforms
- Offshore production ships
- Refineries
- Production facilities
- Loading racks
- Compressor stations
- Turbine enclosures
- Airport water curtains
- Automotive Painting
- LNG/LPG
- Gas Separation Plants
- Warehousing
- Marine

HIGHLIGHTS

X3301 TECHNOLOGY FEATURES

- ▲ Complies with FM 3260
- ▲ EN54 certified
- ▲ Certified SIL 2 capable
- ▲ ATEX Directive compliant
- ▲ Certified performance to multiple fuel types and fire sizes
- ▲ EQP models available
- ▲ Long detection range to carbonaceous fires
- ▲ HART models available
- ▲ FDT/DTM capable
- ▲ Multiple sensitivity levels
- ▲ Maximum false alarm rejection
- ▲ Reliable flame detection with modulated IR background
- ▲ Microprocessor controlled heated optics
- ▲ Calibrated automatic optical check for each sensor eliminates need for testing with external test lamp
- ▲ RFI and EMC Directive compliant
- ▲ Event logging with time and date stamp
- ▲ Integral wiring compartment for ease of installation
- ▲ Operates under adverse weather conditions and in dirty environments

BENEFITS

- ▲ Single detector for multiple hydrocarbon fuels
- ▲ Low cost of coverage
- ▲ Ability to detect smaller fires earlier
- ▲ Solid cone of vision to 125 feet for methane
- ▲ Better detection zoning capability
- ▲ Best combination of flame detection and false alarm rejection
- ▲ Low maintenance costs
- ▲ Reliable fault diagnostics
- ▲ Suitable for heavy industrial applications
- ▲ Explosion/flame proof (Ex d) or increased safety installations (Ex d e) in hazardous locations

SPECIFICATIONS

Operating Voltage	24 Vdc nominal (18 Vdc minimum, 30 Vdc maximum). Maximum ripple is 2 volts peak-to-peak.
Power Consumption	4 watts minimum (without heater), 17 watts at 30 Vdc with EOL resistor installed and heater on maximum.
Relays	<p>Contacts rated 5 amperes at 30 Vdc.</p> <p>Fire Alarm: — Form C (NO and NC contacts) — normally de-energized — latching/non-latching.</p> <p>Fault: — Form A (NO contacts) — normally energized — latching/non-latching.</p> <p>Auxiliary: — Form C (NO and NC contacts) — normally energized/de-energized — latching/non-latching.</p>
Current Output (Optional)	0–20 mA (± 0.3 mA), with a maximum loop resistance of 500 ohms from 18–19.9 Vdc, 600 ohms from 20–30 Vdc.
Temperature Range	<p>Operating: –40°F to +167°F (–40°C to +75°C).</p> <p>Storage: –67°F to +185°F (–55°C to +85°C).</p> <p>Hazardous location ratings from –55°C to +125°C.</p>
Humidity Range	0 to 95% relative humidity, can withstand 100% condensing humidity for short periods of time.
Wiring	16 AWG or 2.5 mm ² shielded cable is recommended.
Enclosure Material	Copper-free aluminum (painted) or stainless steel (316/CF8M Cast).
Conduit Entry Size	3/4 inch NPT or M25.
Warranty	5 years.

Response Characteristics

	Fuel	Size	Distance Ft (m)	Average Response Time (seconds)***
Very High Sensitivity	n-Heptane	1 x 1 foot	265 (80.7)*	22
	n-Heptane	1 x 1 foot	250 (76.2)	17
	n-Heptane	1 x 1 foot	100 (30.5)	3
	n-Heptane	6 in. x 6 in.	100 (24.4)	7
	Isopropanol	6 in. x 6 in.	70 (21.3)	6
	Diesel	1 x 1 foot	175 (53.3)	6**
	Ethanol	1 x 1 foot	210 (64)	11
	Methanol	6 in. x 6 in.	40 (12.2)	3
	Methanol	1 x 1 foot	150 (45.7)	7
	Methanol	1 x 1 foot	150 (45.7)	5**
	Methane	32 inch plume	125 (38.1)	5
	Propane	32 inch plume	125 (38.1)	5
	Jet A	1 x 1 foot	150 (45.7)	4**
	JP-5	2 x 2 feet	235 (71.6)	3**
	JP-8	1 x 1 foot	150 (45.7)	5**
	Class A	Ø12 in. x 7 in.	150 (45.7)	3**
Medium Sensitivity	n-Heptane	1 x 1 foot	100 (30.5)	7
	n-Heptane	1 x 1 foot	50 (15.24)	<2
	Diesel	1 x 1 foot	70 (21.3)	4**
	Ethanol	1 x 1 foot	85 (25.9)	7
	Methanol	1 x 1 foot	70 (21.3)	6
	Methane	32 inch plume	70 (21.3)	6
	Methane	32 inch plume	55 (16.8)	4
	Propane	32 inch plume	75 (22.8)	<5
	JP-5	2 x 2 feet	150 (45.7)	3**
	Class A	Ø12 in. x 7 in.	50 (15.24)	4**

* Outdoor test condition.

** 10 second pre-burn from ignition.

*** Add 2 seconds for EQP Model.

Ø Diameter

NOTE: Refer to the X3301 instruction manual (95-8704) for additional sensitivity levels.

Shipping Weight
(Approximate)

Aluminum: 7 lbs. (3.2 kg).
Stainless Steel: 13.8 lbs. (6.3 kg).

Field of View

90° horizontal by 75° vertical, at a minimum of 70% of the on-axis detection distance.

Certification



Class I, Div. 1, Groups B, C & D (T4A);
Class II, Div. 1, Groups E, F & G (T4A);
Class I, Div. 2, Groups A, B, C & D (T3C);
Class II, Div. 2, Group F & G (T3C);
Class III
Enclosure NEMA/Type 4X.

For FM and CSA Zone approval information, refer to the X3301 instruction manual (95-8704).



IEC 61508

Certified SIL 2 Capable.
Applies to specific models –
Refer to the SIL 2 Certified
X3301 Safety manual (95-8720).

RUSSIA & KAZAKHSTAN



VNIIFTRI
TP TC 012/2011
TC RU C-US. F506.B.00418

2ExdIICT6/T5 IP66
T6 (Tamb = –50°C to +60°C)
T5 (Tamb = –50°C to +75°C)
Ex tb IIIC T130°C Db.
– OR –
1ExdIICT6/T5/T4 IP66
T6 (Tamb = –55°C to +60°C)
T5 (Tamb = –55°C to +75°C)
T4 (Tamb = –55°C to +125°C)
Ex tb IIIC T130°C Db.

RUSSIA



VNIIP
CERTIFICATE OF CONFORMITY TO
TECHNICAL REGULATIONS,
GOST R 53325-2012
C-US. F501.B.02910



Approvals to EN54-10. See instruction manual for details.



US Coast Guard
Coast Guard Approval No. 161.002/49/0.



DEMKO 01 ATEX 130204X
Increased Safety Model

CE 0539 Ex II 2 G

Ex d e IIC T6...T5 Gb
Ex tb IIIC T130°C
T6 (Tamb = –50°C to +60°C)
T5 (Tamb = –50°C to +75°C)
IP66/IP67.

Flameproof Model

CE 0539 Ex II 2 G

Ex d IIC T6...T4 Gb
Ex tb IIIC T130°C
T6 (Tamb = –55°C to +60°C)
T5 (Tamb = –55°C to +75°C)
T4 (Tamb = –55°C to +125°C)
IP66/IP67.



IECEx Certificate of Conformity

IECEx ULD 06.0017X
Ex d e IIC T6...T5 Gb
Ex tb IIIC T130°C
T6 (Tamb = –50°C to +60°C)
T5 (Tamb = –50°C to +75°C)
IP66/IP67.
– OR –
Ex d IIC T6...T4 Gb
Ex tb IIIC T130°C
T6 (Tamb = –55°C to +60°C)
T5 (Tamb = –55°C to +75°C)
T4 (Tamb = –55°C to +125°C)
IP66/IP67.



UL-BR 12.0093X
Ex d e IIC T6-T5 Gb IP66/IP67
Ex tb IIIC T130°C
T6 (Tamb = –50°C to +60°C)
T5 (Tamb = –50°C to +75°C).
– OR –
Ex d IIC T6-T4 Gb IP66/IP67
Ex tb IIIC T130°C
T6 (Tamb = –55°C to +60°C)
T5 (Tamb = –55°C to +75°C)
T4 (Tamb = –55°C to +125°C).




DNV
Type Approval Certificate Number A-13995.
DNV Certificate Number MED-B-9427.

Specifications subject to change without notice.


All trademarks are the property of their respective owners.
© 2015 Detector Electronics Corporation. All rights reserved.



Corporate Office
6901 West 110th Street | Minneapolis, MN 55438 USA
Operator: 952.941.5665 or 800.468.3244
Customer Service: 952.946.6491 or 800.765.3473
www.det-tronics.com | Email: det-tronics@det-tronics.com



D1 NORTH ELEVATION
SCALE: 3/32" = 1'-0"



H1 SOUTH ELEVATION
SCALE: 3/32" = 1'-0"



no.	date	by	ckd	description
0	4/12/19	LS	LT	ISSUE FOR PERMIT

Level 4	133' - 7 7/8"
Level 3	129' - 2"
Level 2	114' - 7"
Level 1	100' - 0"

BURNS MCDONNELL 9400 WARD PARKWAY KANSAS CITY, MO 64114 BMCD LICENSE NO: ARF-11103	
date 11/02/18	detailed L. SLEDGE
designed C.GANIERE	checked L. TOP

UNITED

7759 NE MARY OLSON WAY
PORTLAND, OR 97218
USA

UAL – PDX HANGAR MODIFICATIONS ELEVATIONS	
project 110438	contract CONTRACT
drawing A-251 – 0	rev.
sheet file	of sheets