

# Development Services

## From Concept to Construction

Phone: 503-823-7300 Email: [bds@portlandoregon.gov](mailto:bds@portlandoregon.gov) 1900 SW 4th Ave, Portland, OR 97201

More Contact Info (<http://www.portlandoregon.gov/bds/article/519984>)



### APPEAL SUMMARY

**Status:** Hold for Additional Information- Held over from ID 23279 (1/8/20) for additional information

**Appeal ID:** 23360

**Project Address:** 1202 NW Irving St

**Hearing Date:** 1/22/20

**Appellant Name:** Ruwan Jayaweera, PE

**Case No.:** M-002

**Appellant Phone:** 503-226-2921

**Appeal Type:** Mechanical

**Plans Examiner/Inspector:** Thomas Ng, Ali Soheili

**Project Type:** commercial

**Stories:** 9 **Occupancy:** R-1 **Construction Type:** 1-B

**Building/Business Name:** Proper Hotel

**Fire Sprinklers:** Yes - Throughout

**Appeal Involves:** Erection of a new structure, Reconsideration of appeal

**LUR or Permit Application No.:** 19-201292-EA

**Plan Submitted Option:** pdf [File 1]

**Proposed use:** Hotel

### APPEAL INFORMATION SHEET

#### Appeal item 1

**Code Section** 6.4.3.3.5.1 Guest Room Ventilation Control

#### Requires

Code Section being appealed:  
2019 Oregon Zero Energy Ready Commercial Code (ASHRAE 90.1 2016)

Regulation Requirement:  
6.4.3.3.5.1 Guest Room Ventilation Control

Within 30 minutes of all occupants leaving the guest room, ventilation and exhaust fans shall automatically be turned off, or isolation devices serving each guest room shall automatically shut off the supply of outdoor air to the guest room and shut off exhaust air from the guest room.

#### Code Modification or Alternate Requested

The proposed design (constant central airflow DOAS systems with heat recovery) is more energy efficient than the baseline code minimum system (non-heat recovery ventilation with direct outside air connections for each guest room and separate exhaust fans for each guest room with shut-off for un-occupied guest rooms). Note that we are assuming that a Code system would be a distributed outside air and exhaust system to avoid the added first cost associated with two shutoff dampers at each guest room required to meet Code with a central system. With a distributed system and assuming the hotel rooms are rented 75% of the time and occupied 18 hours per day (4970 hours), heat recovery is not required per Table 6.5.6.1-1 (less than 8000 hours operating).

#### Proposed Design

The hotel guest room ventilation system consists of: a) three (3) roof top Dedicated Outdoor Air System (DOAS) air handlers with energy recovery wheels (assumed 60% heat recovery effectiveness for conservative calculations) and VFD controlled fans with premium efficiency motors, b) multiple fully ducted risers and branch ductwork to each guest room for supply air, and

c) multiple return shafts connected to guest rooms via sub-ducts at the shafts to eliminate the need for fire/smoke dampers.

The proposed design is to be running during all occupied hours of operation for the building and continuous ventilation air and exhaust air is to be provided for each guest room. The amount of outdoor air and exhaust air from guest rooms is also higher than code minimum to ensure better indoor air quality.

Energy from the exhaust air is exchanged and transferred to the incoming outdoor air supply inside the DOAS units via heat recovery wheels to further increase the overall efficiency of the system over the baseline code minimum system.

---

**Reason for alternative** Energy analysis were completed for each system (constant airflow DOAS with heat recovery VS. baseline non-heat recovery with exhaust and ventilation shut-off). A summary of the results is provided below. The constant airflow DOAS system with heat recovery performs better than the baseline system and saves approximately 22% more energy on an annual basis.

PROPOSED DESIGN CODE DESIGN

FAN ENERGY (KWH) 195,970 19,469

VENTILATION LOADS (KWH) 952,462 759,102

ENERGY RECOVERED (KWH) (541,600) -

TOTAL VENTILATION ENERGY (KWH) 606,831 778,571

In addition, the quantity of outdoor air supplied to and exhausted from each guest room is about 25% higher than code minimum (50 vs 40 CFM for a typical sized guest room) providing more air changes per hour and therefore providing higher quality indoor air.

To summarize, the proposed system design saves more energy on an annual basis than the baseline system while simultaneously providing better indoor air quality.

RECONSIDERATION TEXT:

Additional information was requested by the city (mechanical plans and calculations supporting the appeal). Please refer to the attached mechanical plans: "2019-10-16\_Proper Hotel 100DD Mechanical Set" and calculations "Heat Recovery Analysis 12-10-19".

---

## APPEAL DECISION

**Use of constant airflow DOAS system in lieu of non-heat recovery system with automatic exhaust and ventilation shut off devices: Hold for additional information.**

**Appellant may contact Thomas Ng (503 823-7434) with questions.**

Additional information is submitted as a no fee reconsideration, following the same submittal process and using the same appeals form as the original appeal. Indicate at the beginning of the appeal form that you are filing a reconsideration and include the original assigned Appeal ID number. The reconsideration will receive a new appeal number.

Include the original attachments and appeal language. Provide new text with only that information that is specific to the reconsideration in a separate paragraph(s) clearly identified as "Reconsideration Text" with any new attachments also referenced. No additional fee is required.

MECHANICAL DRAWING LIST	
SHEET #	SHEET NAME
M0.01	SYMBOLS, LEGENDS AND ABBREVIATIONS - MECHANICAL
M0.02	EQUIPMENT SCHEDULE - MECHANICAL
M0.03	EQUIPMENT SCHEDULE - MECHANICAL
M0.04	EQUIPMENT SCHEDULE - MECHANICAL
M2.00	MECHANICAL PLAN, FLOOR - PARKING
M2.00M	MECHANICAL PLAN, FLOOR - PARKING MEZZANINE
M2.01	MECHANICAL PLAN, FLOOR - LEVEL 1
M2.02	MECHANICAL PLAN, FLOOR - LEVEL 2
M2.03	MECHANICAL PLAN, FLOOR - LEVEL 3-7
M2.08	MECHANICAL PLAN, FLOOR - LEVEL 8
M2.09	MECHANICAL PLAN, FLOOR - LEVEL 9
M2.10	MECHANICAL PLAN, FLOOR - LEVEL 10 MECHANICAL
M2.11	MECHANICAL PLAN, FLOOR - ROOF
M4.00	MECHANICAL DETAILS

STANDARD MECHANICAL ABBREVIATIONS			
AF	AIRFOIL	IN	INCH(ES)
AFF	ABOVE FINISHED FLOOR	INSUL	INSULATION
AHP	APPARATUS HOUSING PLENUM	ISOL	ISOLATOR(I/ON)
ALT	ALTERNATIVE	KW	KILOWATT
AL	ALUMINUM	KWH	KILOWATT HOUR
APD	AIR PRESSURE DROP	L	LENGTH
APPROX	APPROXIMATELY	LAT	LEAVING AIR TEMP
ARCH	ARCHITECT(URAL)	LB	POUND
AUTO	AUTOMATIC	LDB	LEAVING DRY BULB
BDD	BACKDRAFT DAMPER	LF	LINEAR FEET
BHP	BREAK HORSEPOWER	LFT	LEAVING FLUID TEMPERATURE
BI	BACKWARD INCLINED	LVG	LEAVING
BLDG	BUILDING	LWB	LEAVING WET BULB
BSMT	BASEMENT	LWT	LEAVING WATER TEMPERATURE
BTU	BRITISH THERMAL UNIT	MAX	MAXIMUM
BTUH	BRITISH THERMAL UNITS PER HOUR	MBH	THOUSAND BTU PER HOUR
CFH	CUBIC FEET PER HOUR	MCA	MINIMUM CIRCUIT AMPACITY
CFM	CUBIC FEET PER MINUTE	MECH	MECHANICAL
CFS	CUBIC FEET PER SECOND	MERV	MINIMUM EFFICIENCY REPORTING VALUE
CLG	CEILING OR COOLING	MFR	MANUFACTURER
CONC	CONCRETE	MIN	MINIMUM
CONN	CONNECTION	MISC	MISCELLANEOUS
CONT	CONTINUE(D)UATION	MOP	MAXIMUM OVERCURRENT PROTECTION
CL	CENTERLINE	MTD	MOUNTED
DB	DRY BULB	NC	NORMALLY CLOSED
DDC	DIRECT DIGITAL CONTROL	NIC	NOT IN CONTRACT
DEFL	DEFLECTION	NO	NORMALLY OPEN
DN	DOWN	OAD	OUTSIDE AIR DAMPER
DP	DEW POINT	OAT	OUTSIDE AIR TEMPERATURE
DWDI	DOUBLE WIDTH DOUBLE INLET	OC	ON CENTER DISTANCE
DWG	DRAWING	OSA	OUTSIDE AIR
EA	EXHAUST AIR	PH	PHASE
EAD	EXHAUST AIR DAMPER	PP	POLYPROPYLENE
EAT	ENTERING AIR TEMPERATURE	PSI	POUNDS PER SQUARE INCH
ECM	ELECTRONICALLY COMMUTATED MOTOR	PVC	POLYVINYL CHLORIDE
EDB	ENTERING DRY BULB	PVS	PVC COATED STEEL
EFF	EFFICIENCY	R (RAD)	RADIUS
EFT	ENTERING FLUID TEMPERATURE	RA	RETURN AIR
ELEC	ELECTRIC(AL)	RAD	RETURN AIR DAMPER
ELEV	ELEVATION	REV	REVISION
ENGR	ENGINEER	RH	RELATIVE HUMIDITY
EQ	EQUAL	RPM	REVOLUTIONS PER MINUTE
EQUIP	EQUIPMENT	SA	SUPPLY AIR
ESP	EXTERNAL STATIC PRESSURE	SCFM	STANDARD CUBIC FEET PER MINUTE
EWB	ENTERING WET BULB	SD	SMOKE DAMPER
EWT	ENTERING WATER TEMPERATURE	SECT	SECTION
EX	EXTRACTOR	SENS	SENSIBLE
EXH	EXHAUST	SIM	SIMILAR
EXIST	EXISTING	SP	STATIC PRESSURE
EXP	EXPANSION	SPEC	SPECIFICATION
F	DEGREES FAHRENHEIT	SPEC	SPECIFICATION
FC	FORWARD CURVED	SF	SQUARE FOOT(FEET)
FIG	FIGURE	SO IN	SQUARE INCH(ES)
FLT	FILTER	SS	STAINLESS STEEL
FLA	FULL LOAD AMPACITY	STL	STEEL
FLEX	FLEXIBLE	STRUCT	STRUCTURE(E)AL
FPD	FLUID PRESSURE DROP	SWP	SINGLE WALL PLENUM
FBM	FEET PER MINUTE	SWSI	SINGLE WIDTH SINGLE INLET
FPS	FEET PER SECOND	TEMP	TEMPERATURE
FT	FEET/FOOT	TSP	TOTAL STATIC PRESSURE
FTR	FINNED TUBE RADIATOR	TYP	TYPICAL
FU	FIXTURE UNIT	V	VOLTS
FUT	FUTURE	VD	VOLUME DAMPER
FV	FACE VELOCITY	VEL	VELOCITY
GA	GAGE/GAUGE	VERT	VERTICAL
GAL	GALLON	VFD	VARIABLE FREQUENCY DRIVE
GLY	GALVANIZED	VTR	VENT THROUGH ROOF
GPM	GALLONS PER HOUR	W	WIDTH
GPH	GALLONS PER HOUR	WB	WET BULB
H	HEIGHT	WG	WATER GAUGE
HORIZ	HORIZONTAL	WPD	WATER PRESSURE DROP
HP	HORSEPOWER	WTD	WATER TEMPERATURE DROP
HTG	HEATING	WTR	WATER TEMPERATURE RISE
ID	INSIDE(DIAMETER/DIMENSION)	WI	WITH
IE	INVERT ELEVATION	W/O	WITHOUT

HVAC PIPING			
	D	DRAIN (CONDENSATE/INDIRECT)	
	RS	REFRIGERANT SUCTION	
	RL	REFRIGERANT LIQUID	

CONTROL SYMBOLS	
	DAMPER WITH OPERATOR
	2-WAY CONTROL VALVE
	3-WAY CONTROL VALVE
	DIGITAL OUTPUT FROM DDC PANEL
	ANALOG OUTPUT FROM DDC PANEL
	ANALOG INPUT TO DDC PANEL
	DIFFERENTIAL PRESSURE SWITCH
	EP VALVE
	STATIC PRESSURE CONTROLLER
	VELOCITY PRESSURE TRANSMITTER
	PNEUMATIC RELAY
	DAMPER END SWITCH
	CARBON MONOXIDE SENSOR
	CARBON DIOXIDE SENSOR
	AIR MONITORING STATION
	VELOCITY PRESSURE PROBE
	PE SWITCH
	DUCT SMOKE DETECTOR
	WATER FLOW METER WITH ELECTRONIC TRANSMITTER
	PUSH BUTTON SWITCH
	SWITCHED MAIN AIR
	PRESSURE TRANSMITTER
	MAIN AIR
	ELECTRONIC HUMIDITY TRANSMITTER
	DUCT MOUNTED HIGH LIMIT HUMIDISTAT
	ELECTRONIC TEMPERATURE SENSOR
	FLOW SWITCH
	ELECTRONIC SENSOR WITH AVERAGING

SYMBOLS			
	ACCESS PANEL		CAP EXISTING / CAP FOR FUTURE
	BELOW GRADE / FLOOR		RELOCATE EXISTING
	CONNECT TO EXISTING		REMOVE EXISTING
	EXISTING TO REMAIN		NOTE
CALL OUT SYMBOLS			
	WALL MOUNTED		CARBON MONOXIDE
	PENDANT MOUNTED		CARBON DIOXIDE
	TEMPERATURE		NITROGEN OXIDE
	HUMIDITY		
ROOM SENSORS			

DUCT LEGEND	
	CFM TYPE
	FLOW DIRECTION (NONE SHOWN IF 4-WAY)
	RETURN EXHAUST SUPPLY
	SEE SPEC FOR TYPE
	SEE SCHEDULE FOR SIZE
	CEILING DIFFUSERS & GRILLES
	SIDEWALL SLOT & FLOOR GRILLES
	TERMINAL UNIT
	UNIT NUMBER
	FLOOR UNIT IS LOCATED ON
	AIR HANDLER NUMBER
	TERMINAL UNIT
	EQUIPMENT
	COMBINATION FIRE/SMOKE
	SMOKE
	FIRE
	AUTOMATIC
	VOLUME
	DUCT SECTIONS
	RETURN OR EXHAUST AIR FLOW
	SUPPLY OR OUTSIDE AIR FLOW
	UC 1/2"
	UNDERCUT DOOR

LOW PRESSURE DUCTWORK			
	SECTION		PLAN
	FLEX DUCT		RETURN OR EXHAUST GRILLE CONNECTION
	SECTION		PLAN
	FLEX DUCT		SUPPLY DIFFUSER CONNECTION
	SECTION		PLAN
	LINED PLENUM		SPIN-IN FITTING
	RETURN OR EXHAUST GRILLE		SUPPLY DIFFUSER SIDE FLEX CONNECTION
	SECTION		PLAN
	SUPPLY DIFFUSER HARD CONNECTION		SIDEWALL SUPPLY GRILLE CONNECTION

MEDIUM PRESSURE DUCTWORK			
	CONICAL TEE		LOW LOSS
	LATERAL TEE		CONICAL LATERAL
	BRANCH FITTINGS		ELBOW
	Y-BRANCH		BELL MOUTH
	REDUCER		REDUCER

DUCT DETAILS (LOW VELOCITY)			
	RADIUS ELBOW		TURNING VANES IN ALL ELBOWS AND TEES
	FLEX CONNECTION		ACOUSTICAL LINER
	SIZE SHOWN IS CLEAR AIR PASSAGE		SIZE SHOWN IS CLEAR AIR PASSAGE
	LESS THAN 15"		15" TO 30"
	GREATER THAN 30"		DUCT OFFSETS
	RECTANGULAR TO ROUND		TRANSITIONS
	RECTANGULAR DUCT FITTING		RECTANGULAR TO ROUND FITTING

GENERAL NOTE	
THIS IS A STANDARD LEGEND SHEET, THEREFORE, SOME SYMBOLS MAY APPEAR ON THIS SHEET THAT DO NOT APPEAR ON THE DRAWINGS.	
MISC. VALVES & COCKS	
	SHUT-OFF VALVE
	GLOBE VALVE
	SHUT-OFF VALVE W/ TAMPER SWITCH
	TRIPLE DUTY VALVE
	CHECK VALVE
	2-WAY CONTROL VALVE
	3-WAY CONTROL VALVE
	BALANCING VALVE
	FLOW CONTROL VALVE
	SOLENOID VALVE
	PRESSURE REDUCING VALVE
	AIR VENT (MANUAL/AUTOMATIC)
	RELIEF VALVE
	STRAINER
	STRAINER W/ BLOWDOWN
	DRAIN VALVE
	HOSE BIBB
	WALL HYDRANT
	GROUND HYDRANT
	STEAM TRAP
	PRESSURE GAUGE
	PRESSURE/TEMPERATURE TEST PLUG
	THERMOMETER
	FLOW SWITCH
	TEMPERATURE TRANSMITTER
	SHOCK ARRESTOR
	VACUUM BREAKER
	WATER FLOW METER
	REDUCED PRESSURE BACKFLOW ASSEMBLY
	DOUBLE CHECK VALVE ASSEMBLY
	DOUBLE CHECK DETECTOR ASSEMBLY
	BACKWATER VALVE
	UNDERGROUND GATE VALVE W/BOX
	UNDERGROUND GATE W/POST INDICATOR
	OUTSIDE SCREW & YOKE
	Y PATTERN BOILER BLOWDOWN VALVE
	NON-RETURN STOP VALVE
	QUICK OPENING BOILER BLOWDOWN VALVE

MISC. FITTINGS & SYMBOLS	
	DIRECTION OF FLOW
	DIRECTION OF SLOPE
	PIPE SLEEVE
	REDUCER
	ANCHOR
	ELBOW (90"
	ELBOW (45"
	TEE
	CROSS
	PIPING CONNECTIONS
	JOINT OR COUPLING POINT
	UNION
	FLANGED CONNECTION
	CAP
	PLUG OR BLIND FLANGE
	RISER
	ELBOW UP
	ELBOW DOWN
	TEE UP
	TEE DOWN
	HORIZONTAL TEE
	FLEXIBLE CONNECTION
	BALL JOINT
	MECHANICAL COUPLING
	HEAT TRACE

NEW AND EXISTING WORK	
	EXISTING DUCT WORK
	NEW DUCT WORK
	EXISTING PIPING
	NEW PIPING



DESIGN CONDITIONS - PORTLAND, OR					
SPACE	WINTER			SUMMER	
	TEMPERATURE	HUMIDITY		TEMPERATURE	HUMIDITY
OUTDOOR	25.2 ° F DB	9.6 ° F DP / 90.1 HR / 29.8 ° F MCOB		91.4 ° F DB / 67.3 ° F MCWB	63.2 ° F DP / 87.0 HR / 75.1 ° F MCOB
INDOOR	70 ° F ± 2 ° F DB	50% RH MAX, NO MINIMUM		75 ° F ± 2 ° F DB	50% RH MAX, NO MINIMUM
GENERAL NOTES:					
A. OUTDOOR CONDITIONS BASED ON ASHRAE FUNDAMENTALS 2013 99.6% AND 0.4% DATA.					

UNIT HEATER SCHEDULE										
TAG	LOCATION SERVICE	TYPE	ELEC. COIL CAPACITY (KW)	ELECTRICAL			GEN. POWER (Y/N)	APPROX. WEIGHT (LBS)	MANUFACTURER & MODEL	NOTES
				VOLTS/ PHASE	MOC P (A)	MCA (A)				
UH-P01	STAIR 1	VERTICAL RECESSED	5	208/1					TRANE	1
UH-P02	STAIR 2	VERTICAL RECESSED	5	208/1					TRANE	1
UH-P03	BIKE STORAGE	VERTICAL RECESSED	5	208/1					TRANE	1
UH-P04	WATER ENTRY	VERTICAL RECESSED	3	208/1					TRANE	1
UH-P05	STORAGE	HORIZONTAL CABINET	5	208/1					TRANE	1
UH-101	VESTIBULE 102	VERTICAL RECESSED	3	208/1					TRANE	1
UH-102	GENERATOR	VERTICAL CABINET	12	208/1					TRANE	1
UH-103	TRASHLOADING	HORIZONTAL CABINET	12	208/1					TRANE	1
UH-104	EAST EXIT CORRIDOR	HORIZONTAL RECESSED	3	208/1					TRANE	1
UH-1001	MECH PENTHOUSE	HORIZONTAL CABINET	12	208/1					TRANE	1
GENERAL NOTES:										
A.										
NOTES:										
1. UNIT MOUNTED THERMOSTAT; SET TO 50 °F										

DIFFUSERS AND GRILLES											
TAG	TYPE	DESCRIPTION	AIRFLOW RANGE		INLET SIZE (IN)	FACE SIZE		MAX NC	THROW (FT)	MANUFACTURER & MODEL	NOTES
			MIN (CFM)	MAX (CFM)		T-BAR (IN)	HARD LID (IN)				
C-1	CEILING SUPPLY DIFFUSER	PERFORATED FACE, MODULAR CORE, ADJUSTABLE 4-WAY THROW	0	125	6x6	24x24	13x13	12	2-2-5	TITUS PMC	
			126	220	8x8	24x24	15x15	17	2-3-6		
			221	345	10x10	24x24	17x17	21	3-4-8		
			346	500	12x12	24x24	19x19	24	3-5-9		
			501	780	16x16	24x24	23x23	28	4-6-11		
C-2	CEILING RETURN/ EXHAUST GRILLE	PERFORATED FACE, STEEL, ROUND DUCT CONNECTION	0	340	10x10	24x24	12x12	17	-	TITUS PAR	
			341	780	15x15	24x24	17x17	22	-		
			781	1,125	18x18	24x24	20x20	24	-		
			1,129	1,670	22x22	24x24	24x24	26	-		
			1,671	3,500	22x46	24x48	24x48	25	-		
S-1	CEILING SUPPLY DIFFUSER	SLOT, FIXED BLADE, INSULATED PLENUM, ADJUSTABLE THROW	0	80	6	24x2	24x2	20	10-15-23	TITUS TBDI-10	1
			81	120	6	48x2	48x2	17	9-16-28		1
			121	180	8	48x2	48x2	25	16-24-34		1
			181	325	10	48x4	48x4	26	21-32-46		2
GENERAL NOTES:											
A. NOISE CRITERIA (NC) BASED ON ROOM ABSORPTION OF 10 dB, MEASURED PER ANSI/ASHRAE STANDARD 70.											
B. THROW VALUES GIVEN FOR TERMINAL VELOCITIES 150, 100, AND 50 FPM FOR ISOTHERMAL CONDITIONS.											
C. ADJUST THROW DIRECTION AND QUANTITY PRIOR TO AIR BALANCING.											
NOTES:											
1. ONE 1-INCH SLOT.											
2. TWO 1-INCH SLOTS.											

ERV SCHEDULE						
TAG NUMBER		LOCATION		ERV-101		
SERVICE				LOADING		
				VENTILATION LT & MEZZ		
OUTSIDE AIR	DESIGN OSA	CFM	1,200			
	CODE MIN OSA	CFM	1,150			
	PRE-FILTER MERV RATING		8			
	FINAL FILTER MERV RATING		-			
SUPPLY FAN	QUANTITY		1			
	AIRFLOW	CFM	1,200			
	FAN TYPE					
	TSP	(IN. WG.)				
	ESP	(IN. WG.)				
	FAN RPM					
	MOTOR BHP					
	MOTOR HP		1.5			
	VOLT/PHASE		460/3			
	VFD		VFD			
EXHAUST FAN	QUANTITY		1			
	AIRFLOW	CFM	1,200			
	FAN TYPE					
	TSP	(IN. WG.)				
	ESP	(IN. WG.)				
	FAN RPM					
	MOTOR BHP					
	MOTOR HP		1.5			
	VOLT/PHASE		460/3			
	VFD		VFD			
HEAT RECOVERY SECTION	OSA	CFM	1,200			
	EXHAUST	CFM	1,200			
	TYPE		STATIC PLATE			
	WINTER	OSA EAT	(°F DB)			
		OSA LAT	(°F DB)			
		EXH EAT	(°F DB)			
		EFFECTIVENESS	%			
	SUMMER	OSA EAT	(°F DBWB)			
		OSA LAT	(°F DBWB)			
		EXH EAT	(°F DBWB)			
		EFFECTIVENESS	%			
	APPROX. WEIGHT		(LBS)	1,000		
	MANUFACTURER & MODEL				RENEWAIRE HE2X	
	NOTES					
GENERAL NOTES:						
A. UNITS HUNG, SUPPORTED BY STRUCTURE.						
B. MINIMUM OSA CALCULATED BASED ON CODE AND ASHRAE STANDARD 62.						
C. PROVIDE SCOR SUFFICIENT TO MEET THE AVAILABLE FAULT CURRENT AT THE DRAWINGS AND ELECTRICAL CONTRACTOR.						
D. HEAT RECOVERY SECTION EFFECTIVENESS IS BASED ON AHRI 1060.						
NOTES:						

AIR HANDLING UNIT SCHEDULE										
TAG NUMBER			DOAS-1001		DOAS-1002		DOAS-1003			
LOCATION			ROOF		ROOF		ROOF			
SERVICE			WEST HOTEL ROOMS		EAST HOTEL ROOMS		CENTRAL HOTEL ROOMS			
TYPE			MULTIZONE		MULTIZONE		MULTIZONE			
MIXING BOX	DESIGN OSA		CFM		6,000		6,000		7,000	
	CODE MIN OSA		CFM		5,500		5,500		6,500	
	PRE-FILTER MERV RATING				8		8		8	
	FINAL FILTER MERV RATING				13		13		13	
	QUANTITY		1		1		1		1	
SUPPLY FAN	AIRFLOW		CFM		6,000		6,000		7,000	
	FAN TYPE									
	TSP		(IN. WG.)							
	ESP		(IN. WG.)							
	FAN RPM									
	MOTOR BHP									
	MOTOR HP				7.5		7.5		7.5	
	VOLT/PHASE		460/3		460/3		460/3		460/3	
	VFD		YES		YES		YES		YES	
	QUANTITY		1		1		1		1	
EXHAUST FAN	AIRFLOW		CFM		6,000		6,000		7,000	
	FAN TYPE									
	TSP		(IN. WG.)							
	ESP		(IN. WG.)							
	FAN RPM									
	MOTOR BHP									
	MOTOR HP				7.5		7.5		7.5	
	VOLT/PHASE		460/3		460/3		460/3		460/3	
	VFD		YES		YES		YES		YES	
	QUANTITY		2		2		2		2	
AIR COOLED CONDENSER FAN	FAN TYPE									
	FLA		1.8		1.8		1.8			
	VOLT/PHASE		460/3		460/3		460/3			
	OSA		CFM		6,000		6,000		7,000	
	EXHAUST		CFM		6,000		6,000		7,000	
	TYPE		WHEEL		WHEEL		WHEEL			
	FLA		0.47		0.47		0.47			
	VOLT/PHASE		460/3		460/3		460/3			
	HEAT RECOVERY SECTION	WINTER	OSA EAT		(°F DB)					
			OSA LAT		(°F DB)					
EXH EAT			(°F DB)							
EFFECTIVENESS			%							
SUMMER		OSA EAT		(°F DBWB)						
		OSA LAT		(°F DBWB)						
		EXH EAT		(°F DBWB)						
		EFFECTIVENESS		%						
ELECTRIC HEATING COIL	KW		20		20		20			
	CONTROL									
	EAT		(°F)							
	LAT		(°F)							
	FLA		24.1		24.1		24.1			
REFRIGERANT COIL	VOLT/PHASE		460/3		460/3		460/3			
	HEATING	EAT		(°F DBWB)						
		LAT		(°F DBWB)						
		EAT		(°F DBWB)						
	COOLING	LAT		(°F DBWB)						
		EER								
		REFRIGERANT								
			(LBS/ SYSTEM)		R-410A		R-410A		R-410A	
	APPROX WEIGHT			(LBS)		4,000		4,000		4,000
	MANUFACTURER & MODEL					AAON RN		AAON RN		AAON RN
NOTES										
GENERAL NOTES:										
A. UNITS MOUNTED ON VIBRATION ISOLATING ROOF CURB.										
B. MINIMUM OSA CALCULATED BASED ON OREGON MECHANICAL SPECIALTY CODE AND ASHRAE STANDARD 62.										
C. HEATING COILS BASED ON MAXIMUM FACE VELOCITY OF 750 FPM, 0.15 IN WG MAXIMUM AIR PRESSURE DROP.										
D. COOLING COILS BASED ON MAXIMUM FACE VELOCITY OF 500 FPM, 0.75 IN WG MAXIMUM AIR PRESSURE DROP.										
E. PROVIDE SCRR SUFFICIENT TO MEET THE AVAILABLE FAULT CURRENT AT THE PANELBOARD OR SWITCHBOARD FROM WHICH THE UNIT IS FED, OR AS OTHERWISE INDICATED ON THE MECHANICAL EQUIPMENT CONNECTION SCHEDULES. ...										
F. HEAT RECOVERY SECTION EFFECTIVENESS IS BASED ON AHRI 1060.										
NOTES:										
1. ARRANGE UNIT FOR SINGLE POINT POWER CONNECTION W/ DISCONNECT SWITCH. PROVIDE A SEPARATE, DEDICATED 120V CONNECTION FOR RECEPTACLE(S) AND LIGHTS.										

VRF INDOOR UNIT SCHEDULE															
TAG	UNIT QUANTITY	OUTDOOR UNIT	LOCATION	SERVICE	TYPE	AIRFLOW (CFM)	COOLING		HEATING	ELECTRICAL		GEN POWER (Y/N)	APPROX WEIGHT (LBS)	MANUFACTURER & MODEL	NOTES
							TOTAL (BTU/h)	SENSIBLE (BTU/h)	TOTAL (BTU/h)	VOLT/ PHASE	RLA (A)				
FCU-P01	1	ACCU-1001	LEVEL P	ENGINEERING	4-WAY CASSETTE		13352	10307	17100	208/1	0.2		60	LG ARNU	
FCU-P02	1	ACCU-1001	LEVEL P	IT	4-WAY CASSETTE		10682	8239	13649	208/1	0.2		60	LG ARNU	
FCU-P03	1	ACCU-1001	LEVEL P	F & B STORAGE	4-WAY CASSETTE		10682	8239	13649	208/1	0.2		60	LG ARNU	
FCU-P04	1	ACCU-1018	LEVEL P	FIRE PUMP	WALL MOUNTED		12300		13600	208/1	0.3	Y	30	LG ARNU	
FCU-P05	1	ACCU-1018	LEVEL P	ELECTRICAL	WALL MOUNTED		12300		13600	208/1	0.3	Y	30	LG ARNU	
FCU-M01	1	ACCU-1001	LEVEL M	GEN MGR	4-WAY CASSETTE		4747	3541	6100	208/1	0.2		60	LG ARNU	
FCU-M02	1	ACCU-1001	LEVEL M	HR	4-WAY CASSETTE		4747	3541	6100	208/1	0.2		60	LG ARNU	
FCU-M03	1	ACCU-1001	LEVEL M	OPEN OFFICE	DUCTED		10696	8968	13600	208/1	2.3		60	LG ARNU	
FCU-M04	1	ACCU-1001	LEVEL M	ACCOUNTING	4-WAY CASSETTE		4747	3541	6100	208/1	0.2		60	LG ARNU	
FCU-M05	1	ACCU-1001	LEVEL M	LINEN	DUCTED		8348	7074	10900	208/1	2.3		60	LG ARNU	
FCU-M06	1	ACCU-1001	LEVEL M	LOCKER B	DUCTED		6522	5562	8500	208/1	2.3		60	LG ARNU	
FCU-M07	1	ACCU-1001	LEVEL M	LOCKER A	DUCTED		6522	5562	8500	208/1	2.3		60	LG ARNU	
FCU-M08	1	ACCU-1001	LEVEL M	UNIFORM	4-WAY CASSETTE		4747	3541	6100	208/1	0.2		60	LG ARNU	
FCU-M09	1	ACCU-1001	LEVEL M	CONF	4-WAY CASSETTE		6528	5056	8500	208/1	0.2		60	LG ARNU	
FCU-M10	1	ACCU-1001	LEVEL M	F&B STORAGE	DUCTED		8348	7074	10900	208/1	2.3		60	LG ARNU	
FCU-M11	1	ACCU-1018	LEVEL M	TELE/ELEC	DUCTED		10696	8968	13600	208/1	2.3	Y	60	LG ARNU	
FCU-102	1	ACCU-1018	LEVEL 1	FCC	DUCTED		13392	11310	17100	208/1	2.3	Y	60	LG ARNU	
FCU-103	1	ACCU-1002	LEVEL 1	BAR/LOUNGE A	DUCTED		36523	28982	47000	208/1	2.3		60	LG ARNU	
FCU-104	1	ACCU-1002	LEVEL 1	BAR/LOUNGE B	DUCTED		36523	28982	47000	208/1	2.3		60	LG ARNU	
FCU-105	1	ACCU-1002	LEVEL 1	HOTEL LOBBY	DUCTED		36523	28982	47000	208/1	2.3		60	LG ARNU	
FCU-106	1	ACCU-1002	LEVEL 1	RECEPTION	DUCTED		6522	5562	8500	208/1	2.3		60	LG ARNU	
FCU-107	1	ACCU-1002	LEVEL 1	LOBBY SUPPORT	4-WAY CASSETTE		4748	3541	6100	208/1	0.2		60	LG ARNU	
FCU-108	1	ACCU-1002	LEVEL 1	KITCHEN	DUCTED		83081	62499	107500	208/1	5.2		60	LG ARNU	
FCU-109	1	ACCU-1002	LEVEL 1	DINING A	DUCTED		31479	24913	40600	208/1	2.3		60	LG ARNU	
FCU-110	1	ACCU-1002	LEVEL 1	DINING B	DUCTED		31479	24913	40600	208/1	2.3		60	LG ARNU	
FCU-111	1	ACCU-1002	LEVEL 1	EVENT LOBBY	DUCTED		83081	62499	107500	208/1	2.3		60	LG ARNU	
FCU-112	1	ACCU-1002	LEVEL 1	EVENT A	DUCTED		16609	13863	21500	208/1	2.3		60	LG ARNU	
FCU-113	1	ACCU-1002	LEVEL 1	EVENT B	DUCTED		16609	13863	21500	208/1	2.3		60	LG ARNU	
FCU-114	1	ACCU-1002	LEVEL 1	SEC/ELEC	DUCTED		8348	7074	10900	208/1	2.3		60	LG ARNU	
FCU-115	1	ACCU-1002	LEVEL 1	HSKP	DUCTED		13392	11310	17100	208/1	2.3		60	LG ARNU	
FCU-116	1	ACCU-1002	LEVEL 1	BREAK	DUCTED		13392	11310	17100	208/1	2.3		60	LG ARNU	
FCU-117	1	ACCU-1002	LEVEL 1	PREP	DUCTED		13392	11310	17100	208/1	2.3		60	LG ARNU	
FCU-201	1	ACCU-1003	LEVEL 2	FITNESS	DUCTED		36522	28981	47000	208/1	2.3		60	LG ARNU	
FCU-301	1	ACCU-1019	LEVEL 3	TELCO	WALL MOUNTED		12300		13600	208/1	0.3		30	LG ARNU	
FCU-501	1	ACCU-1019	LEVEL 5	TELCO	WALL MOUNTED		12300		13600	208/1	0.3		30	LG ARNU	
FCU-701	1	ACCU-1019	LEVEL 7	TELCO	WALL MOUNTED		12300		13600	208/1	0.3		30	LG ARNU	
FCU-914	1	ACCU-1019	LEVEL 9	TELCO	WALL MOUNTED		12300		13600	208/1	0.3		30	LG ARNU	
FCU-901	1	ACCU-1017	LEVEL 9	EVENTS LOBBY	DUCTED		46962	39281	61400	208/1	2.5		60	LG ARNU	
FCU-902	1	ACCU-1017	LEVEL 9	EVENTS	DUCTED		23481	19641	30700	208/1	2.3		60	LG ARNU	
FCU-903	1	ACCU-1017	LEVEL 9	EVENTS	DUCTED		23481	19641	30700	208/1	2.3		60	LG ARNU	
FCU-904	1	ACCU-1017	LEVEL 9	BAR	DUCTED		46962	39281	61400	208/1	2.5		60	LG ARNU	
FCU-905	1	ACCU-1017	LEVEL 9	BAR	DUCTED		46962	39281	61400	208/1	2.5		60	LG ARNU	
FCU-906	1	ACCU-1017	LEVEL 9	BAR	DUCTED		46962	39281	61400	208/1	2.5		60	LG ARNU	
FCU-907	1	ACCU-1017	LEVEL 9	DINING 908	DUCTED		31482	24915	40600	208/1	2.3		60	LG ARNU	
FCU-908	1	ACCU-1017	LEVEL 9	DINING 908	DUCTED		31482	24915	40600	208/1	2.3		60	LG ARNU	
FCU-909	1	ACCU-1017	LEVEL 9	DINING 908	DUCTED		31482	24915	40600	208/1	2.3		60	LG ARNU	
FCU-910	1	ACCU-1017	LEVEL 9	KITCHEN A	DUCTED		31482	24915	40600	208/1	2.3		60	LG ARNU	
FCU-911	1	ACCU-1017	LEVEL 9	KITCHEN B	DUCTED		31482	24915	40600	208/1	2.3		60	LG ARNU	
FCU-912	1	ACCU-1017	LEVEL 9	DINING 909	DUCTED		16611	13864	21500	208/1	2.3		60	LG ARNU	
FCU-913	1	ACCU-1017	LEVEL 9	DINING 910	DUCTED		21046	17539	27300	208/1	2.3		60	LG ARNU	
FCU-1001	1	ACCU-1018	LEVEL 10	ELEVATOR	WALL MOUNTED		12300		13600	208/1	0.3	Y	30	LG ARNU	
FCU-A	59	VARIES	LEVEL 2-8	GUEST ROOM - NORTH	DUCTED		6528	5104	8500	208/1	0.4		60	LG ARNU	
FCU-B	42	VARIES	LEVEL 2-8	GUEST ROOM - EAST	DUCTED		10682	8391	13600	208/1	0.8		60	LG ARNU	
FCU-C	105	VARIES	LEVEL 2-8	GUEST ROOM - SOUTH & WEST	DUCTED		13352	10458	17100	208/1	0.8		60	LG ARNU	
FCU-D	6	VARIES	LEVEL 2-8	JR SUITE - WEST	DUCTED		24348	19306	31500	208/1	2.3		60	LG ARNU	
FCU-E	8	VARIES	LEVEL 2-8	1 BR SUITE - EAST	DUCTED		24348	20893	31500	208/1	2.5		60	LG ARNU	
FCU-F	1	VARIES	LEVEL 8	SUITE 809	DUCTED		36522	28981	47000	208/1	2.3		60	LG ARNU	
GENERAL NOTES:															
A. MINIMUM EFFICIENCY IS AT ARI STANDARD CONDITIONS.															
B. ALL DUCTED AND CASSETTE UNITS ARE PROVIDED WITH AN INTEGRAL CONDENSATE PUMP CAPABLE OF 27 IN WG OF LIFT.															
C. ALL FAN MOTORS ARE EC TYPE															
D. DUCTWORK CONNECTED TO DUCTED FAN-COIL UNITS IS LOW PRESSURE															
E. MINIMUM AND MAXIMUM ALLOWABLE SUPPLY AIR TEMPERATURES ARE 55°F AND 105°F, RESPECTIVELY.															
NOTES:															
1. PROVIDE WITH CASSETTE COVER; BASIS OF DESIGN: LG PTDCM															
2. PROVIDE WITH AUXILIARY CONDENSATE PUMP															
3. PROVIDE UNIT WITH A MINIMUM OF TWO STAGES OF FAN SPEED CONTROL. MINIMUM FAN SPEED CAN BE NO GREATER THAN 66% OF FULL SPEED.															

VRF OUTDOOR UNIT SCHEDULE														
TAG	LOCATION	SERVICE	RATED CAPACITY		MIN EFFICIENCY		REFRIGERANT		ELECTRICAL		GEN. POWER (Y/N)	APPROX. WEIGHT (LBS)	MANUFACTURER & MODEL	NOTES
			COOLING (MBH)	HEATING (MBH)	COOLING (EER/SEER)	HEATING COP	TYPE	CHARGE (LBS)	VOLT/ PHASE	MCA (A)				
ACCU-1001	ROOF	LOWER LEVELS	96	108	33.0	4.33	R410A		460/3	16.4	25	1,200	LG ARUM	
ACCU-1002	ROOF	LEVEL 1	408	459	18.8	3.34	R410A		460/3	35.7+38.3	100	1,200	LG ARUM	
ACCU-1003	ROOF	LEVEL 2 WEST	192	216	25.9	3.75	R410A		460/3	35.7	50	1,200	LG ARUM	
ACCU-1004	ROOF	LEVEL 2 EAST	192	216	25.9	3.75	R410A		460/3	35.7	50	1,200	LG ARUM	
ACCU-1005	ROOF	LEVEL 3 WEST	192	216	25.9	3.75	R410A		460/3	35.7	50	1,200	LG ARUM	
ACCU-1006	ROOF	LEVEL 3 EAST	192	216	25.9	3.75	R410A		460/3	35.7	50	1,200	LG ARUM	
ACCU-1007	ROOF	LEVEL 4 WEST	192	216	25.9	3.75	R410A		460/3	35.7	50	1,200	LG ARUM	
ACCU-1008	ROOF	LEVEL 4 EAST	192	216	25.9	3.75	R410A		460/3	35.7	50	1,200	LG ARUM	
ACCU-1009	ROOF	LEVEL 5 WEST	192	216	25.9	3.75	R410A		460/3	35.7	50	1,200	LG ARUM	
ACCU-1010	ROOF	LEVEL 5 EAST	192	216	25.9	3.75	R410A		460/3	35.7	50	1,200	LG ARUM	
ACCU-1011	ROOF	LEVEL 6 WEST	192	216	25.9	3.75	R410A		460/3	35.7	50	1,200	LG ARUM	
ACCU-1012	ROOF	LEVEL 6 EAST	192	216	25.9	3.75	R410A		460/3	35.7	50	1,200	LG ARUM	
ACCU-1013	ROOF	LEVEL 7 WEST	192	216	25.9	3.75	R410A		460/3	35.7	50	1,200	LG ARUM	
ACCU-1014	ROOF	LEVEL 7 EAST	192	216	25.9	3.75	R410A		460/3	35.7	50	1,200	LG ARUM	
ACCU-1015	ROOF	LEVEL 8 WEST	192	216	25.9	3.75	R410A		460/3	35.7	50	1,200	LG ARUM	
ACCU-1016	ROOF	LEVEL 8 EAST	192	216	25.9	3.75	R410A		460/3	35.7	50	1,200	LG ARUM	
ACCU-1017	ROOF	LEVEL 9	480	540	19.0	3.21	R410A		460/3	18.4+26.4+38.3	110	1,200	LG ARUM	
ACCU-1018	ROOF	UNITS ON GEN	96	108	33.0	4.33	R410A		460/3	16.4	25	1,200	LG ARUM	
ACCU-1019	ROOF	TELCO	72	81			R410A		460/3	12.8	20	1,200	LG ARUM	
GENERAL NOTES:														
A. MINIMUM EFFICIENCY IS AT AHRI STANDARD CONDITIONS.														
B. SIZE REFRIGERANT PIPING PER MANUFACTURER'S INSTRUCTIONS.														
C. REFRIGERANT CHARGE INDICATED IS FOR THE EQUIPMENT ONLY. PROVIDE NECESSARY REFRIGERANT QUANTITY TO MEET THE REQUIREMENTS FOR THE SPECIFIC INSTALLATION.														
D. SUPPLEMENTAL HEATING IS AUTOMATICALLY DISABLED AT OA TEMPERATURES ABOVE 40°F														
NOTES:														
1. UNIT COMPRISED OF 2 MODULES WITH SEPARATE ELECTRICAL CONNECTIONS & DISCONNECTS. SEE ELECTRICAL SHEETS FOR COORDINATION.														
2. UNIT COMPRISED OF 3 MODULES WITH SEPARATE ELECTRICAL CONNECTIONS & DISCONNECTS. SEE ELECTRICAL SHEETS FOR COORDINATION.														



**1223 SW Washington Street  
Suite 200  
Portland, OR 97205  
T 503 224 3860  
F 503 224 2482  
[www.zgf.com](http://www.zgf.com)**

### Consultants

CONSTRUCTION  
HOWARD S. WRIGHT  
PORTLAND, OR 97209  
1455 NW IRVING STREET, STE 40  
503-220-0895

STRUCTURAL  
KPF CONSULTING ENGINEERS  
111 SW FIFTH AVENUE  
SUITE 2500  
T 503-227-3251

CIVIL  
KPFF CONSULTING ENGINEERS  
111 SW FIFTH AVENUE  
SUITE 2500  
T 503-227-3251

MEP (BOD)  
PAE CONSULTING ENGINEERS  
522 SW FIFTH AVENUE  
SUITE 1500  
T 503-226-2921

LIGHTING DESIGN  
LUMA  
522 SW FIFTH AVENUE  
SUITE 1500  
T 503-226-2921

VENTILATION SCHEDULE - MULTIPLE SPACES - OREGON																	
DOAS-1002																	
LOCATION	TOTAL ZONES	ZONE FLOOR AREA (SF)	ZONE PRIMARY AIRFLOW RATE (CFM)	OCCUPANCY CLASSIFICATION	PEOPLE OUTDOOR AIRFLOW RATE Rp (CFM/PERSON)	AREA OUTDOOR AIRFLOW RATE Ra (CFM/SF)	DEFAULT OCCUPANT DENSITY (PEOPLE/1000SF)	ZONE CODE POPULATION	ZONE DESIGN POPULATION	TOTAL DESIGN POPULATION	OUTDOOR AIRFLOW RATE Vbz (CFM)	ZONE AIR DISTRIBUTION EFFECTIVENESS Ez	ZONE OUTDOOR AIR INTAKE Voz (CFM)	ZONE DESIGN OUTDOOR AIR INTAKE (CFM)	TOTAL OUTDOOR AIR INTAKE Voz (CFM)	TOTAL DESIGN OUTDOOR AIR INTAKE (CFM)	NOTES
STANDARD ROOM	70	350	385	Bedroom/living room	5	0.06	10	3.5	4.0	280.0	41.0	0.8	52	52	3640	3640	
1 BR SUITE	7	750	825	Bedroom/living room	5	0.06	10	7.5	4.0	28.0	65.0	0.8	82	82	574	574	
COORDINOR 2-6	7	462	508	Corridors	--	0.06	--	0.0	508	--	27.7	0.8	35	35	245	245	
			0		--	--	--	--	--	--	--	--	--	--	0	0	
Dining 908	1	1234	1423	Dining rooms	8	0.18	70	90.6	67.9	67.9	742.4	0.8	929	929	929	929	
Dining 909	1	226	249	Dining rooms	8	0.18	70	15.8	11.9	11.9	129.7	0.8	163	163	163	163	
Dining 910	1	311	342	Dining rooms	8	0.18	70	21.8	16.3	16.3	178.4	0.8	224	224	224	224	
Kitchen L9	1	1629	1792	Kitchens (cooking)/b	--	--	--	0.0	10.0	10.0	0.0	0.8	0	0	0	0	
Storage L9	1	200	220	Storage rooms	--	0.12	--	0.0	--	--	24.0	0.8	30	30	30	30	
TOTALS:										414						5806	5806
TOTAL AIRFLOW:		6,000															
SYSTEM POPULATION:		311															
CODE REQUIRED OUTDOOR AIR INTAKE FLOWRATE - Vot: 5,805																	
OUTDOOR AIR SUPPLIED: 6,000																	
GENERAL NOTES:																	
A. SYSTEM OUTDOOR AIR CALCULATION IS BASED ON THE SECTION 403 OF THE 2014 OREGON MECHANICAL SPECIALTY CODE.																	
B. REFER TO AIR HANDLING UNIT SCHEDULE FOR ACTUAL OUTDOOR AIR FLOW RATE.																	
NOTES:																	
1. DESIGN OCCUPANCY REPRESENTS THE AVERAGE OCCUPANCY, WHICH IS NOT LESS THAN 1/2 THE CODE OCCUPANCY.																	

VENTILATION SCHEDULE - MULTIPLE SPACES - OREGON													
LEVEL 1 AND LOWER LEVELS													
LOCATION	FLOOR AREA (SF)	PRIMARY AIRFLOW RATE (CFM)	OCCUPANCY CLASSIFICATION	PEOPLE OUTDOOR AIRFLOW RATE (CFM/PERSON)	AREA OUTDOOR AIRFLOW RATE (CFM/SF)	DEFAULT OCCUPANT DENSITY (PEOPLE/1000SF)	CODE POPULATION	DESIGN POPULATION	OUTDOOR AIRFLOW RATE (CFM)	ZONE AIR DISTRIBUTION EFFECTIVENESS Ez	OUTDOOR AIR INTAKE (CFM)	DESIGN OUTDOOR AIRFLOW (CFM)	NOTES
100-01-100 Bar/Lounge	2079	2267	Lobbies/prefunction	8	0.06	30	62.4	62.4	592.5	0.8	741	741	
100-01-105 Lobby Hotel	1272	1399	Main entry lobbies	5	0.06	10	12.7	12.7	139.9	0.8	175	175	
100-01-110 Reception	336	370	Reception areas	5	0.06	30	10.1	10.1	70.6	0.8	89	89	
100-01-115 Lobby Support	5	156	Office spaces	5	0.06	5	0.8	1.0	14.4	0.8	18	18	
100-01-120 Kitchen	2008	2268	Kitchens (cooking)	—	—	—	0.0	0.0	0.0	0.0	0	0	
100-01-125 Dining	1012	1113	Dining rooms	8	0.18	70	70.8	70.8	713.5	0.8	892	892	
100-01-130 Event Lobby	654	609	Lobbies/prefunction	8	0.06	30	16.6	16.6	157.3	0.8	198	198	
100-01-135A Event A	810	891	Multipurpose assembly	5	0.06	120	97.2	97.2	534.5	0.8	669	669	
100-01-135B Event B	836	920	Multipurpose assembly	5	0.06	120	100.3	100.3	551.8	0.8	690	690	
100-01-140 Security	63	91	Office spaces	5	0.06	5	0.4	1.0	10.0	0.8	13	13	
100-01-145 HS&P	560	616	Office spaces	5	0.06	5	2.8	2.8	47.8	0.8	60	60	
100-01-150 Break	363	421	Office spaces	5	0.06	5	1.9	1.9	32.6	0.8	41	41	
100-01-155 Prep	368	427	Office spaces	5	0.06	5	1.9	1.9	33.0	0.8	42	42	
Vestibule (Public Elevators)	240	0	Corridors	—	—	—	0.0	0.0	14.4	0.8	18	18	
FCC	200	0	Storage rooms	—	0.12	—	0.0	—	24.0	0.8	30	30	
Storage (lobby)	160	0	Storage rooms	—	0.12	—	0.0	—	21.6	0.8	27	27	
100-01-160 Gen. Mgr	167	184	Office spaces	5	0.06	5	0.8	1.0	15.0	0.8	19	19	
100-01-165 H R	206	227	Office spaces	5	0.06	5	1.0	1.0	17.5	0.8	22	22	
100-01-170 open office	815	897	Office spaces	5	0.06	5	4.1	4.1	69.3	0.8	87	87	
100-01-175 Accounting	303	333	Office spaces	5	0.06	5	1.5	1.5	25.8	0.8	33	33	
100-01-180 Linen	526	579	Commercial laundry	25	—	10	5.3	5.3	131.5	0.8	165	165	
100-01-185 Lockeroom	141	155	Locker/dressing rooms	15	—	—	0.0	—	0.0	0.8	9	9	

Revision:

**PORTLAND  
PROPER  
HOTEL**

1202 NW IRVING ST

Drawing Title

EQUIPMENT  
SCHEDULE -  
MECHANICAL

Date: 10.18.19  
Job No: 23725.inv  
Drawn By: Author  
Checked By: Checker

Drawing No.

# M0.04

**100% DD**

**GENERAL NOTES:**

A. REFER TO ARCHITECTURAL REFLECTED CEILING PLANS, ELEVATIONS, AND FLOOR PLANS FOR ACTUAL LOCATIONS OF ALL CEILING, WALL AND FLOOR MOUNTED DEVICES AND EQUIPMENT.

B. PROVIDE VOLUME DAMPER AT EACH BRANCH OUTLET/INLET.

C. COORDINATE ACCESS PANEL LOCATIONS WITH ARCHITECT


D. RUN DUCTS AND PIPING CONCEALED, UNLESS SPECIFIED OTHERWISE, AND CLEAR OF CEILING INSERTS. ALL DUCTWORK SHALL BE INSTALLED AS CLOSE AS POSSIBLE TO WALL AND UNDERSIDE OF BEAMS AND JOISTS.

E. ALL WORK SHALL BE COORDINATED WITH ALL TRADES INVOLVED. OFFSETS IN PIPING AND DUCTS (INCLUDING DIVIDED DUCTS) AND TRANSITIONS AROUND OBSTRUCTIONS SHALL BE PROVIDED AT NO ADDITIONAL COST TO THE OWNER.


F. ALL PIPING AND CABLES ROUTED THROUGH PLENUMS MUST BE PLENUM RATED.

**NOTES:**

1. ROUTE CONDENSATE TO NEAREST FLOOR DRAIN OR MOP SINK



1 MECHANICAL PLAN, FLOOR - PARKING  
1/8" = 1'-0"



A	B
C	D
E	F

GENERAL NOTES:

A. REFER TO ARCHITECTURAL REFLECTED CEILING PLANS, ELEVATIONS, AND FLOOR PLANS FOR ACTUAL LOCATIONS OF ALL CEILING, WALL AND FLOOR MOUNTED DEVICES AND EQUIPMENT.

B. PROVIDE VOLUME DAMPER AT EACH BRANCH OUTLET/INLET.

C. COORDINATE ACCESS PANEL LOCATIONS WITH ARCHITECT


D. RUN DUCTS AND PIPING CONCEALED, UNLESS SPECIFIED OTHERWISE, AND CLEAR OF CEILING INSERTS. ALL DUCTWORK SHALL BE INSTALLED AS CLOSE AS POSSIBLE TO WALL AND UNDERSIDE OF BEAMS AND JOISTS.

E. ALL WORK SHALL BE COORDINATED WITH ALL TRADES INVOLVED. OFFSETS IN PIPING AND DUCTS (INCLUDING DIVIDED DUCTS) AND TRANSITIONS AROUND OBSTRUCTIONS SHALL BE PROVIDED AT NO ADDITIONAL COST TO THE OWNER.

F. ALL PIPING AND CABLES ROUTED THROUGH PLENUMS MUST BE PLENUM RATED.

NOTES:

1. ROUTE CONDENSATE TO NEAREST FLOOR DRAIN OR MOP SINK.



1 MECHANICAL PLAN, FLOOR - PARKING MEZZANINE  
1/8" = 1'-0"

Revisions

PORTLAND  
PROPER  
HOTEL

1202 NW IRVING ST

Drawing Title

MECHANICAL  
PLAN, FLOOR -  
PARKING  
MEZZANINE


Date: 10.18.19  
Job No: 23725.ini  
Drawn By: Author  
Checked By: Checker

Drawing No.

M2.00M

100% DD

A	B
C	D
E	F





## GENERAL NOTES:

A. REFER TO ARCHITECTURAL REFLECTED CEILING PLANS, ELEVATIONS, AND FLOOR PLANS FOR ACTUAL LOCATIONS OF ALL CEILING, WALL AND FLOOR MOUNTED DEVICES AND EQUIPMENT.

B. PROVIDE VOLUME DAMPER AT EACH BRANCH OUTLET/INLET.

C. COORDINATE ACCESS PANEL LOCATIONS WITH ARCHITECT


D. RUN DUCTS AND PIPING CONCEALED, UNLESS SPECIFIED OTHERWISE, AND CLEAR OF CEILING INSERTS. ALL DUCTWORK SHALL BE INSTALLED AS CLOSE AS POSSIBLE TO WALL AND UNDERSIDE OF BEAMS AND JOISTS.

E. ALL WORK SHALL BE COORDINATED WITH ALL TRADES INVOLVED. OFFSETS IN PIPING AND DUCTS (INCLUDING DIVIDED DUCTS) AND TRANSITIONS AROUND OBSTRUCTIONS SHALL BE PROVIDED AT NO ADDITIONAL COST TO THE OWNER.

F. ALL PIPING AND CABLES ROUTED THROUGH PLENUMS MUST BE PLENUM RATED.

## NOTES:

1. ROUTE CONDENSATE TO NEAREST FLOOR DRAIN OR SINK TAIL PIECE.



1 MECHANICAL PLAN, FLOOR - LEVEL 1  
1/8" = 1'-0"

Revisions

PORTLAND  
PROPER  
HOTEL

1202 NW IRVING ST


Drawing Title

MECHANICAL  
PLAN, FLOOR -  
LEVEL 1

Date: 10.18.19  
Job No: 23725.ini  
Drawn By: Author  
Checked By: Checker

Drawing No.

A	B
C	D
E	F



M2.01

100% DD

PORTLAND  
PROPER  
HOTEL

1202 NW IRVING ST

Drawing Title

MECHANICAL  
PLAN, FLOOR -  
LEVEL 2

Date: 10.18.19

Job No: 23725.invi

Drawn By: Author

Checked By: Checker

Drawing No.

M2.02

100% DD

## GENERAL NOTES:

A. REFER TO ARCHITECTURAL REFLECTED CEILING PLANS, ELEVATIONS, AND FLOOR PLANS FOR ACTUAL LOCATIONS OF ALL CEILING, WALL AND FLOOR MOUNTED DEVICES AND EQUIPMENT.

B. PROVIDE VOLUME DAMPER AT EACH BRANCH OUTLET/INLET.

C. COORDINATE ACCESS PANEL LOCATIONS WITH ARCHITECT


D. RUN DUCTS AND PIPING CONCEALED, UNLESS SPECIFIED OTHERWISE, AND CLEAR OF CEILING INSERTS. ALL DUCTWORK SHALL BE INSTALLED AS CLOSE AS POSSIBLE TO WALL AND UNDERSIDE OF BEAMS AND JOISTS.

E. ALL WORK SHALL BE COORDINATED WITH ALL TRADES INVOLVED. OFFSETS IN PIPING AND DUCTS (INCLUDING DIVIDED DUCTS) AND TRANSITIONS AROUND OBSTRUCTIONS SHALL BE PROVIDED AT NO ADDITIONAL COST TO THE OWNER.

F. ALL PIPING AND CABLES ROUTED THROUGH PLENUMS MUST BE PLENUM RATED.

## NOTES:

1. ROUTE CONDENSATE TO NEAREST FLOOR DRAIN OR SINK TAIL PIECE.



1 MECHANICAL PLAN, FLOOR - LEVEL 2  
1/8" = 1'-0"

GENERAL NOTES:

A. REFER TO ARCHITECTURAL REFLECTED CEILING PLANS, ELEVATIONS, AND FLOOR PLANS FOR ACTUAL LOCATIONS OF ALL CEILING, WALL AND FLOOR MOUNTED DEVICES AND EQUIPMENT.

B. PROVIDE VOLUME DAMPER AT EACH BRANCH OUTLET/INLET.

C. COORDINATE ACCESS PANEL LOCATIONS WITH ARCHITECT

D. RUN DUCTS AND PIPING CONCEALED, UNLESS SPECIFIED OTHERWISE, AND CLEAR OF CEILING INSERTS. ALL DUCTWORK SHALL BE INSTALLED AS CLOSE AS POSSIBLE TO WALL AND UNDERSIDE OF BEAMS AND JOISTS.

E. ALL WORK SHALL BE COORDINATED WITH ALL TRADES INVOLVED. OFFSETS IN PIPING AND DUCTS (INCLUDING DIVIDED DUCTS) AND TRANSITIONS AROUND OBSTRUCTIONS SHALL BE PROVIDED AT NO ADDITIONAL COST TO THE OWNER.


F. ALL PIPING AND CABLES ROUTED THROUGH PLENUMS MUST BE PLENUM RATED.

NOTES:

- ROUTE CONDENSATE TO NEAREST FLOOR DRAIN OR SINK TAIL PIECE.
- REFER TO TYPICAL ROOM LAYOUTS ON M2.02.
- TELCO FAN COIL UNITS ARE ALSO LOCATED ON FLOORS 5 & 7.



1 MECHANICAL PLAN, FLOOR - LEVEL 3  
1/8" = 1'-0"



A	B
C	D
E	F

# PORTLAND PROPER HOTEL

202 NW IRVING ST

Drawing Title

MECHANICAL  
PLAN, FLOOR -  
LEVEL 8

Date: 10.18.19  
Job No: 23725.invi  
Drawn By: Author  
Checked By: Checker

Drawing No.

## M2.08

**00% DD**

**GENERAL NOTES:**

A. REFER TO ARCHITECTURAL REFLECTED CEILING PLANS, ELEVATIONS, AND FLOOR PLANS FOR ACTUAL LOCATIONS OF ALL CEILING, WALL AND FLOOR MOUNTED DEVICES AND EQUIPMENT.

B. PROVIDE VOLUME DAMPER AT EACH BRANCH OUTLET/INLET.

C. COORDINATE ACCESS PANEL LOCATIONS WITH ARCHITECT

D. RUN DUCTS AND PIPING CONCEALED, UNLESS SPECIFIED OTHERWISE, AND CLEAR OF CEILING INSERTS. ALL DUCTWORK SHALL BE INSTALLED AS CLOSE AS POSSIBLE TO WALL AND UNDERSIDE OF BEAMS AND JOISTS.

E. ALL WORK SHALL BE COORDINATED WITH ALL TRADES INVOLVED. OFFSETS IN PIPING AND DUCTS (INCLUDING DIVIDED DUCTS) AND TRANSITIONS AROUND OBSTRUCTIONS SHALL BE PROVIDED AT NO ADDITIONAL COST TO THE OWNER.


F. ALL PIPING AND CABLES ROUTED THROUGH PLENUMS MUST BE PLENUM RATED.

 **NOTES:**

1. ROUTE CONDENSATE TO NEAREST FLOOR DRAIN OR SINK TAIL PIECE.
2. REFER TO TYPICAL ROOM LAYOUTS ON M2.02.



1 MECHANICAL PLAN, FLOOR - LEVEL 8  
1/8" = 1'-0"



A	B
C	D
E	F



**GENERAL NOTES:**

A. REFER TO ARCHITECTURAL REFLECTED CEILING PLANS, ELEVATIONS, AND FLOOR PLANS FOR ACTUAL LOCATIONS OF ALL CEILING, WALL AND FLOOR MOUNTED DEVICES AND EQUIPMENT.

B. PROVIDE VOLUME DAMPER AT EACH BRANCH OUTLET/INLET.

C. COORDINATE ACCESS PANEL LOCATIONS WITH ARCHITECT


D. RUN DUCTS AND PIPING CONCEALED, UNLESS SPECIFIED OTHERWISE, AND CLEAR OF CEILING INSERTS. ALL DUCTWORK SHALL BE INSTALLED AS CLOSE AS POSSIBLE TO WALL AND UNDERSIDE OF BEAMS AND JOISTS.

E. ALL WORK SHALL BE COORDINATED WITH ALL TRADES INVOLVED. OFFSETS IN PIPING AND DUCTS (INCLUDING DIVIDED DUCTS) AND TRANSITIONS AROUND OBSTRUCTIONS SHALL BE PROVIDED AT NO ADDITIONAL COST TO THE OWNER.


F. ALL PIPING AND CABLES ROUTED THROUGH PLENUMS MUST BE PLENUM RATED.

**NOTES:**

1. ROUTE CONDENSATE TO NEAREST FLOOR DRAIN OR SINK TAIL PIECE.



1 MECHANICAL PLAN, FLOOR - LEVEL 9  
1/8" = 1'-0"



A	B
C	D
E	F

M2.09

100% DD

**GENERAL NOTES:**

A. REFER TO ARCHITECTURAL REFLECTED CEILING PLANS, ELEVATIONS, AND FLOOR PLANS FOR ACTUAL LOCATIONS OF ALL CEILING, WALL AND FLOOR MOUNTED DEVICES AND EQUIPMENT.

B. PROVIDE VOLUME DAMPER AT EACH BRANCH OUTLET/INLET.

C. COORDINATE ACCESS PANEL LOCATIONS WITH ARCHITECT


D. RUN DUCTS AND PIPING CONCEALED, UNLESS SPECIFIED OTHERWISE, AND CLEAR OF CEILING INSERTS. ALL DUCTWORK SHALL BE INSTALLED AS CLOSE AS POSSIBLE TO WALL AND UNDERSIDE OF BEAMS AND JOISTS.

E. ALL WORK SHALL BE COORDINATED WITH ALL TRADES INVOLVED. OFFSETS IN PIPING AND DUCTS (INCLUDING DIVIDED DUCTS) AND TRANSITIONS AROUND OBSTRUCTIONS SHALL BE PROVIDED AT NO ADDITIONAL COST TO THE OWNER.


F. ALL PIPING AND CABLES ROUTED THROUGH PLENUMS MUST BE PLENUM RATED.

**NOTES:**

1. 36x36 LOUVER BY DIV 8. SMOKE CONTROL RELIEF.
2. ##x## LOUVER BY DIV 8. FAN FAILURE RELIEF.
3. ROUTE CONDENSATE TO NEAREST FLOOR DRAIN OR SINK TAIL PIECE.



1 MECHANICAL PLAN, FLOOR - MECHANICAL LEVEL  
1/8" = 1'-0"



A	B
C	D
E	F

**PORTLAND  
PROPER  
HOTEL**

1202 NW IRVING ST

Drawing Title

MECHANICAL  
PLAN, FLOOR -  
LEVEL 10  
MECHANICAL

Date: 10.18.19  
Job No: 23725.ini  
Drawn By: Author  
Checked By: Checker

Drawing No.

M2.10

100% DD

## GENERAL NOTES:

A. REFER TO ARCHITECTURAL REFLECTED CEILING PLANS, ELEVATIONS, AND FLOOR PLANS FOR ACTUAL LOCATIONS OF ALL CEILING, WALL AND FLOOR MOUNTED DEVICES AND EQUIPMENT.


B. PROVIDE VOLUME DAMPER AT EACH BRANCH OUTLET/INLET.

C. COORDINATE ACCESS PANEL LOCATIONS WITH ARCHITECT

D. RUN DUCTS AND PIPING CONCEALED, UNLESS SPECIFIED OTHERWISE, AND CLEAR OF CEILING INSERTS. ALL DUCTWORK SHALL BE INSTALLED AS CLOSE AS POSSIBLE TO WALL AND UNDERSIDE OF BEAMS AND JOISTS.

E. ALL WORK SHALL BE COORDINATED WITH ALL TRADES INVOLVED. OFFSETS IN PIPING AND DUCTS (INCLUDING DIVIDED DUCTS) AND TRANSITIONS AROUND OBSTRUCTIONS SHALL BE PROVIDED AT NO ADDITIONAL COST TO THE OWNER.

F. ALL PIPING AND CABLES ROUTED THROUGH PLENUMS MUST BE PLENUM RATED.



Revisions

PORTLAND  
PROPER  
HOTEL

1202 NW IRVING ST

Drawing Title

MECHANICAL  
PLAN, FLOOR -  
ROOF

Date: 10.18.19


Job No: 23725.rvt

Drawn By: Author

Checked By: Checker


Drawing No.

A	B
C	D
E	F




M2.11

100% DD



13 CONDENSING UNIT MOUNTING AND REFRIGERANT PIPING ROOF PENETRATION  
NONE



**GENERAL NOTES:**

- A. REFER TO MECHANICAL AND ELECTRICAL FLOOR PLANS AND DETAILS FOR FIRE/SMOKE DAMPER AND DUCT SMOKE DETECTOR QUANTITIES AND LOCATIONS. CONNECT DAMPERS TO 120V 20A BRANCH CIRCUITS AS INDICATED ON ELECTRICAL DRAWINGS.
- B. CONTRACTOR SHALL COORDINATE DUCT SMOKE DETECTOR INSTALLATION AT EACH FSD LOCATION AND MAIN RETURN AIR DUCT LOCATION PRIOR TO COMMENCING WORK. DIV. 23 SHALL PROVIDE ALL DUCTWORK MODIFICATIONS REQUIRED TO ACCOMMODATE DUCT SMOKE DETECTOR INSTALLATION. PROVIDE ALL WORK TO SUIT INSTALLATION REQUIREMENTS AND ALL APPLICABLE CODES.
- C. IN NORMAL SYSTEM OPERATION, FIRE ALARM SYSTEM SHALL CLOSE ALL COMBINATION FIRE/SMOKE DAMPERS WHEN CORRESPONDING FAN SYSTEM IS OFF. DDC SYSTEM SHALL PROVIDE ALL REQUIRED FAN SYSTEM STATUS SIGNALS TO FIRE ALARM SYSTEM TO ACHIEVE THIS OPERATION.

**FAN SHUTDOWN SEQUENCE OF OPERATIONS:**


UPON THE DETECTION OF SMOKE BY ANY DUCT SMOKE DETECTOR:

1. THE FIRE ALARM SYSTEM SHALL SIGNAL THE AIR HANDLING UNIT IN ALARM TO SHUTDOWN VIA ADDRESSABLE CONTROL RELAY LOCATED AT EACH AIR HANDLING UNIT.
2. THE FIRE ALARM SYSTEM SHALL PROVIDE A SIGNAL TO THE DDC SYSTEM VIA SINGLE ADDRESSABLE CONTROL RELAY TO INITIATE THE DDC SYSTEM SHUTDOWN MODE.
3. UPON CONFIRMATION THAT ALL AIR HANDLING UNITS HAVE SHUTDOWN, THE DDC SYSTEM SHALL PROVIDE FAN SHUTDOWN STATUS SIGNAL TO FIRE ALARM SYSTEM.
4. THE FIRE ALARM SYSTEM SHALL CLOSE ALL COMBINATION FIRE/SMOKE DAMPERS VIA ADDRESSABLE CONTROL RELAY(S) 20-SECONDS (ADJUSTABLE) AFTER FAN SHUTDOWN SIGNAL OCCURRED.


UPON FIRE ALARM RESET AFTER THE DETECTION OF SMOKE HAS OCCURRED:

1. THE FIRE ALARM SYSTEM SHALL OPEN ALL COMBINATION FIRE/SMOKE DAMPERS VIA ADDRESSABLE CONTROL RELAY(S).
2. THE FIRE ALARM SYSTEM SHALL DISABLE FAN SHUTDOWN SIGNAL TO THE DDC SYSTEM VIA SINGLE ADDRESSABLE CONTROL RELAY.
3. THE FIRE ALARM SYSTEM SHALL DISABLE SHUTDOWN SIGNAL TO EACH AIR HANDLING UNIT VIA ADDRESSABLE CONTROL RELAY.


14 M. HVAC AND FIRE ALARM SYSTEM INTERFACE  
NONE




9 SMOKE CONTROL FAN - STAIRWELL  
NONE



10 SMOKE CONTROL FAN - ELEVATOR SHAFT  
NONE




11 DUCTED RETURN/EXHAUST GRILLE  
NONE



**NOTES:**

1. DRAIN SIZE IS OUTLET SIZE UNLESS SHOWN LARGER.


12 COIL DRAIN PIPING  
NONE




**NOTES:**

1. COMBINATION FIRE AND SMOKE DAMPER (VERTICAL SUPPLY TYPE SHOWN, HORIZONTAL & RETURN/EXHAUST SIMILAR).
2. GALVANIZED STEEL SLEEVE GAUGE NOT LESS THAN CONNECTION DUCT. FASTEN TO DAMPER FRAME AND PERIMETER ANGLES. CAULK BETWEEN DAMPER FRAME & SLEEVE.
3. PERIMETER ANGLES-14 GA. GALVANIZED STEEL, 1 1/2" x 1 1/2" MIN. TO PROVIDE 1" MIN. OVERLAP OF OPENING ON ALL 4 SIDES. DO NOT FASTEN TO PARTITION.
4. AIR TIGHT, BREAKAWAY DUCT CONNECTION.
5. ACCESS PANEL-SIZE & LOCATION TO PERMIT SERVICING FUSIBLE ROD AND LINK. ACTUATOR TO BE LOCATED OUT OF AIR STREAM. LOCATE PANEL WITHIN 12" OF FSD.
6. PROVIDE 15/16" TO 1/2" CLEARANCE ON HEIGHT & WIDTH, OR AS SPECIFIED BY DAMPER MANUFACTURER. FILL OPENING WITH FIRESTOP MATERIAL.
7. PROVIDE AIRFOIL BLADES ON MEDIUM PRESSURE DUCTWORK.
8. SMOKE DETECTOR FURNISHED PER DIVISION 26, INSTALLED PER DIVISION 23, POWER WIRING PER DIVISION 26, CONTROL WIRING PER DIVISION 28.
9. DAMPER POSITION SWITCH.


5 COMBINATION FIRE/SMOKE DAMPER  
NONE



6 RETURN AIR BOOT  
NONE




7 TYP. SQUARE NECK T-BAR DIFFUSER  
NONE



**GENERAL NOTES:**

- A. SEE SPECIFICATIONS FOR VIBRATION ISOLATION AND SEISMIC RESTRAINT.


8 ROOF MOUNTED UTILITY SET  
NONE



**NOTES:**

1. COMBINATION FIRE AND SMOKE DAMPER, BASED ON RUSKING FSD90FA. INSTALL PER MANUFACTURERS INSTRUCTIONS.
2. GRILLE.
3. FASTENERS SHALL BE A MINIMUM #10 SCREWS FOR STUD WALL CONSTRUCTION OR MINIMUM #10 SELF-TAPPING CONCRETE ANCHORS. FASTENERS SHALL BE MINIMUM 12" ON CENTER.
4. FIRE/SMOKE DAMPER SLEEVE (12-1/2").
5. ACTUATOR AND CONNECTION CABINET SHALL BE ACCESSED THROUGH GRILLE.
6. INTEGRAL MOUNTING ANGLE.


1 COMBINATION FIRE/SMOKE DAMPER FRONT ACCESS  
NONE




**GENERAL NOTES:**

- A. SEE SPECIFICATION FOR VIBRATION ISOLATION AND SEISMIC RESTRAINT.

2 UPBLAST EXHAUST FAN  
NONE



3 TYPICAL SLOT DIFFUSER  
NONE



**NOTES:**

1. 1.5 DIA. MINIMUM FLEX DUCT RADIUS (4" MAX LENGTH).

4 DIFFUSER DETAIL - ROUND CONNECTION  
NONE