
Development Services

From Concept to Construction



More Contact Info (http://www.portlandoregon.gov//bds/article/519984)





APPEAL SUMMARY

Status: Decision Rendered			
Appeal ID: 23425	Project Address: 6094 SE Woodstock Blvd		
Hearing Date: 1/29/20	Appellant Name: Kevin Partain		
Case No.: B-023	Appellant Phone: 5034212967		
Appeal Type: Building	Plans Examiner/Inspector: Robert Keal		
Project Type: residential	Stories: 2 Occupancy: R-3 Construction Type: V-B		
Building/Business Name:	Fire Sprinklers: No		
Appeal Involves: Erection of a new structure	LUR or Permit Application No.: 18-207201-RS		
Plan Submitted Option: pdf [File 1]	Proposed use: Residential		

APPEAL INFORMATION SHEET

Appeal item 1

Code Section	ORSC R302.1 and Table R302.1
Requires	Eaves less than 3 feet to a property line must be protected on the underside as required for one-hour fire-rated construction.
Code Modification or Alternate Requested	Allow for the eaves to be 18" from the assumed property line between units 1 & 3 with the fire rating as presented in the attached exhibit.
Proposed Design	Fire rate the eaves to allow the 18" of separation between the assumed property line.
Reason for alternative	The structures are already framed but were framed with extended rafter tails.


APPEAL DECISION

- 1. Alternate one hour assembly for North eave of proposed SFR within 2 feet of property line: Granted provided:
- a. Two layers of 5/8" Type X gypsum sheathing are provided on the underside of the soffit with 2 x blocking between rafters as required for nailing. (A protective weather barrier may cover the gypsum sheathing).
- b. No openings including eave vents may be installed in the soffit and no openings including windows, roof vents or skylights may be installed in that portion of the wall or roof that is within three feet of the property line.
- c. No built elements including gutters and footings may cross the property line and stormwater must remain and be disposed of on site.

Appellant may contact John Butler (503 823-7339) with questions.

The Administrative Appeal Board finds with the conditions noted, that the information submitted by the appellant demonstrates that the approved modifications or alternate methods are consistent with the intent of the code; do not lessen health, safety, accessibility, life, fire safety or structural requirements; and that special conditions unique to this project make strict application of those code sections impractical.

Pursuant to City Code Chapter 24.10, you may appeal this decision to the Building Code Board of Appeal within 90 calendar days of the date this decision is published. For information on the appeals process, go to www.portlandoregon.gov/bds/appealsinfo, call (503) 823-7300 or come in to the Development Services Center.





City of Portland, Oregon - Bureau of Development Services




1900 SW Fourth Avenue · Portland, Oregon 97201 | 503-823-7300 | www.portlandoregon.gov/bds

ORSC SECTION 302.1 – EAVES AND EXTERIOR WALL PROTECTION

O. What are the requirements for protecting the exterior walls of a house or an accessory structure (like a garage) when a wall is close to a property line?

A. If all parts of the building (including eaves) are at least 3' from the property line, there are no limitations. If any parts are closer than 3', see illustrations for protection and limitations.

No construction, including the gutters, may cross the property line.



Continued on other side

1900 SW 4th Avenue, Suite 5000, Portland, OR 97201 ORSC-SEC-3021

