

Development Services

From Concept to Construction

Phone: 503-823-7300 Email: bds@portlandoregon.gov 1900 SW 4th Ave, Portland, OR 97201
More Contact Info (<http://www.portlandoregon.gov/bds/article/519984>)



APPEAL SUMMARY

Status: Decision Rendered

Appeal ID: 24362	Project Address: 250 Tomahawk Island Dr
Hearing Date: 11/25/20	Appellant Name: Jason C Pacheco
Case No.: E-001	Appellant Phone: 3609044412
Appeal Type: Electrical	Plans Examiner/Inspector: Brett Welland, Brian Crise
Project Type: commercial	Stories: 1 Occupancy: Marina Construction Type: Marina Dock
Building/Business Name: McCuddy's Marina	Fire Sprinklers: No
Appeal Involves: Correction of a violation	LUR or Permit Application No.: 20-178749-ET
Plan Submitted Option: mail	Proposed use: Marina

APPEAL INFORMATION SHEET

Appeal item 1

Code Section	NEC 555.7
Requires	Service equipment may not be located on or in the floating structure. This includes the floating docks and egress ramp. The service must be located
Code Modification or Alternate Requested	Leave remaining service at current location
Proposed Design	Main service eq. has always been located at the current location, we have no plans to update the main incoming service to marina. Our scope only includes updating individual dock slip receptacles to new stand alone shore power pedestals and work associated with them. Nothing with the main service gear.
Reason for alternative	We are not doing any upgrades to existing gear, only branch circuits leaving ear already run to the end of each dock, we will upgrade panel at the end of each dock where needed. We are not running new feeder to existing panel locations

APPEAL DECISION

Existing electrical service to remain on floating dock: Denied. Proposal does not provide equivalent Life Safety protection.

Appellant may contact Brett Welland (503-823-7289) with questions.

Pursuant to City Code Chapter 27.02, you may appeal this decision to the Electrical Code Board of Appeal within 90 calendar days of the date this decision is published. For information on the appeals process, go to www.portlandoregon.gov/bds/appealsinfo, call (503) 823-7300 or come in to the Development Services Center.