Development Services

From Concept to Construction

Phone: 503-823-7300 Email: bds@portlandoregon.gov 1900 SW 4th Ave, Portland, OR 97201 More Contact Info (http://www.portlandoregon.gov//bds/article/519984)

Status: Decision Rend	lered	
Appeal ID: 24393		Project Address: 200 NW Royal Blvd, Lot #2
Hearing Date: 11/25/20		Appellant Name: Robert Oshatz
Case No.: P-004		Appellant Phone: 5036354243
Appeal Type: Plumbing		Plans Examiner/Inspector: Jim Bechtel, McKenzie James, Joe Blanco
Project Type: residential		Stories: 5 Occupancy: R Construction Type: V-B
Building/Business Name: RHO LLC		Fire Sprinklers:
Appeal Involves: Erection of a new structure		LUR or Permit Application No.: 20-176267-RS
Plan Submitted Option	n: pdf [File 1]	Proposed use: Single family residence
Appeal item 1 Code Section	307.0 LOCATION	
Requires Code Modification or	307.1 SYSTEMS. Except as otherwise provide in this code, no plumbing system, drainage system building sewer, private sewage disposal system, or part thereof shall be located in a lot other than the lot that is the site of the building, structure or premises served by such facilities.	
Alternate Requested	drainage lines in part or wholly in Tract A the commonly own portion of the subdivision. And requesting approval of existing private sanitary pressure line running in existing easement that goes through Tract A and other lots in the subdivision.	
Proposed Design	Stormwater system I am proposing to efficiently build stormwater planters following City of Portland Stormwater Management typical detail SW-140. To be apply to efficiently build along the site contour lines I am requesting to partial locate the planter outside of the actual individual lot lines. Sanitary sewer system	
	private pressurize sewer line that is	nd approved by the City in 2010. The lot is serviced by its owr place in an easement recorded by Multnomah County. The ne subdivision and other lots within the subdivision
Reason for alternative	Stormwater sewer system	
	Originally, When the subdivision wa	is approved it had one large stormwater planter for all 5 lots in

stormwater planter. For one, since no homes were yet designed the size would be purely a guess. If too big I would be financially penalized and if to small it would require future enlargement of the existing planter or adding a secondary stormwater planter in Tract A. In addition, the geotechnical engineer is now recommending small stormwater planter spread out on the site. At the time I submitted Construction Management Plans, the City agreed I could build individual stormwater planters with the construction of a residence. The Planning Department agreed that the stormwater planters could be located within their lot or whole or in part into Tract "A" (reference Timothy Novak and Ella Indarta in Planning). The intent is to select the most favorable contours on this steely downslope site and as close to each residence as possible for visual maintenance. Individual lots are long and narrow and run perpendicular to the contours of the site. To keep the stormwater planter within their lot lines the stormwater planters would need to be built inefficiently stepping down the site. An efficient stormwater planter should be built running parallel with the site contours.

In closing this is a very environmentally sensitive site so my intent is to select the best locations for stormwater planters and as close to each lot as possible without disturbing trees so each owner can easily visually see and get to the planters so they can properly preform maintenance. See attached drawing for stormwater sewer system layout

Sanitary sewer system

I am not sure if it is necessary to include this system in the appeal since the work has already been done and approved by the City.

Hearing Officer lan Simpson approved the subdivision on Lot 7 Block5, Royal on March 28, 2007 (see LU 06-109711). In 2010 through building permit 09-150770-5D, 5 pressurize private sewer lines were installed, inspected and approved by the City in an easement recorded with Multnomah County. At the time there was no requirement by the City to appeal code section R307 but to cover all plumbing that could be within the requirements of section 307 it is included there. See attached drawing for sanitary sewer system layout.

APPEAL DECISION

Construction of stormwater planters, related catch basins and drainage lines in part or wholly in the commonly owned Tract A: Granted as proposed with drainage and maintenance easement. Easement shall be reviewed and approved by Bureau of Development Services prior to recording. Appellant shall contact Jessica Ruch (503-823-4162) for information.

Note: Applicant is responsible to confirm any outstanding items on the public works permit(s) are resolved before proceeding with work.

The Administrative Appeal Board finds that the information submitted by the appellant demonstrates that the approved modifications or alternate methods are consistent with the intent of the code; do not lessen health, safety, accessibility, life, fire safety or structural requirements; and that special conditions unique to this project make strict application of those code sections impractical.

Pursuant to City Code Chapter 24.10, you may appeal this decision to the Plumbing Code Board of Appeal within 90 calendar days of the date this decision is published. For information on the appeals process, go to www.portlandoregon.gov/bds/appealsinfo, call (503) 823-7300 or come in to the Development Services Center.

