

ENB-15.17 - Application of Projection Room Standards of Section - UBC/4/#2

APPLICATION OF PROJECTION ROOM STANDARDS OF SECTION

Administrative Rule Adopted by Bureau Pursuant to Rule-Making Authority

ARB-ENB-15.17

TOPIC: Projection Rooms - UBC/4/#2

CODE: Structural Specialty Code: 1998 Edition

REVISED: March 1, 1999

REFERENCE: Section 406 - Structural Specialty Code

SUBJECT: Application of Projection Room Standards of Section 406

QUESTION: Given the change in technology in films and projection equipment, where are the standards of Section 406 applicable?

RESPONSE: Section 406 standards shall apply only to theatrical and other projection rooms where open arc equipment is used.

For all other projections rooms, a sign shall be posted stating: "NO OPEN ARC PROJECTION EQUIPMENT ALLOWED IN THIS ROOM WITHOUT PERMIT FROM THE BUREAU OF BUILDINGS."

HISTORY

Updates July 1, 1996 edition

Replaces UBC/40/#1 which replaced Policy & Procedure # D-18.

Revised March 1, 1999

Filed for inclusion in PPD September 29, 2004