

## Appendix E

# STORMWATER POLLUTION REDUCTION STORM DEVELOPMENT METHODOLOGY

May 20, 2004 (Updated for September 1, 2004 Stormwater Management Manual Revision)

### INTRODUCTION

The development of design storms for the sizing of stormwater pollution reduction (treatment) facilities generally involves a statistical analysis of local rainfall data, whereas a certain storm volume, duration, and peak intensity (or rainfall distribution) is identified to achieve a predetermined treatment volume goal. This treatment volume goal will vary from jurisdiction to jurisdiction, but is generally 80 to 95% of the average annual runoff. It can be linked to each jurisdiction's municipal stormwater discharge permit (MS4 permit) definition of MEP (maximum extent practicable) as it relates to the removal of pollutants from stormwater. This definition is rarely clear, but justification for the treatment volume goal generally involves social/political, economic, and environmental considerations. Without a firm grasp on the environmental consideration at this time (i.e. what percentage of average annual runoff volume needs to be treated such that the effluent water quality isn't harmful to fish or aquatic systems or groundwater resources?), the economic and social/political considerations are most widely used. An optimization model can be developed to determine a treatment volume that will result in the "biggest bang for the buck", or the point at which additional percentage points of annual treatment volume begin to require a disproportionately large increase in treatment facility size (see attached Figure 4). However the treatment volume goal is justified, the link to how treatment facilities are actually sized, and whether they end up achieving the intended goal, can be lost in translation.

### TREATMENT VOLUME GOAL

Before the adoption of the September 2004 Stormwater Management Manual revision, Portland relied on a single treatment storm methodology, using a storm of 0.83 inches over 24 hours (NRCS Type 1A rainfall distribution). Used since 1994, the original intent of this design storm was to: 1) treat the "first-flush" or first 0.5 inches of runoff from all storm events and 2) pass 100% of 95% of all storm events through the treatment facility. There did not seem to be a direct environmental or economic justification for choosing 95% of storm events at the time. The justification was mainly social/political in that it sounded like a reasonable standard.

The City of Eugene uses a treatment goal of 80% of the average annual runoff, and the justification seems to be both social/political and economic, as an attempt was made to choose a treatment intensity at the "knee" of an intensity versus percentage of annual runoff volume treated curve. Gresham also uses 80% of the average annual runoff, with a similar justification (URS performed both studies). The Washington State Department of Ecology (and thus many other jurisdictions in Washington) uses 91%, and claims that an economic analysis was performed to justify the goal.

Rather than stating a treatment volume goal without a link to environmental or economic considerations, Portland has chosen to consider economic factors to provide the most "bank for the buck". From a social/political and environmental perspective it is also desirable to set a

minimum value to this goal. A continuous simulation analysis, summarized as Figure 4, has been performed on multiple years of rainfall data to determine the percentage of average annual rainfall that should be treated to maximize treatment efficiency. This analysis indicates a knee in the curve somewhere between 80 and 85 percent of the average annual volume. It may not be desirable to set the treatment goal directly at the economically optimal point, as stormwater treatment facilities do not always operate at their optimal design flow rates. Filters blind over time, or swales accumulate sediments that decrease the effective treatment flow rate through them. A margin of safety should be incorporated into the treatment volume goal. For these reasons, the City of Portland has chosen to set its treatment volume goal at 90% of the average annual rainfall volume.

## **TREATMENT STORM ANALYSIS**

Over the past several years, Portland's 0.83" storm and justification have been questioned by other northwest jurisdictions. Agencies such as NOAA Fisheries are unsure which stormwater management regulations to use in the Pacific Northwest, as from an outside perspective the water quality storms and overall treatment goals used by various jurisdictions seem to vary dramatically. On the surface, Washington State DOE appears to use a treatment volume roughly double that of Portland's, although with the incorporation of the  $V_b/V_r$  (volume of basin / volume of runoff) factor they are basically equal (both result in the use of  $2/3^{\text{rd}}$  of the 2-year, 24-hour storm volume). The City of Eugene uses 1.4"/24 hours, and the City of Gresham uses 1.2"/12 hours. Their treatment storm volumes appear greater than Portland's (1.4" and 1.2" compared with 0.83"), but with the incorporation of the  $V_b/V_r$  ratio, are actually less (1.4" and 1.2" compared with 1.66").

While the City of Eugene uses 1.4"/24 hours for volume based treatment facilities, they use the intensities of 0.13"/hr and 0.22"/hr (for off-line and on-line facilities, respectively) for flow rate based facilities. These dual sizing standards result in treatment of 80% of the average annual runoff for rate based facilities, and 100% treatment of the 80<sup>th</sup> percentile storm for volume based facilities. At this time it is unclear how the treatment of X% of the average annual runoff with rate based systems is comparable to treating the X<sup>th</sup> percentile storm with volume based facilities. Rather than sizing to the X<sup>th</sup> percentile storm for volume based facilities, it is recommended to use a different methodology (see discussion under Volume Based Treatment Systems). In either case, the need for separate rate and volume based facility sizing standards is clear if the treatment volume goal is to remain consistent.


## RATE BASED TREATMENT SYSTEMS

Stormwater treatment systems can be divided into two categories based on the methods used to size them: rate (or flow) and volume (or detention) based systems. Rate based systems used in Portland include swales, sand filters, and Stormfilter cartridge systems. Rate based systems remove pollutants with physical processes that settle or filter particulates as the flow passes through the system. The actual volume of the facility doesn't play a major role in the pollutant removal process, as there isn't a significant detention period for the water to remain in the system for any length of time.

A continuous simulation model can easily be used to determine the average annual runoff volume percentage treated by a rate based system. An assumption is that 100% of the runoff less than or equal to the peak treatment flow rate is fully treated, while the flows that exceed the peak treatment flow rate receive no treatment. Different assumptions can be made for on and off-line treatment systems. Likewise, an analysis of continuous rainfall intensity data can determine the average annual rainfall volume that is associated with a particular range of rainfall intensities. This type of analysis was completed for four different rain gages representing the different quadrants of Portland, and is summarized in Exhibit 5. 5, 10 and 20-minute intensities were analyzed to determine the intensities associated with the 90% rainfall volume goal. For 5-minute intensities, rainfall intensities of 0.19 inches per hour or less were determined to account for 90% of the average annual rainfall volume.

Eugene performed an analysis on 50 years of Eugene Airport rainfall data and also concluded that a rainfall intensity of 0.19"/hr would be needed to treat 90% of the average annual runoff volume.

Figure 1: Continuous simulation determination of 90% treatment flow rate



## VOLUME BASED TREATMENT SYSTEMS

Unlike rate based systems, volume (or detention) based systems provide a significant storage volume for water to accumulate and be detained for a period of time. Pollutants are removed through physical (settlement) and/or biological processes. Volume based facilities used in Portland include wet ponds and wetlands. Unlike rate based systems, it is not easy to model volume based systems with continuous simulation models or rainfall analysis. Storm detention time needs to be factored into the model, and the mixing of water within the facility from one storm to the next creates a complex process that cannot be simulated accurately at this time. The currently accepted methodology used to size volume based treatment facilities (in Portland's SWMM, Gary Minton's *Stormwater Treatment* textbook, and many other jurisdictions) is to set the wet portion of the pond or wetland (permanent pool) equal to the full volume of runoff generated by the predetermined water quality storm, and apply a safety factor (Vb/Vr ratio).


The volumes of most jurisdictions' water quality storms are set at their average annual treatment volume goal. For example, if the goal is to treat 80% of the average annual flow volume, the treatment storm depth is set to the 80% percentile storm. Eugene's goal is to treat 80% of the average annual volume. Their water quality storm is 1.4"/24 hours, which is equal to the 80<sup>th</sup> percentile storm. 80% of their storm events have a depth of 1.4 inches or less. In Portland's case, the 0.83" storm is not equal to the 90<sup>th</sup> percentile storm. An estimate would put it somewhere between the 60<sup>th</sup> and 65<sup>th</sup> percentile storm. This had been compensated for in the September 2002 Stormwater Management Manual by requiring volume-based facilities to use twice the volume of runoff generated by the 0.83" storm, or a Vb/Vr ratio of 2, but this factor should most likely be a function of soil type. In a recent version of *Stormwater Treatment Northwest* (Vol 9, No 4), Gary Minton and Roger Sutherland suggest that Pacific Northwest monitoring data indicates that a Vb/Vr ration of 1 may be adequate to achieve a TSS removal of 80%.

The City of Eugene has performed an analysis on 50 years of Eugene Airport rainfall data, and concluded that 90% of rainfall events are less than 2.4 inches in depth. Hourly rainfall intensity data was used in the analysis, storm depths of 0.01 inches or less were eliminated from the analysis, and a minimum inter-event time of 6 hours was used. A slight change in the modeling assumptions has a significant impact on the outcome. In the December 2003 issue of *Stormwater Treatment Northwest*, Gary Minton stated that an analysis he did of 24-hour rainfall data from the Seattle-Tacoma International Airport indicated that with a storm depth of about 1.35 inches, 90% of the runoff would be treated over time. The specific assumptions that were used in Dr. Minton's analysis are not known, but he was not using the 90<sup>th</sup> percentile Seattle-Tacoma storm. The Washington State Department of Ecology's Western Washington Stormwater Manual targets the capture of 91% of the average annual runoff for water quality, which they equate to two-thirds of a 2-year storm event (roughly 1.65 inches). Again, this storm event is not equivalent to the 91<sup>st</sup> percentile Western Washington storm.

A way of modeling the rainfall that could result in a clearer link to the treatment goal may be to determine the volume of a wet basin that will result in an average storm detention time of 24, 36, or 48 hours, depending on the anticipated TSS settling velocity in the vicinity of the site. The assumed inter-event time could be adjusted to ensure that enough detention time is provided between each storm event. An assumption could be made that storms with total volumes less than the "90% treatment storm" would receive 100% treatment. Storms with total volumes greater than the "90% treatment storm" would receive partial treatment- 100% treatment for the volume equal to the 90% storm volume, and 0 treatment for the volume greater than the 90%

storm volume. This may be overly conservative, as some very long, drawn-out storms (>24 hours) with total volumes greater than the designated treatment volume, may in fact receive greater than 24 hours of detention time for the entire storm, or 100% effective treatment.

**Figure 2: Continuous simulation determination of 90% treatment volume**



## CONCLUSION AND RECOMMENDATION

The Portland water quality design storm shall be stated as a volume treatment goal- e.g. “90% of the average annual runoff shall be treated”, and will be clarified by stating the peak rainfall intensity, and total volume components. This achieves two things:

- 1) Volume based facilities and rate based facilities will be theoretically sized to achieve treatment of the same percentage of average annual runoff volume.
- 2) With the treatment rainfall intensity already given, the SBUH or other hydrograph based hydrologic analysis method won't be needed to size rate based treatment facilities, simplifying the design process. Rather, the Rational Method can be used to calculate the runoff treatment flow rate, based on the site's time of concentration.

To achieve the treatment of 90% of the average annual rainfall volume, rate based facilities must be sized to treat rainfall at 0.19 inches per hour for sites with 5-minute time of concentration or less, 0.16 inches per hour for sites with a 10-minute time of concentration, and 0.13 inches per hour for sites with a 20-minute time of concentration.

For volume based facilities, Portland shall continue to size wet basins using 0.83 inches of rainfall over 24 hours (NRCS Type 1A rainfall distribution), with a  $V_b/V_r$  ratio of 2. Further analysis will be completed during the September 2007 Stormwater Management Manual revision process.

There should no longer be the perception of extreme water quality design storm discrepancies between Portland's Stormwater Management Manual and the Department of Ecology's Stormwater Management Manual for Western Washington, answering questions raised by NOAA Fisheries during review of Portland's manual.


In the long term, as more is learned about the capabilities of stormwater treatment facilities and their relationship to environmental, economic, and social considerations, Portland's treatment storm characteristics shall be re-analyzed and compared with those of other local jurisdictions periodically to determine if changes are necessary.

**Figure 3: Water Quality Design Storm Pacific Northwest Comparison**

Jurisdiction	Average Annual Rainfall (inches)	Treatment Goal (average annual runoff %)	WQ Storm Volume (inches) Vr	Volume Based Facility Sizing Factor	WQ Storm Duration (hours)	WQ Storm Intensity for Off-Line Facilities (in/hr)	WQ Storm Intensity for On-Line Facilities (in/hr)
City Of Gresham	37.4	80	1.2	1	12	0.11	0.20
City Of Eugene	46.6	80	1.4	1	24	0.13	0.22
City Of Corvallis	43.2	90	0.90, 0.3 mean ann. storm for wet ponds	3	24	Not Specified: 0.90" storm peak 10 min intensity (per NRCS 1A dist.) = 0.29 in/hr	
Clean Water Services-Oregon	36	85	0.36	1	4	WQ Volume / 4 hours = 0.09 in/hr	
DOE Western Washington SWMM	Varies 36-46	91	"6-month storm volume"-Varies	1	24	91% treatment: varies by jurisdiction, HSPF continuous simulation, different on & off-line	
City Of Tacoma	37.6	91	"6-month storm volume"	1	24	91% treatment, HSPF continuous simulation, different on & off-line	
City Of Seattle	38.6	Not Clear	"Mean annual storm" = 0.47	1	24	6-month storm (64% of 2-year storm or 1.08 inches) peak 10-min intensity using SBUH = 0.35 in/hr	
King County-Washington	38.6	95	"Mean annual storm" = 0.47- 0.65	3	24	60% of 2-yr storm flow rate using KCRTS continuous simulation, or 64% of 2-yr storm flow rate using SBUH	
Oregon State DEQ	Varies 37 approx. average	Not Clear	2-year storm: 2.4" in Portland	1	24	Not Specified: 2.4" storm peak 10 min intensity (per NRCS 1A dist.) = 0.78 in/hr	
City Of Portland (1996-Sept. 2004)	36	Not Clear: 95% Claim	0.83	2	24	Not Specified: 0.83" storm peak 10 min intensity (per NRCS 1A dist.) = 0.27 in/hr	
City Of Portland (Recommended for Sept. 2004)	36	90	90% Ave. annual treatment volume*	1 if Vr = 1.7, 2 if Vr = 0.83	24	90% treatment as shown by continuous simulation (see Figure 5) = 0.19 to 0.13 in/hr, depending on site's ToFC	

\* As defined by the recommended analysis of 24 years of Portland rainfall data, assuming a minimum inter-event time of 12 hours and minimum rainfall amount of 0.01 inches (see Figure 6). Portion of storm volume below specified treatment volume receives 100% treatment, portion of storm volume above specified treatment volume receives 0% treatment.

**Figure 4: Rainfall Intensity Versus Percentage of Annual Rainfall Volume**  
 Rainfall data taken from each of four Portland quadrants, then averaged. 8/12/2004  
Fancher





## Figure 5: BES Stormwater Pollution Reduction Storm Analysis April 30, 2004

**Intensities Resulting in Treatment of 90% of Rainfall Volume (in/hr)**

Assumption: Percentage of rainfall less intense than specified intensity receives 100% treatment, percentage of rainfall more intense than specified intensity receives 0 treatment.

5 minute intensity NW	0.19	Average = 0.19 in/hr
5 minute intensity SW	0.19	
5 minute intensity SE	0.20	
5 minute intensity NE	0.19	
10 minute intensity NW	0.15	Average = 0.16 in/hr
10 minute intensity SW	0.15	
10 minute intensity SE	0.165	
10 minute intensity NE	0.16	
20 minute intensity NW	0.13	Average = 0.13 in/hr
20 minute intensity SW	0.12	
20 minute intensity SE	0.14	
20 minute intensity NE	0.135	

## Figure 6: BES Stormwater Pollution Reduction Storm Analysis April 30, 2004

### Volumes Resulting in Treatment of 90% of Rainfall Volume (in/hr)

Assumptions: Percentage of storm volume less than specified volume receives 100% treatment, percentage of storm volume greater than specified volume receives 0 treatment. Storm event is defined by a minimum of 0.01 inches of rainfall with a minimum inter-event period of 12 hours.

Place & Time	Total Rainfall (in)	Number of 12-hr Storms	Average Storm Size (in)	90% Treatment Storm Size (in)	Average 90% Treatment Storm Size (in)
NW 97-98	80.15	169	0.47	1.6	Average = 1.7 in
NW 90-91	65.5	163	0.40	1.3	
NW 83-84	83.9	202	0.42	1.9	
NW 80-81	95.37	247	0.39	2.1	
SW 97-98	73.85	176	0.42	1.4	Average = 1.7 in
SW 90-91	61.83	180	0.34	1.25	
SW 83-84	82.37	201	0.41	1.9	
SW 80-81	67.45	160	0.42	2.1	
SE 97-98	74.41	185	0.40	1.6	Average = 1.8 in
SE 90-91	63.71	184	0.35	1.3	
SE 83-84	82.75	192	0.43	2.0	
SE 80-81	65.41	163	0.40	2.3	
NE 97-98	74.00	180	0.41	1.4	Average = 1.7 in
NE 90-91	64.62	176	0.37	1.2	
NE 83-84	72.27	217	0.33	1.7	
NE 80-81	65.37	188	0.35	2.3	

## Appendix: Local Pollution Reduction Storm Specifications

### MEMORANDUM

**TO:** Greg Gescher, CP&P Supervisor  
**FROM:** Bruce Moser, Project Manager  
**DATE:** December 15, 2003  
**SUBJECT:** Stormwater Quality Facility Design Storm

This memo reviews the stormwater quality design storm event for the City of Corvallis, and recommends using a NRCS Type 1A storm event of 0.9 inch in 24 hours.

#### Background

NPDES Phase 1 and 2 Stormwater regulations require agencies to implement stormwater quality treatment by the use of best management practices. NPDES Phase 1 and 2 Permits do not include a specific requirement for meeting a design storm and treatment level. The State of Oregon DEQ has not established stormwater quality criteria for NPDES Phase 1 for receiving streams that are not water quality limited (TMDLs have not been established).

The Corvallis SWMP includes the requirement to retrofit all existing stormwater outfalls with water quality facilities, and to require new development to install stormwater quality facilities. The SWMP includes Technical Memorandum No. 3, dated Nov. 10, 1999, in which Brown&Caldwell staff recommended that the City of Corvallis use 2/3's of the 2 year, 24 hour rainfall event, or 1.67 inches for 24 hours for the stormwater treatment design storm event. This level of treatment exceeds the level other agencies in Oregon are currently using.

#### Discussion

Agencies in Oregon that have NPDES stormwater permits have established differing criteria for the stormwater quality design storm event to capture and treat. Agencies have reviewed local rainfall data to determine the level of storm event to capture that represents a percentage of the total rainfall. This methodology is based on the assumption that the majority of pollutants are mobilized and transported prior to the peak of a large rainfall event. Several stormwater quality studies have substantiated this assumption.

The process for review of rainfall data involves review of historical rainfall events to establish a level of 24 hour precipitation that represents a given percentage of the total volume of rainfall. The City of Portland has established design criteria of 95% of total stormwater runoff is to be treated to remove 70% of Total Suspended Solids (TSS). The design storm to capture has been established as 0.83 inches in 24 hours, using NRCS Type 1A curve. The City of Eugene has established the design criteria of 90% of total stormwater runoff to be treated, but the TSS removal criteria is not mentioned. City of Eugene staff assume that a properly designed stormwater quality BMP will remove 80% of TSS. City of Eugene has established the design storm as 0.21 inches in one hour for on-line facilities, and 0.12 inches in one hour for off-line facilities. This is based on using 1.0 inch

in 24 hour as the design storm, using the NRCS Type 1A curve. The on-line facilities have a greater design storm based on the assumption that the effectiveness of an on-line facility will be impacted by flow when compared to an off-line facility.

Establishing Stormwater Quality Treatment Design Storm Event for Corvallis

The design rainfall event and treatment level is not currently identified under existing or anticipated regulatory requirements for the City of Corvallis. The SWMP does not specify treatment levels, but community input frequently referenced the water quality requirements that larger Oregon cities were meeting. A reasonable expectation for the implementation of stormwater quality facilities in Corvallis would be meeting community standards established in other Oregon cities that require stormwater treatment.

The stormwater receiving streams in Corvallis do not have established TMDL's, and none are anticipated to be implemented in the foreseeable future. In addition, the EPA Implementation Plan for Corvallis has not established a water quality treatment requirement with the exception of water temperature.

The methodology for developing the storm event for design treatment levels for the City of Corvallis uses review of historical daily rainfall over the last 42 years from the Hyslop rainfall gage (located 4 miles north of Corvallis) to determine the 24 hour event that would provide 90% capture for treatment. The 42 year historical data was tabulated to establish the average yearly rainfall of 43.20 inches. The amount of yearly rainfall that equals 90% of this yearly rainfall is 38.87 inches. The next step of the methodology was to establish a daily rainfall amount that collectively meets the 38.88 inches over the 42 years of data. The historical rainfall data was input to a spreadsheet "if, then" command to record all daily rainfall less than or equal to 0.9 inches. Rainfall greater than 0.9 inches was converted to 0.9 inches for the 24 hour period. The data was again tabulated and averaged to determine the yearly average rainfall amount, which was calculated to be 38.99 inches. This level nearly matches the target the yearly average for 90% rainfall of 38.88 inches.

The following table compares the annual average rainfall and design storm events for Portland, Corvallis, and Eugene.

City	Portland	Corvallis	Eugene
Annual Ave. Rainfall (inches)	37.07	43.20	50.90
24 Hr. Design Storm (inch/24 hour)	0.83	0.90	1.00

**Recommendation**

Based on review of other agency design storm methodology and review of local rainfall data, the stormwater quality design storm event for the City of Corvallis is recommended to be 0.9 inches in 24 hours, using the NRCS Type 1A distribution curve.

X:\Divisions\Engineering\Capital Planning&Projects\Projects\Stormwater CIP 03-04\doc\eseno on stormwater quality design storm event.wpd



### Design & Construction Standards

Clean Water Services Design and Construction Standards are the administrative and technical requirements for the design of sanitary and surface water management systems which are of residential or commercial development. The new Design and Construction Standards Resolution and Order 04-9 (R&O 04-9) became effective March 1, 2004 and replaces the previous version of the standards.

Unless otherwise specifically identified in the land use conditions, new development submittals within the District's boundaries--development within cities--should comply with R&O 04-9.


- [Click here to view or download Resolution and Order 04-9 \(PDF\).](#)
- [AutoCAD users may click here for PNG files.](#) A CD containing PDF files of the document is also available for purchase at Clean Water Services Permit Counter, 270 Hillsboro Street, Suite 270, Hillsboro. The cost for the CD is \$100.
- [Click here for language changes January 6, 2004.](#)
- [You may also access Resolution and Order 03-11 effective January 1, 2005.](#)

[Back](#)

[Home](#)

[About Us](#)

[Contact Us](#)



(c) 2002, Clean Water Services - [Click Here For More Information](#)

Last Site

**APPENDIX B:  
WATER QUALITY & QUANTITY  
FACILITY DESIGN**

1.0 GENERAL REQUIREMENTS FOR WATER QUALITY AND QUANTITY FACILITIES

1.1 Erosion Protection

- a. Inlets to water quality and quantity facilities shall be protected from erosive flows through the use of an energy dissipater or rip rap stilling basin of appropriate size based on flow velocities. Flow shall be evenly distributed across the treatment area.
- b. All exposed areas of water quality and quantity facilities shall be protected using coconut or jute matting. Coconut matting or high density jute matting (Geojute Plus or approved equal) shall be used in the treatment area of swales and below the WQV levels of ponds. Low density jute matting (EconoJute or approved equal) may be used on all other zones.

1.2 Vegetation

- a. Vegetation shall be in accordance with the Appendix D: Landscape Requirements.
- b. No invasive species shall be planted or permitted to remain within the facility which may affect its function, including, but not limited to the following:
  - 1. Himalayan blackberry (*Rubus discolor*)
  - 2. Reed canarygrass (*Phalaris arundinacea*)
  - 3. Teasel (*Dipsacus fullonum*)
  - 4. English Ivy (*Hedra helix*)
  - 5. Nightshade (*Solanum sp.*)
  - 6. Clematis (*Clematis ligusticifolia* and *C. vitifolia*)
  - 7. Cattail (*Typhus latifolia*)
  - 8. Thistle (*Cirsium arvense* and *C. vulgare*)
  - 9. Scotch Broom (*Cytisus scoparius*)

- 8) A vehicle turnaround shall be provided when the access road exceed 40' in length.

## 2.0 WATER QUALITY FACILITY DESIGN

This section presents methodology for designing water quality facilities.

### 2.1 Water Quality Volumes and Flows

*(Reproduced from Appendix A: Hydrology and Hydraulics; Section 1)*

The water quality storm is the storm-required by regulations to be treated. The storm defines both the volume and rate of runoff.

- a. Water Quality Storm: Total precipitation of 0.36 inches falling in 4 hours with a storm return period of 96 hours.
- b. Water quality volume (WQV) is the volume of water that is produced by the water quality storm.
- c. Water Quality Volume (WQV): 0.36-inches over 100-percent of the new impervious area.

$$\text{Water Quality Volume (cf)} = \frac{0.36(\text{in}) \times \text{Area (sf)}}{12 (\text{in/ft})}$$

- d. Water Quality Flow (WQF): The average design flow anticipated from the water quality storm.

$$\text{Water Quality Flow (cfs)} = \frac{\text{Water Quality Volume (cf)}}{14,400 \text{ Sec}}$$

Or

$$\text{Water Quality Flow (cfs)} = \frac{0.36(\text{in}) \times \text{Area (sf)}}{12(\text{in/ft})(4 \text{ hr})(60 \text{ min/hr})(60 \text{ sec/min})}$$

### 2.2 Pretreatment

- a. Pretreatment Required

Sheet flow of impervious surfaces into water quality facilities will not be allowed without pretreatment. Incoming flows to the water quality facility must be pretreated using a water quality manhole in accordance with section 2.3 or other pre-treatment method as approved by the District/City. Other methods of pretreatment may include proprietary devices, filter



# **Stormwater Management Manual for Western Washington**

---


- Volume I - Minimum Technical Requirements  
and Site Planning**
- Volume II - Construction Stormwater Pollution Prevention**
- Volume III - Hydrologic Analysis and  
Flow Control Design/BMPs**
- Volume IV - Source Control BMPs**
- Volume V - Runoff Treatment BMPs**

Prepared by:

Washington State Department of Ecology  
Water Quality Program

August 2001

Publication Numbers 99-11 through 99-15  
(Replaces Publication Number 91-75)

 *Printed on Recycled Paper*



---

## Chapter 4 - General Requirements for Stormwater Facilities

---

*Note: All Figures in Chapter 4 are courtesy of King County*

This chapter addresses general requirements for treatment facilities. Requirements discussed in this chapter include design volumes and flows, sequencing of facilities, liners, and hydraulic structures for splitting or dispersing flows.

### 4.1 Design Volume and Flow

#### 4.1.1 Water Quality Design Storm Volume

The volume of runoff predicted from a 24-hour storm with a 6-month return frequency (a.k.a., 6-month, 24-hour storm).

Wetpool facilities are sized based upon use of the NRCS (formerly known as SCS) curve number equations in Chapter 2 of Volume III, for the 6-month, 24-hour storm. Treatment facilities sized by this simple runoff volume-based approach are the same size whether they precede detention, follow detention, or are integral with the detention facility (i.e., a combined detention and wetpool facility).

Unless amended to reflect local precipitation statistics, the 6-month, 24-hour precipitation amount may be assumed to be 72 percent of the 2-year, 24-hour amount. Precipitation estimates of the 6-month and 2-year, 24-hour storms for certain towns and cities are listed in Appendix I-B of Volume I. For other areas, interpolating between isopluvials for the 2-year, 24-hour precipitation and multiplying by 72% yields the appropriate storm size. Isopluvials for 2-year, 24-hour amounts for Western Washington are reprinted in Volume III.

#### 4.1.2 Water Quality Design Flow Rate

***Downstream of Detention Facilities:* The full 2-year release rate from the detention facility.**

An approved continuous runoff model should identify the 2-year return frequency flow rate discharged by a detention facility that is designed to meet the flow duration standard.

***Preceding Detention Facilities or when Detention Facilities are not required:* The flow rate at or below which 91% of the runoff volume, as estimated by an approved continuous runoff model, will be treated.** Design criteria for treatment facilities are assigned to achieve the applicable performance goal at the water quality design flow rate (e.g., 80 percent TSS removal).

- *Off-line facilities:* For treatment facilities not preceded by an equalization or storage basin, and when runoff flow rates exceed the water quality design flow rate, the treatment facility should continue to receive and treat the water quality design flow rate to the applicable treatment performance goal. Only the higher incremental portion of flow rates are bypassed around a treatment facility. Ecology encourages design of systems that engage a bypass at higher flow rates provided the reduction in pollutant loading exceeds that achieved with bypass at the water quality design flow rate.

Treatment facilities preceded by an equalization or storage basin may identify a lower water quality design flow rate provided that at least 91 percent of the estimated runoff volume in the time series of a continuous runoff model is treated to the applicable performance goals (e.g., 80 percent TSS removal at the water quality design flow rate and 80 percent TSS removal on an annual average basis).

- *On-line facilities:* Runoff flow rates in excess of the water quality design flow rate can be routed through the facility provided a net pollutant reduction is maintained, and the applicable annual average performance goal is likely to be met.

*Estimation of Water Quality Design Flow Rate for Facilities Preceding Detention or when Detention Facilities are not required:*

Until a continuous runoff model is available that identifies the water quality design flow rate directly, that flow rate shall be estimated using Table 4.1, and its following directions for use:

- Step 1 Determine whether to use the 15-minute time series or the 1-hour time series. At the time of publication, all BMPs except wetpool-types should use the 15-minute time series.
- Step 2 Determine the ratio corresponding with the effective impervious surface associated with the project. For effective impervious areas between two 5 percent increments displayed in the table, a straight line interpolation may be used, or use the higher 5 percent increment value.
- Step 3 Multiply the 2-year return frequency flow for the post-developed site, as predicted by an approved continuous runoff model, by the ratio determined above.

# **City of Tacoma Surface Water Management Manual**

---

## **Volume I Minimum Technical Requirements and Site Planning**

Prepared by:

Tacoma Public Works  
Environmental Services

January 2003

related natural resources. Based upon gross level applications of continuous runoff modeling and assumptions concerning minimum flows needed to maintain beneficial uses, watersheds must retain the majority of their natural vegetation cover and soils, and developments must meet the Flow Control Minimum Requirement of this chapter, in order to avoid significant natural resource degradation in lowland streams.

The Roof Downspout Control BMPs described in Chapter 3 of Volume III, and the Dispersion and Soil Quality BMPs in Chapter 5 of Volume V are insufficient to prevent significant hydrologic disruptions and impacts to streams and their natural resources. Therefore, Ecology has suggested that the City and other local governments should look for opportunities to encourage and require additional BMPs such as those in Sections 5.2 through 5.4 of Volume V through updates to their site development standards and land use plans.

### **3.5.6 Minimum Requirement #6: Runoff Treatment**

#### ***Thresholds***

The following require construction of stormwater treatment facilities (see Table 3.1):

- Projects in which the total of effective pollution-generating impervious surface (PGIS) is 5,000 square feet or more in a threshold discharge area of the project, or
- Projects in which the total of pollution-generating pervious surfaces (PGPS) is three-quarters (3/4) of an acre or more in a threshold discharge area, and from which there is a surface discharge in a natural or man-made conveyance system from the site.

#### ***Treatment Facility Sizing***

**Water Quality Design Storm Volume:** The volume of runoff predicted from a 24-hour storm with a 6-month return frequency (a.k.a., 6-month, 24-hour storm). Wetpool facilities are sized based upon the volume of runoff predicted through use of the Natural Resource Conservation Service curve number equations in Chapter 2 of Volume III, for the 6-month, 24-hour storm.

#### **Water Quality Design Flow Rate:**

- *Preceding Detention Facilities or when Detention Facilities are not required:* The flow rate at or below which 91% of the runoff volume will be treated, as estimated by an approved continuous runoff model. Design criteria for treatment facilities are assigned to achieve the applicable performance goal at the water quality design flow rate.
- Volume V includes performance goals for Basic, Enhanced, Phosphorus, and Oil Control treatment, and a menu of facility options for each treatment type. Treatment facilities that are




## **Stormwater Treatment Technical Requirements Manual**

Issued November 2000



**City of Seattle**

### **Title 22.800 Stormwater, Grading & Drainage Control Code**



Volume 1: Source Control Technical Requirements Manual

Volume 2: Construction Stormwater Control Technical Requirements Manual

Volume 3: Flow Control Technical Requirements Manual

**Volume 4: Stormwater Treatment Technical Requirements Manual**

## 2.2 Sequence of Facilities

concentration. TC depends on several factors, including ground slope, ground roughness, and distance of flow.

The Soil Conservation Service (SCS) runoff curve number to be used with the SBUH method shall be 98 for impervious surfaces, and 85 or greater for pervious surfaces unless one of the following conditions is met:

- A lower SCS curve number is justified for an area incorporating one or more site design options (see City of Seattle Directors' Rule for Flow Control), or
- A soil report by an experienced geotechnical/civil engineer indicates site soils are sufficiently pervious to allow a smaller SCS curve number to be used.

In the City of Seattle, the design storm used by the SBUH method for design of treatment facilities is based on a standard SCS Type 1A storm event hyetograph where, during the peak 10-minute period, 5.40% of the total rainfall occurs. Note that for design of flow control facilities, a modified SBUH method is used where 9.92% of the rainfall occurs during the ten-minute period at the peak of the storm event (see Appendix A).

### Water Quality Design Flow

*Flow-through* treatment structures, such as biofiltration facilities, media filtration facilities, and oil control facilities, must be sized based on runoff from the 6-month, 24-hour storm event, which has a rainfall runoff volume of 1.08 inches. This value is based on the assumption that the 6-month, 24-hour storm volume is 64% of the volume of the 2-year, 24-hour storm event.<sup>4</sup> For these types of facilities, water quality design flow,  $Q_{wq}$ , is equal to the peak flow (measured in cfs). Using the SBUH method, this peak occurs during the ten-minute interval between 470 and 480 minutes, when 5.40% of the total rainfall volume occurs. Additional information on the SBUH method is provided in Appendix A. For *storage* treatment facilities, such as wetponds, wetvaults, and stormwater wetlands, sizing is based on the volume of runoff from the mean annual storm event, which for Seattle is 0.47 inches. Additional information on determining water quality design flows for storage treatment facilities is contained in Chapter 4.

## 2.2 SEQUENCE OF FACILITIES

As specified in the water quality menus, where more than one water quality facility is used, the order is often prescribed. This is because the specific pollutant removal role of the second or third facility in a treatment train often assumes that significant solids settling has already occurred. For example, phosphorus removal using a two-facility treatment train relies on the second facility (sand filter) to remove a finer fraction of solids than those removed by the first facility.

There is a larger question, however, of whether water quality facilities should be placed upstream or downstream of detention facilities. In general, all water quality facilities may be installed upstream of detention facilities, although presettling basins are needed for sand filters and infiltration basins. Not all water quality facilities, however, can be located

<sup>4</sup> Ref. Stormwater Management Manual for the Puget Sound Basin; The Technical Manual (1992). Publication 91-75, Washington State Department of Ecology, Olympia, Washington.

# CHAPTER 6

## WATER QUALITY DESIGN



### KING COUNTY, WASHINGTON

## SURFACE WATER DESIGN MANUAL

<b>Section 6.1</b>	<b>Water Quality Menus</b>	<b>6-3</b>
Section 6.1.1	Basic Water Quality Menu	6-4
Section 6.1.2	<del>Enhanced Basic Water Quality Menu</del> <u>Sensitive Lake Protection Menu</u>	6-6
Section 6.1.3	Sensitive Lake Protection Menu	6-8
Section 6.1.4	Sphagnum Bog Protection Menu	6-14
Section 6.1.5	High-Use Menu	6-15
<b>Section 6.2</b>	<b>General Requirements for WQ Facilities</b>	<b>6-19</b>
Section 6.2.1	Water Quality Design Flows	6-19
Section 6.2.2	Sequence of Facilities	6-20
Section 6.2.3	Setbacks, Slopes, and Embankments	6-23
Section 6.2.4	Facility Liners	6-25
Section 6.2.5	Flow Splitter Designs	6-30
Section 6.2.6	Flow Spreading Options	6-34
<b>Section 6.3</b>	<b>Biofiltration Facility Designs</b>	<b>6-39</b>
Section 6.3.1	Basic Biofiltration Swales	6-39
Section 6.3.2	Wet Biofiltration Swales	6-55
Section 6.3.3	Continuous Inflow Biofiltration Swales	6-58
Section 6.3.4	Basic Filter Strips	6-59
Section 6.3.5	Narrow Area Filter Strips	6-67
<b>Section 6.4</b>	<b>Wetpool Facility Designs</b>	<b>6-69</b>
Section 6.4.1	Wetponds — Basic and Large	6-69
Section 6.4.2	Wetvaults	6-82
Section 6.4.3	Stormwater Wetlands	6-88
Section 6.4.4	Combined Detention and Wetpool Facilities	6-94
<b>Section 6.5</b>	<b>Media Filtration Facility Designs</b>	<b>6-101</b>
Section 6.5.1	General Requirements	6-101
Section 6.5.2	Sand Filters — Basic and Large	6-102
Section 6.5.3	Sand Filter Vaults	6-123
Section 6.5.4	Linear Sand Filters	6-129
Section 6.5.5	<del>Leaf-Compost Filters</del> <u>(LCF) Stormfilter™</u>	6-134
<b>Section 6.6</b>	<b>Oil Control Facility Designs</b>	<b>6-137</b>
Section 6.6.1	Catch Basin Inserts	6-137
Section 6.6.2	Oil/Water Separators	6-143



## 6.2 GENERAL REQUIREMENTS FOR WQ FACILITIES

This section presents the general requirements for water quality (WQ) facilities. When detail in the WQ designs is lacking, refer to Chapter 5 for guidance. In cases where requirements are extremely costly, a less expensive alternative that is functionally equivalent in terms of performance, environmental effects, health and safety, and maintenance can be sought through the adjustment process (see Section 1.4).

### Use of Metal Materials

Galvanized metals leach zinc into the environment, especially in standing water situations. High zinc concentrations, sometimes in the range that can be toxic to aquatic life, have been observed in the region.<sup>12</sup> Therefore, use of galvanized materials in stormwater facilities and conveyance systems is discouraged. Where other metals, such as aluminum or stainless steel, or plastics are available, they should be used.

### 6.2.1 WATER QUALITY DESIGN FLOWS

#### Water Quality Design Flow

The water quality design flow is defined as follows:

- *Preceding detention: 60% of the developed two-year peak flow rate, as determined using the KCRTS model with 15-minute time steps calibrated to site conditions (see Chapter 3). Note: If KCRTS is not being used on a project, the WQ design flow may also be estimated using 64% of the 2-year 24-hour precipitation in the SBUH model.<sup>13</sup>*
- *Downstream of detention: The full 2-year release rate from the detention facility.*

The KCRTS model will typically be used to compute the WQ design flow. When examining the peak flow rates associated with various runoff volumes, it was found that detained flows and undetained flows must be described differently. However, unlike peak flows, the KCRTS model computation of volume of runoff is unaffected by whether or not the runoff is detained. Therefore, facilities such as wetponds, which are sized by a simple volume-based approach that does not route flows through a detention pond/facility, are the same size whether they precede or follow detention.

Note that facilities which are sized based on volume and which include routing of flows through a detention pond/facility, such as the detailed sand filter method, are significantly smaller when located downstream of detention, even though the same volume of water is treated in either situation. This is because the detention pond/facility routing sequence stores peaks within the pond and releases them at a slow rate, reducing the size of the sand filter pond subsequently needed (the volume needed to store the peaks need not be provided again in the sand filter pond).

#### Flow Volume to be Treated

When water quality treatment is required pursuant to the core and special requirements of this manual, it is intended that a minimum of **95% of the annual average runoff volume** in the (8 year) time series, as determined with the KCRTS model, be treated. Designs using the WQ design flow (as discussed above) will treat this minimum volume.

#### Treatable Flows

As stated in Chapter 1, only runoff from target pollution-generating surfaces must be treated using the water quality facility options indicated in the applicable water quality menu. These surfaces include both

<sup>12</sup> Finlayson, 1990. Unpublished data from reconnaissance of Metro Park and Ride lot stormwater characteristics.

<sup>13</sup> The Department of Ecology WQ design flow is based on the flow predicted by the SBUH model for 64% of the 2-year 24-hour precipitation. This is roughly equivalent to the WQ design flows given here for the KCRTS model.



#### 6.4.1.1 METHODS OF ANALYSIS

This section describes methods of analysis for the following two wetpond sizes:

- **Basic wetpond** (see below)
- **Large wetpond** (see page 6-73).

##### □ BASIC WETPOND

The primary design factor that determines a wetpond's **particulate removal efficiency** is the volume of the wetpool in relation to the volume of stormwater runoff from the *mean annual storm*.<sup>25</sup> The larger the wetpond volume in relation to the volume of runoff, the greater the potential for pollutant removal. Also important are the avoidance of short-circuiting and the promotion of plug flow. *Plug flow* describes the hypothetical condition of stormwater moving through the pond as a unit, displacing the "old" water in the pond with incoming flows. To prevent short-circuiting, water is forced to flow, to the extent practical, to all potentially available flow routes, avoiding "dead zones" and maximizing the time water stays in the pond during the active part of a storm.

Design features that encourage plug flow and avoid dead zones are as follows:

- Dissipating energy at the inlet
- Providing a large length-to-width ratio
- Providing a broad surface for water exchange across cells rather than a constricted area.

Maximizing the flowpath between inlet and outlet, including the vertical path, also enhances treatment by increasing residence time.

Wetponds designed using the method below (with the volume =  $3V$ ) and the required design criteria in Section 6.6.2.2 are expected to meet the Basic WQ menu goal of 80% TSS removal. The actual performance of a wetpond may vary, however, due to a number of factors, including design features, maintenance frequency, storm characteristics, pond algae dynamics, and waterfowl use.

Procedures for determining a wetpond's dimensions and volume are outlined below.

**Step 1: Identify required wetpool volume factor ( $f$ ).** A basic wetpond requires a volume factor of 3. This means that the required wetpond volume is 3 times the volume of runoff  $V$ , from the mean annual storm (see Steps 2 and 3).


**Step 2: Determine rainfall ( $R$ ) for the mean annual storm.** The rainfall for the mean annual storm  $R$  is obtained by locating the project site on Figure 6.4.1.A (p. 6-71) and interpolating between isopleths. Convert to feet for use in Equation (6-13).

**Step 3: Calculate runoff from the mean annual storm ( $V$ ) for the developed site.** The runoff volume  $V$ , is the amount of rainfall that runs off a particular set of land covers. To determine  $V$ , each portion of the wetpond tributary area is assigned to one of four cover types, each having a different runoff coefficient: impervious surface, till grass, till forest, or outwash.

- **Impervious surface** is a compacted surface, such as pavement, gravel, soil, or other hard surfaces, as well as open water bodies. *Note: The effective impervious computations given in Chapter 3, Table 3.2.2.D-E may be used, unless more detailed information is available if desired.*
- **Till grass** is post-development grass or landscaped area and onsite forested land on till soil that are not permanently in sensitive area buffers or covenants. *Till* is soil that does not drain readily and, as a

<sup>25</sup> The *mean annual storm* is a statistically derived rainfall event defined by the U.S. Environmental Protection Agency in "Results of the Nationwide Urban Runoff Program", 1986. It is defined as the annual rainfall divided by the number of storm events in the year. The NURP studies refer to pond sizing using a  $V_d/V_r$  ratio: the ratio of the pond volume  $V_d$  to the volume of runoff from the mean annual storm  $V_r$ . This is equivalent to using a volume factor  $f$  times  $V_r$ .

FIGURE 6.4.1.A PRECIPITATION FOR MEAN ANNUAL STORM IN INCHES (FEET)



result, generates large amounts of runoff. For this application, till soil types include Buckley and bedrock soils, and alluvial and outwash soils that have a seasonally high water table or are underlain at a shallow depth (less than 5 feet) by glacial till. U.S. Soil Conservation Service (SCS) hydrologic soil groups that are classified as till soils include a few B, most C, and all D soils. See Chapter 3 for classification of specific SCS soil types.