

2636 SE 107TH AVE  
11-146507-000-00-SE

3078799

On-Site Sewage Evaluations & Services

Issued: 6/8/11

Single Family Dwelling/Decommission Sewage Disposal System

Occupancy: Const. Type:

### Inspection:

842 Decommission System (Pumped & Filled) (503) 209-7641

Call Date/Time: 7/31/2012 17:15:57

Requested Date/Time: 8/1/12

decommission cesspool

Applicant:  
MAKSIM BELOUSOV  
(360) 909-0234


Owner:  
MAKSIM BELOUSOV  
(360) 909-0234

Zoning Enforcement Agency:  
Portland Field Visit

Applicant:  
MAKSIM BELOUSOV  
(360) 909-0234

Owner:  
MAKSIM BELOUSOV  
(360) 909-0234

Most Recent Inspections:



### City of Portland BDS

### INSPECTION REPORT

IVR Number: 3078799

Inspection Code: 842

- ☒ 1 Approved
- ☐ 2 Partially Approved
- ☐ 3 Approved with Corrections
- ☐ 4 Rollover/Missed
- ☐ 5 Not Approved
- ☐ 6 Consultation Completed

No Access	1
Stop Work Order Issued	2
Not Ready	3
Could Not Locate	4
See Correction Notice on Job Site	5
No Plans on Job	6
No Permit Card on Job	7
Fees Owed	8
Subcontractor Information Missing	9
Cancelled by Customer	0

Confirmation: #243747 Inspector/Date/Time/Phone

*Jim M. 823-5471 8/1/12*

*Locate ring C.P. found on N side of house ≈ 3' bgs + 10' out. Filled w/ 3/4" crushed.*

*2 ABS 4" pipe found from illegal bldg(s) in back yard (E side) going to sewer. Nothing old so not b/t w/ cesspool. (bldg had been demod. Only foundation left) as sewer record shows from 1994.*

*Compact well & O.K. to backfill.*

### Fees Paid

Decommission \$233.00