

## EXHIBIT A

AMENDMENT TO PORTLAND FIRE CODE-SECTION 902 (Adding New Definition) and  
SECTION 903.7 (Adding New Requirement)**SECTION 902  
DEFINITIONS**

**NIGHTCLUB.** For the purpose of Section 903.7, Nightclub means an A-2 occupancy use under the 2009 International Building Code which (a) has areas for dancing or viewing performers; and (b) serves food or drink. "Nightclub" does not include houses of worship, theaters with fixed seating, banquet halls, or lodge halls.

**SECTION 903  
AUTOMATIC SPRINKLER SYSTEMS**

**903.7 Nightclubs in Existing Buildings.** Existing nightclubs with an occupant load greater than 100 shall be protected by an approved automatic fire sprinkler system designed and installed in accordance with Section 903.3.1.1 and 903.4 as follows:

1. Throughout the story containing the nightclub; and
2. Throughout all stories below the story containing the nightclub; and
3. In the case of a nightclub located below the level of exit discharge, throughout all stories intervening between that story and the level of exit discharge including the level of exit discharge.
4. Nightclubs with an occupant load of 200 or greater shall comply with this regulation no later than December 31, 2014.
5. Nightclubs with an occupant load of 101-199 shall comply with this regulation no later than June 30, 2015.