



Chevron U.S.A. Inc.
575 Market Street, San Francisco, CA 94105
Mail Address: P.O. Box 7643, San Francisco, CA 94120

149312

RECEIVED

APR 10 9 01 AM 1980

GEORGE YERKOVICH, AUDITOR
CITY OF PORTLAND, ORE.

BY GA

J. H. Dotter
Manager, Plant Operations
Marketing Operations

April 3, 1980

Mr. George Yerkovich
Auditor of the City of Portland
Room 202, City Hall
Portland, Oregon 97204

Dear Sir:

Effective January 1, 1977, the domestic operations of our parent corporation, Standard Oil Company of California, were consolidated into a single U.S. subsidiary, which is named Chevron U.S.A. Inc. As a part of this reorganization, all operations and activities of Chevron Asphalt Company have been taken over by Chevron U.S.A. All assets and liabilities were assigned to Chevron U.S.A. at that time. Therefore, the document accepting the terms and provisions of Ordinance No. 149312 has been executed by Chevron U.S.A. Inc. We assume that this meets with your approval.

Further, we want to thank you for your expeditious handling of this matter.

Very truly yours,
J. H. Dotter

By J. F. Aldrich
Supervisor,
Asphalt Operations

JFA:tp
Attachment

APPROVED AS TO FORM

Christopher P. Thomas
CITY ATTORNEY

ORDINANCE NO. 149312

An Ordinance granting a revocable permit to Chevron Asphalt Company to construct a crude oil storage tank at their Chevron Asphalt plant on property located at 5501 N. W. Front Avenue, under certain conditions and declaring an emergency.

The City of Portland ordains:

Section 1. The Council finds:

1. That Chevron Asphalt Company, through Mackenzie Engineering, Inc., has requested a permit to construct a 150,000 barrel crude oil storage tank on the property at 5501 N. W. Front Avenue.
2. That these tanks are necessary for additional storage of crude oil which is used as base material for asphalt.
3. That inspection has been made by the Fire Marshal's Office and the Bureau of Buildings, who recommend that the permit be granted under certain conditions.

NOW, THEREFORE, the Council directs:

- a. That the action of the Commissioner in charge of the issuing of the permit be ratified and that a revocable permit be granted to the Chevron Asphalt Company to install a 150,000 barrel crude oil storage tank at the Chevron Asphalt plant located at 5501 N. W. Front Avenue under the following conditions:
 - (1) That the plans and specifications by Mackenzie Engineering, Number 79531 (2 pages), the dike calculations, Chevron's tank and appurtenance schedule for floating roof tanks Number D-W-20373, the letter and site plan of February 13, 1980, of the fire protection water loop from Mr. Jim McQueen, Chevron Refinery Manager, and the letter of application dated January 15, 1980, from Mr. Thomas R. Mackenzie, of Mackenzie Engineering.
 - (2) That no flammable or combustible liquids with boil-over characteristics, which is unstable or reactive, or which will vigorously polymerize, decompose, condense, or become self-reactive under conditions of shock, pressure, or temperature shall be stored in the tanks installed under this permit.
 - (3) That the tanks which are installed shall be of an "approved" type which meets the requirements of section 1-2 of N.F.P.A. Pamphlet #30, Flammable and Combustible Liquids Code, dated 1977, and be fabricated in accordance with American Petroleum Institute Standard #650, "Welded Steel Tanks for Oil Storage."
 - (4) That all electrical equipment installed shall be that which is approved and suitable for hazardous atmospheres, as

ORDINANCE No.

prescribed by section 7-5 including applicable provisions of Table of 7-1 N.F.P.A. Standard #30 of the National Fire Codes, 1977 Edition.

- (5) That the dikes or retaining walls shall be of earth, steel, concrete, or solid masonry, designed to be liquid-tight and to withstand a full hydraulic head, and so constructed as to provide the protection as required in section 2-2.3 of N.F.P.A. Standard #30 of the National Fire Codes, 1977 Edition.
- (6) That all piping, valves and fittings shall be equal to the requirements of Chapter 3, N.F.P.A. Standard #30 of the National Fire Codes, 1977 Edition.

(7) That the proposed water pipe and hydrant fire loop system be constructed at such time as to be operational prior to the subject tank receiving product.

(8) That all construction, including tanks, tank pads, piping, piping supports, pumps, walkways, docks, dikes, and electrical installations, shall be accomplished under permits obtained from the Bureau of Buildings, and shall be in accordance with detailed drawings and specifications submitted to and approved by that bureau.

b. This permit shall be in force and effect until and unless the permittee shall have first filed with the Auditor of the City of Portland in form approved by the City Attorney, a document in writing accepting the terms and conditions of this ordinance. Upon the filing of such acceptance, the City Auditor shall, at the expense of the permittee, file a certified copy of this ordinance in the Deed Records of Multnomah County, Oregon.

Section 2. Inasmuch as this ordinance is necessary for the immediate preservation of the public health, peace and safety of the City of Portland in this: In order that ratification of the granting of the permit may be made and the required documents heretofore filed with the Auditor may be attached and recorded without delay; therefore, an emergency hereby is declared to exist and this ordinance shall be in force and effect from and after its passage by the Council.

Passed by the Council, **MAR 20 1980**
 Francis J. Sargant, Chief Fire Marshal
 February 26, 1980
 M. Greenslade/lh

William W. Lombard
 Mayor of the City of Portland

Attest:
George J. Green
 Auditor of the City of Portland

Calendar No. 356
 ORDINANCE No. 149315
 Life
 NOTED BY COMMISSIONER
 INTRODUCED BY
 COMMISSIONER

976
Calendar No. ~~888~~

ORDINANCE NO. 149312

Title

An Ordinance granting a revocable permit to Chevron Asphalt Company to construct a crude oil storage tank at their Chevron Asphalt plant on property located at 5501 N. W. Front Avenue, under certain conditions and declaring an emergency.

THURSDAY

MAR 13 1980

CONTINUED TO MAR 20 1980

THE COMMISSIONERS VOTED AS FOLLOWS:	
Years	Days
Ivancie	1
Jordan	1
Lindberg	1
Schwab	1
McCreedy	1

FOUR-FIFTHS CALENDAR	
Ivancie	
Jordan	
Lindberg	
Schwab	
McCreedy	

Filed MAR 7 1980

GEORGE YERKOVICH

Auditor of the CITY OF PORTLAND

By *Jordan Crockett*
Deputy

INTRODUCED BY
Commissioner Lindberg

NOTED BY THE COMMISSIONER
Affairs
Finance and Administration
Safety
Utilities
Works

BUREAU APPROVAL
Bureau: Fire Bureau
Prepared By: F. J. Sargant
Date: 2/26/80

Budget Impact Review:
<input type="checkbox"/> Completed <input type="checkbox"/> Not required
Bureau Head:

NOTED BY
City Attorney
City Auditor
City Engineer

976
Calendar No. ~~888~~

ORDINANCE No. 149312

Title

An Ordinance granting a revocable permit to Chevron Asphalt Company to construct a crude oil storage tank at their Chevron Asphalt plant on property located at 5501 N. W. Front Avenue, under certain conditions and declaring an emergency.

THURSDAY

MAR 13 1980

CONTINUED TO MAR 20 1980

INTRODUCED BY
Commissioner Lindberg

NOTED BY THE COMMISSIONER
Affairs
Finance and Administration
Safety
Utilities
Works

BUREAU APPROVAL
Bureau: Fire Bureau
Prepared By: F. J. Sargant
Date: 2/26/80

Budget Impact Review:
<input type="checkbox"/> Completed <input type="checkbox"/> Not required
Bureau Head:

NOTED BY
City Attorney
City Auditor
City Engineer

THE COMMISSIONERS VOTED AS FOLLOWS:	
Years	Days
Ivancie	1
Jordan	1
Lindberg	1
Schwab	1
McCreedy	1

FOUR-FIFTHS CALENDAR	
Ivancie	
Jordan	
Lindberg	
Schwab	
McCreedy	

Filed **MAR 7 1980**

GEORGE YERKOVICH

Auditor of the CITY OF PORTLAND

By *George Yerkovich*
Deputy