

10065 SW BARBUR BLVD

DFS-01 C011-124322

DFS 01 Coll-124322

F

JAN 23 2012
MICROFILMED

14

(0611103--FREESTY -CHASE DRIVE TIRU/ -- PORTLAND, OR - A-DRAGY

Top chord 2x5 HF SS
Bot chord 2x4 HF #168at.
Webs 2x4 HF Std/Stud

90 mph wind, 15.00 ft mean hgt, ASCE 7-05, CLOSED bldg, located anywhere in roof, CAT II, EXP 8, wind TC DL-7.2 psf, wind SC DL-0.7.2 psf.

End-verticals not exposed to wind pressure.

Roof overhang supports 2.00 net roof load

Deflection meets L/360 live and L/240 total load.

Trough must be fastened as shown with 100 chord in.

bottom chord section directly below beam pocket bearings shall be cut out before fastening.

[illegible]

Bottom chord section directly below beam pocket bearing(s) shall be cut out prior to installing truss.

Truss transfers a maximum horizontal load of 2100 lb (113.00 kip) along top chord, from either direction to supports where indicated. Diaphragm and connections are to be designed by Engineer of Record.

UFig Loads:	Force(%)	(PLF)	Wof	Start	End
Case 1:	2100	113.00	TC	0.00	19.29

Run	Time	Temp	Pressure	Flow	Detector	Response	Area	Conc
1	2.10	150.50	BC			2.33	16.25	

Unbalanced snow loads have not been considered. Parameters used for snow pressure.

Provide 1/4" per foot slope in finished roof, or consult building official, provide for complete drainage of roof at all times.
Fonding not considered



City of Portland, Oregon - Bureau of Development Services

1900 SW Fourth Avenue • Portland, Oregon 97201 • 503-823-7300 • www.portlandoregon.gov/bds



Deferred Submittal Requirements and Application

Applicants will provide:

- ☐ A copy of this application
- ☐ Three (3) sets of plans
- ☐ One (1) set of calculations
- ☐ Two (2) sets of product information
- ☐ Drawings and calculations must be stamped and signed by an Engineer registered in Oregon and approved by the Architect/Engineer of record for the building.
- ☐ Permit fee (paid at time of submittal)
- ☐ If the DFS includes exterior elements, plan, views and elevations identifying the location(s) as approved by the Architect and Engineer of Record must be submitted.
- ☐ One (1) copy of your main building permit approved plans (NOTE: Approved plans do not need to be submitted if your project has a development liaison assigned)

Contractor submittal information:

Contact name Eric Bluth
 Address 10065 SW Barber
 City Portland State OR Zip Code 97219
 Phone 360-601-6814 E-mail eric.bluth@reconstruction.com
 Value of deferred submittal \$9000 Issued main building permit # 11-124322 CO
 Description/Scope of work Trusses for drive through canopy

Fees

Deferred submittal (DFS) fees are collected in addition to the standard building review fee paid on the main building permit. DFS fees cover the cost of the additional processing and review time associated with the design build element.

The DFS fee for processing and reviewing deferred plan submittals is 10 percent of the building permit fee calculated using the value of the particular deferred portion of the project.

Minimum fee: Residential, one and two family dwelling ... \$117 for DFS with valuation of less than or equal to \$222,000

Commercial and all other projects \$292 for DFS with valuation of less than or equal to \$680,000

The Bureau of Development Services (BDS) fee schedule is also available on the BDS web site at www.portlandonline.com/bds | select the Fees tab.

Helpful Information

Bureau of Development Services
 1900 SW 4th Avenue, Portland, OR 97201

Submit your plans to:

Development Services Center (DSC), First Floor,
 Tuesday - Friday:
 8:00 am - 3:00 pm
 Closed Mondays

Important Telephone Numbers

BDS main number 503-823-7300
 DSC automated information line 503-823-7310
 Building code information 503-823-1456
 BDS 24 hour inspection request line 503-823-7000
 Residential information for
 one and two family dwellings 503-823-7388
 City of Portland TTY 503-823-6868

DEFERRED SUBMITTAL REQUIREMENTS AND APPLICATION