

RECEIVED

AUG 12 10 22 AM 1981

ACCEPTANCE

GEORGE YERKOVICH, AUDITOR
CITY OF PORTLAND, ORE.



BY _____
Portland, Oregon, July 16, 1981

GEORGE YERKOVICH
Auditor of the City of Portland.
Room 202, City Hall
Portland, Oregon 97204

Dear Sir:

This is to advise the City of Portland, Oregon, that I hereby accept the terms and provisions of Ordinance No. 151923, passed by the Council July 15, 1981, granting a revocable permit to Port of Portland to install an additional propane storage tank on their property at the Airport Fire Department, under certain conditions,

and in consideration of the benefits to be received thereunder by me I hereby agree to abide by and perform each and all of the terms and provisions thereof applicable to me.

Very truly yours,

PORT OF PORTLAND



EXECUTIVE DIRECTOR


*William C. Boone
AVIATION MAINTENANCE MANAGER

PO Box 3529, Portland, Or 97208

Address


[CORPORATE SEAL]

Approved, as to form: AS TO FORM



CITY ATTORNEY

APPROVED AS TO FORM



of Counsel for the Port of Portland

*When an acceptance is required from a firm or corporation the Acceptance must be signed by an officer of the firm or corporation stating his or her official title, and corporations must affix the corporate seal.

151923

ORDINANCE NO. 151923

An Ordinance granting a revocable permit to Port of Portland to install an additional propane storage tank on their property at the Airport Fire Department, under certain conditions, and declaring an emergency.

The City of Portland ordains:

Section 1. The Council finds:

1. That the Port of Portland Airport Fire Department, through Assistant Chief Fred Cantrell, has requested a permit to install additional propane storage at the Port Fire Station located at the Portland International Airport.
2. That the propane fuel storage is needed for the addition of equipment bay heating equipment.
3. That inspection of the plans and the site has been made by the Fire Marshal who recommends that the permit be granted under certain conditions.

NOW, THEREFORE, the Council directs:

- a. That the action of the Commissioner-in-charge of the issuing of the permit be ratified and that a revocable permit hereby be granted to install propane storage at the Port Fire Department located at the Portland International Airport, under the following conditions:
 1. That the letter of application, dated May 5, 1981, from Assistant Chief Fred Cantrell, shall be made a part of this permit.
 2. That the tank, related appurtenances, and all piping and equipment shall be installed by a qualified, licensed liquefied petroleum gas fitter.
 3. That the installation shall be made in accordance with the basic rules and good practices established in National Fire Protection Association Standard #58, entitled "Liquefied Petroleum Gases, 1976."
 4. That prior to the use of the tank for any propane storage or the system being put on the line, the system as a whole shall be inspected and approved by the Fire Marshal's Office of the City of Portland.

151923

FIRE PREVENTION DIV.
RECEIVED



Port of Portland

Box 3529 Portland, Oregon 97208
503 324-3000
TOLL FREE 1-800-541-7111

MAY 8 1981

May 5, 1981

Matthew Greenslade
Special Hazards Inspector
Portland Fire Bureau
55 S.W. Ash
Portland, OR 97204

Dear Inspector Greenslade:

The Airport Fire Department anticipates installing overhead propane furnaces in the fire equipment bays after July 1, 1981. This will necessitate a larger propane storage capacity than that of our current 1,000 gallon tank. We request an allowance to install an additional 1,000 gallon capacity tank, besides our other one. Thank you for your consideration.

Sincerely,

Fred Cantrell
Assistant Chief
Airport Fire Department

FC/jr

000000

ORDINANCE No.

- b. This permit shall not be in force and effect until and unless the permittee shall have first filed with the Auditor of the City of Portland, in form approved by the City Attorney, a document in writing accepting the terms and conditions of this ordinance. Upon the filing of such acceptance, the City Auditor shall, at the expense of the permittee, file a certified copy of this ordinance in the Deed Records of Multnomah County, Oregon.

Section 2. Inasmuch as this ordinance is necessary for the immediate preservation of the public health, peace and safety of the City of Portland in this: In order that ratification of the granting of the permit may be made and the required documents heretofore filed with the Auditor may be attached and recorded without delay; therefore, an emergency hereby is declared to exist and this ordinance shall be in force and effect from and after its passage by the Council.

Passed by the Council, JUL 15 1981

Commissioner Mildred Schwab
June 18, 1981
Matthew Greenslade/lh

Attest:


Auditor of the City of Portland

Calendar No. ~~2282~~ ²²⁹⁶

ORDINANCE No. 151923

Title

An Ordinance granting a revocable permit to Port of Portland to install an additional propane storage tank on their property at the Airport Fire Department, under certain conditions, and declaring an emergency.

THURSDAY

JUL 9 1981

CONTINUED TO JUL 15 1981:30 A.M.

THE COMMISSIONERS VOTED AS FOLLOWS:		
	Yeas	Nays
JORDAN	/	
LINDBERG	-	
SCHWAB	/	
STRACHAN	/	
IVANCIE	/	

FOUR-FIFTHS CALENDAR	
JORDAN	
LINDBERG	
SCHWAB	
STRACHAN	
IVANCIE	

Filed JUN 29 1981

GEORGE YERKOVICH
Auditor of the CITY OF PORTLAND

George Yerkovich
Deputy

INTRODUCED BY <i>Commissioner Schwab</i>

NOTED BY THE COMMISSIONER
Affairs <i>[Signature]</i>
Finance and Administration
Safety
Utilities
Works

BUREAU APPROVAL
Bureau: Bureau of Fire
Prepared By: Greenslade/lh Date: 6/18/81
Budget Impact Review: <input type="checkbox"/> Completed <input checked="" type="checkbox"/> Not required
Bureau Head: <i>Francis J. Sargent</i> Francis J. Sargent

CALENDAR	
Consent <input checked="" type="checkbox"/>	Regular

NOTED BY
City Attorney
City Auditor
City Engineer