
## **Development Services**

#### From Concept to Construction







#### APPEAL SUMMARY

Status:	Hold for Additional Information
---------	---------------------------------

Appeal ID: 16553	Project Address: 1900 SE Lafayette St
Hearing Date: 2/28/18	Appellant Name: Mike Moerlins
Case No.: M-007	Appellant Phone: 503-382-2643
Appeal Type: Mechanical	Plans Examiner/Inspector: Thomas Ng
Project Type: commercial	Stories: 2 Occupancy: Utility and Misc Group U Construction Type: Type I
Building/Business Name:	Fire Sprinklers: Yes - Hoistway
Appeal Involves: Alteration of an existing structure	<b>LUR or Permit Application No.:</b> Original Building Permit #: 14-127672-000-00-CO
Plan Submitted Option: pdf [File 1]	Proposed use: Elevator

#### APPEAL INFORMATION SHEET

#### Appeal item 1

Code Section	OEESC, Chapter 5, Section 502

## **Requires** The building thermal envelope opaque assemblies shall meet the requirements of Table 502.1.1

and Section 502.2. Fenestration shall meet the requirements of 502.3.

#### **Proposed Design** This project includes the addition of a packaged HVAC system to serve an existing glass and steel

elevator hoistway, to provide heating and cooling only as required to meet the temperature and humidity requirements of the elevator machinery, for safe operation of the elevator system.

The proposed design does not include upgrades to the hoistway envelope (opaque assembly insulation, fenestration, etc.).


#### Reason for alternative Because this HVAC equipment is being installed only to serve the elevator equipment, and the


hoistway itself is an unoccupied "small building" (around 220 square feet) per OEESC 101.5.3, we believe that the energy code upgrades to the envelope (which is essentially all glass on four sides and an uninsulated roof) would not be required, even with the addition of HVAC to the space.

Additionally, the elevator hoistway walls are primarily glass due to visibility and safety concerns, and it's operation is needed to provide ADA access to the bridge. Our interpretation of the energy code is that it is not intended to abridge safety requirements per OEESC 101.3, which would potentially occur with the addition of opaque insulation to the hoistway envelope.

#### APPEAL DECISION

Omission of envelope insulation in elevator hoistway: Hold for additional information. Appellant may contact Thomas Ng (503-823-7434) for details.





GENERAL SHEET NOTES

A. INSTALL ALL EQUIPMENT SUCH THAT MANUFACTURER AND CODE REQUIRED CLEARANCES ARE MAINTAINED.

12x12 SG-1 500 TYP. 2

-12X12 SIDEWALL SUPPLY


M15LF-502

DIFFUSER, TYP. 8

ELEV. DOOR

## SHEET KEY NOTES

- I. DUCTWORK POINT OF ENTRY INTO HOISTWAY. COORDINATE EXACT LOCATION WITH ARCHITECTURAL DETAILS. SEE 3/MI5LF-502.
- 2. COORDINATE EXACT LOCATION OF AHU AND CONCRETE PAD WITH CIVIL AND STRUCTURAL ENGINEERS. COORDINATE HEIGHT OF PAD WITH CONDENSATE DRAINAGE REQUIREMENTS.
- 3. PROVIDE MOTORIZED DAMPER ON INTERIOR OF EXISTING HOISTWAY VENTILATION LOUVER. INTERLOCK NORMALLY-OPEN DAMPER OPERATION WITH ASSCOAITED AHU AND HOISTWAY FIRE ALARM SYSTEM. DAMPER TO CLOSE WHEN AHU SUPPLY FAN IS RUNNING. DAMPER TO OPEN UPON DETECTION OF SMOKE WITHIN THE HOISTWAY.
- 4. LOCATE VERTICAL SUPPLY DUCT BETWEEN EXISTING STRUCTURAL MEMBERS. LOCATE DUCTWORK BEHIND VERTICAL STEEL TUBING TO MAINTAIN CLEARANCE FROM MOVING ELEVATOR COMPONENTS.



DUCTWORK OVERLAY — HVAC
SCALE: 1/4" = 1'-0"

SCALE: I'' = 20'

90% DESIGN


SCALE: 1/4'' = 1'-0''9 TRI-COUNTY METROPOLITAN TRANSPORTATION DISTRICT OF OREGON 2/23/18 DATE MM DESIGNED LAFAYETTE ELEVATOR CORRECTIVE ACTION PLAN 2/23/18 DATE QB DRAWN CAPITAL PROJECTS HVAC ELEVATOR HOISTWAY 111 SW Fifth Ave., Suite 2500 Portland, OR 97204 O: 503.227.3251 DIVISION


1800 SW FIRST AVE., SUITE 300
PORTLAND, OREGON 97201 2/23/18 DATE 90% DESIGN 2-23-18 AL CHECKED INTERFACE 1-2-18 60% DESIGN F: 503.227.7980 ENGINEERING 2/23/18 DATE CONCEPT DESIGN 9-29-17 www.kpff.com EXPIRES: 12/31/18 APPROVED APPD. REVISIONS SHEET NO .: MI5LF-502 2/23/18 SC180092KN 2/23/18 AS SHOWN

14X14, TYP. 2 ——

30x36

30X36 RG-1





EAST AND WEST HOISTWAY SECTION — HVAC SCALE: 1/4" = 1'-0"

C. <u>EAST ELEVATION</u>

EAST AND WEST HOISTWAY ELEVATION - HVAC SCALE: 1/4" = 1'-0"

#### PACKAGED HEAT PUMP UNIT SCHEDULE BASIS OF DESIGN (NOTE #6) DX COOLING COIL SUPPLY FAN AIR SOURCE HEAT PUMP CONDENSER HEAT PUMP ELECTRICAL AUX TOTAL SENS EER HTG MIN MAXHTG HTG CAP CAP OR AMBIENT TOTAL ESP NOM AMBIENT OSA EDB EWB LDB LWB (°F) MHP DRIVE (MBH) (MBH) (MBH) (KW) STAGES TONS DB (°F) SEER (°F) WB (°F) AREA SERVED MODEL IN H20) COP | VOLTS | PH | MCA | MOCP | (LBS) SYMBOL MFR CFM CFM NOTES 2.75 DIRECT 126 94.5 111 40.6 3.6 208 3 193 200 1500 EAST TOWER 53 TRANE WSCI20E3 4000 1000 1.75 80 67 55 2 10 95 11.2 22 ALL 2.75 DIRECT 126 94.5 111 40.6 3.6 208 3 193 200 1500 AHU-2 WEST TOWER TRANE WSCI20E3 67 53 11.2 4000 1000 1.75 80 55 2 10 95 22 ALL


## NOTES:


- PROVIDE CONDENSATE TRAP TO DRAIN TO GRADE.
- PROVIDE WITH INTEGRAL DISCONNECT SWITCH AND UNPOWERED CONVENIENCE OUTLET. COORDINATE WITH ELECTRICAL CONTRACTOR.
- PROVIDE SMOKE DETECTOR IN RETURN OF ALL UNITS WITH SUPPLY AIR FLOW GREATER THAN 2,000 CFM. UNIT TO SHUT DOWN UPON DETECTION OF SMOKE.
- PROVIDE 0-100% ECONOMIZER WITH DRY BULB CONTROL
- PROVIDE ECM PREMIUM EFFICIENCY MOTOR
- TRANE UNIT IS BASI-OF-DESIGN ONLY. TRIMET APPROVED EQUIVALENT UNIT, PER SPECIFICATIONS SECTION 238100 (DECENTRALIZED UNITARY HVAC EQUIPMENT), IS ALSO ACCEPTABLE.
- UNIT TO MEET REQUIREMENTS OF THE "BUY AMERICAN" ACT.


DIFFUSER, REGISTER AND GRILLE SCHEDULE							
SYMBOL	TYPE	FACE	FRAME	DAMPER	FINISH	BASIS OF DESIGN	NOTES
RG-I	HEAVY DUTY RETURN GRILLE	FIXED BAR 30 DEG. DEFL.	SURFACE	NONE	COORD. W/ ARCH.	TITUS 63F	ALL
SR-I	SUPPLY REGISTER	SINGLE DEFL.	I/4" BORDER	OBD	COORD. W/ ARCH.	TITUS 301RS-HD	ALL

### NOTES:

- COORDINATE EXACT QUANTITY, SIZE, DAMPER TYPE, AND LOCATION WITH MECHANICAL PLANS.
- HEAVY DUTY, ANTI-CORROSION










## □ DETAIL KEYNOTE

I. PIPE SIZE TO MATCH AHU CONNECTION SIZE.



# 90% DESIGN

					MM	2/2
					DESIGNED	
					QB	2/2
					DRAWN	
	2-23-18			90% DESIGN	AL	2/2
	1-2-18			60% DESIGN	CHECKED	
	9-29-17			CONCEPT DESIGN	<u> </u>	2/2
NO.	DATE	BY	APPD.	REVISIONS	APPROVED	
		CHK.				


SUPPLY REGISTER DETAIL


SCALE: NTS

/23/18 DATE /23/18 DATE /23/18 DATE /23/18 DATE

GRILLE DETAIL

SCALE: NTS









CAPITAL PROJECTS DIVISION 1800 SW FIRST AVE., SUITE 300 PORTLAND, OREGON 97201

LAFAYETTE ELEVATOR CORRECTIVE ACTION PLAN

> HVAC SCHEDULES

CONTRACT NO.: DRAWING NO .:

2/23/18

APPROVED:

SCALE: NTS

2/23/18

MI5LF-503 NO SCALE

SC180092KN

SHEET NO .: