



City of Portland, Oregon - Bureau of Development Services

1900 SW Fourth Avenue • Portland, Oregon 97201 | 503-823-7300 | www.portland.gov/bds



Permit Revision Submittal Requirements and Application

A Permit Revision is required when there are proposed changes to the project after the permit has been issued. This may arise due to discrepancies between the city-approved permit drawings and actual field conditions, or the customer has changed their mind about an aspect of the project. In all cases, a revision to the existing permit must be submitted, reviewed and approved.

Minimum Submittal Requirements (check all boxes and sign below):

- ☒ A copy of this application.
- ☒ One PDF copy of plans for electronic submittals or three copies for paper submittals.
- ☒ All plans must clearly reflect the proposed change(s). Changes must be bubbled.
- ☐ Drawings and calculations must be stamped and signed by the Architect and/or the Engineer of Record, if applicable.
- ☐ Project narrative for extensive revisions.
- ☐ One PDF copy of calculations and other supporting documents for electronic submittals or two copies for paper submittals.
- ☐ Copy of Inspector's correction notice, if the revision is due to an inspection correction. One PDF copy for electronic submittals and two copies for paper submittals.

Applicant Information:

Applicant Name Bradlee Hersey (Faster Permits)

Street Address 2000 SW 1st Ste City/State/ZIP Portland OR 97201

Email Bradlee@fasterpermits.com Phone 503-913-8811

Value of Proposed Revision \$ 0 Issued Permit # 21-085113-RS

Job Site Address 15421 SE FLAVEL ST City/State/ZIP Portland OR

Description of Revision

Revision to Fire Sprinkler plans that were submitted as DFS (21-085113-DFS-01-RS). The plans and calculations are replacing the previous submittal.

Applicant Signature [Signature] Date 8/4/2022

Fees:

An invoice with permit fees will be sent to the applicant once minimum submittal requirements have been verified. Permit Revisions are subject to fees associated with plan review, processing and any increase in project value.

The Bureau of Development Services fee schedule is on the BDS web site: www.portlandoregon.gov/bds/article/102792

Helpful Information:

Bureau of Development Services | City of Portland, Oregon

1900 SW 4th Avenue, Portland, OR 97201

For Hours Call 503-823-7310 or visit www.portlandoregon.gov/bds

Important Telephone Numbers:

BDS main number	503-823-7300
DSC automated information line	503-823-7310
Building code information	503-823-1456
BDS 24-hour inspection request line	503-823-7000
Residential information for one- and two-family dwelling	503-823-7388
General Permit Processing and Fee Estimate info	503-823-7357
Zoning Information Line	503-823-7526
City of Portland TTY	503-823-6868

I hereby certify that this plan, specification, or report was prepared by me or under my direct supervision and that I am NICET Certified.



Tim W McDonald Date: 07/22/2022

NICET Certification No. 150393
Water-Based Systems Layout - Level III
Certification Expires: June 1, 2025

Uponor

AquaSAFE™ Fire Safety System

Hydratec Incorporated
64 Haverhill Road
Route 111
Windham, NH 03087
603-434-0502

Job Name : HAWTHORNE ESTATES - CAMBRIDGE - One Head Calculation (H.29)
Drawing : RESIDENTIAL
Location : SE HAWTHORNE MEADOWS ST PORTLAND OR 97236
Remote Area : 1
Contract : 42892F 004
Data File : 42892F 004 Hawthorne Estates - Cambridge.wx1
Date/Time : 07/22/2022 - 12:55 PM

SUBMITTED
09/15/2022

HYDRAULIC DESIGN INFORMATION SHEET

Name - HAWTHORNE ESTATES - CAMBRIDGE Date - 7/21/2022
Location - PORTLAND OR 97236
Building - RESIDENTIAL System No. - 1
Contractor - WOLCOTT PLUMBING Contract No. - 42892F 004
Calculated By - SILVIU RADES Drawing No. - F100
Construction: (X) Combustible () Non-Combustible Ceiling Height VARIES
OCCUPANCY - RESIDENTIAL


S Type of Calculation: () NFPA 13 Residential () NFPA 13R (X) NFPA 13D
Y Number of Sprinklers Flowing: (X) 1 () 2 () 4 ()
S () Other
T () Specific Ruling Made by Date
E
M Listed Flow at Start Point - 17 Gpm System Type
Listed Pres. at Start Point - 12 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 18 x 18 () Deluge () PreAction
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
S Additional Flow Added - Gpm Make SENJU Model RC-RES
I Elevation at Highest Outlet - 109 Feet Size 7/16 K-Factor 4.9
G Note: Temperature Rating 162
N

Calculation Gpm Required 17 Psi Required 74.34 At Ref Pt STR
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - x Rated Cap. Cap.
T Time of Test - x @ Psi Elev.
E Static (Psi) - 112 Elev.
R Residual (Psi) - 97 Other Well
Flow (Gpm) - 300 Proof Flow Gpm
S Elevation - 97
P Location: STREET
P
L Source of Information: CONTRACTOR
Y

Water Supply Curve

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - One Head Calculation (H.29)



Fittings Used Summary

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - One Head Calculation (H.29)

Fitting Legend Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

- Diameter Units Inches
- Length Units Feet
- Flow Units US Gallons per Minute
- Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - One Head Calculation (H.29)

Page 4
Date 7/22/2022

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
STR	112.0	97	300.0	111.926	16.97	74.343

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>		<i>Notes</i>
H.29	109.0	4.9	12.0	16.97	0.05	324
T.56	109.0		15.27			
T.55	109.0		15.71			
H.25	109.0		17.43			
T.53	109.0		18.46			
T.52	109.0		18.98			
H.20	109.0		20.09			
T.42	109.0		24.35			
H.19	109.0		24.86			
H.15	109.0		25.11			
T.41	109.0		25.58			
H.14	109.0		25.96			
H.18	109.0		26.15			
H.17	109.0		26.28			
H.16	109.0		26.46			
T.44	109.0		26.87			
T.43	109.0		26.94			
T.49	109.0		27.36			
T.50	109.0		27.56			
T.54	109.0		27.81			
S.1	109.0		29.08			
PRV	97.0		62.64			
SOV	97.0		62.69			
MTR	97.0		69.57			
STR	97.0		74.34			
H.30	109.0		13.39			
H.28	109.0		15.48			
T.57	109.0		16.88			
T.51	109.0		18.96			
T.48	109.0		19.86			
T.47	109.0		20.19			
H.23	109.0		20.96			
H.22	109.0		22.37			
T.46	109.0		23.78			
T.45	109.0		24.05			
H.21	109.0		24.18			
H.27	109.0		15.48			
H.24	109.0		20.03			
H.26	109.0		23.92			
T.36	118.0		20.77			
H.12	118.0		21.47			
H.11	118.0		21.64			

Flow Summary - NFPA

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - One Head Calculation (H.29)

Page 5
Date 7/22/2022

NODE ANALYSIS (cont.)

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
H.13	118.0		22.18		
T.39	118.0		22.47		
H.9	118.0		22.66		
T.37	118.0		23.25		
T.34	118.0		21.44		
H.5	118.0		21.65		
H.6	118.0		21.76		
H.4	118.0		21.89		
H.7	118.0		22.03		
H.8	118.0		22.14		
T.35	118.0		22.34		
T.38	118.0		23.21		
H.1	118.0		21.53		
T.32	118.0		21.69		
T.33	118.0		21.93		
H.2	118.0		21.96		
H.3	118.0		22.17		
H.10	118.0		23.23		

Final Calculations : Hazen-Williams

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - One Head Calculation (H.29)

Page 6
Date 7/22/2022

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
*Remote Head to Supply												
H.29 to T.56	109 109	4.90	8.98	0.75	Utr	0.0	17.000 2.000	150	12.000 0.0			
T.56 to T.55	109 109		8.98	0.671			19.000	0.1723	3.274	Vel =	8.15	
T.56 to T.55	109 109		-2.01	0.75	Utr	0.0	2.000 2.000	150	15.274 0.0			
T.55 to H.25	109 109		6.97	0.671			4.000	0.1080	0.432	Vel =	6.32	
T.55 to H.25	109 109		2.01	0.75	Utr	0.0	8.000 2.000	150	15.706 0.0			
H.25 to T.53	109 109		8.98	0.671			10.000	0.1723	1.723	Vel =	8.15	
H.25 to T.53	109 109		0.0	0.75	Utr	0.0	4.000 2.000	150	17.429 0.0			
T.53 to T.52	109 109		8.98	0.671			6.000	0.1722	1.033	Vel =	8.15	
T.53 to T.52	109 109		0.0	0.75	Utr	0.0	1.000 2.000	150	18.462 0.0			
T.52 to H.20	109 109		8.98	0.671			3.000	0.1723	0.517	Vel =	8.15	
T.52 to H.20	109 109		0.35	0.75	Utr	0.0	4.000 2.000	150	18.979 0.0			
H.20 to T.42	109 109		9.33	0.671			6.000	0.1853	1.112	Vel =	8.46	
H.20 to T.42	109 109		0.0	0.75	Utb Utr	0.0 0.0	4.000 19.000	150	20.091 0.0			
T.42 to H.19	109 109		9.33	0.671			23.000	0.1852	4.259	Vel =	8.46	
T.42 to H.19	109 109		-6.56	0.75	Utb	0.0	9.000 17.000	150	24.350 0.0			
H.19 to H.15	109 109		2.77	0.671			26.000	0.0196	0.509	Vel =	2.51	
H.19 to H.15	109 109		0.0	0.75	Utr	0.0	11.000 2.000	150	24.859 0.0			
H.15 to T.41	109 109		2.77	0.671			13.000	0.0195	0.254	Vel =	2.51	
H.15 to T.41	109 109		0.0	0.75	Utb Utr	0.0 0.0	5.000 19.000	150	25.113 0.0			
T.41 to H.14	109 109		2.77	0.671			24.000	0.0195	0.469	Vel =	2.51	
T.41 to H.14	109 109		-0.41	0.75	Utb Utr	0.0 0.0	7.000 19.000	150	25.582 0.0			
H.14 to H.18	109 109		2.36	0.671			26.000	0.0146	0.379	Vel =	2.14	
H.14 to H.18	109 109		0.0	0.75	Utr	0.0	11.000 2.000	150	25.961 0.0			
H.18 to H.17	109 109		2.36	0.671			13.000	0.0146	0.190	Vel =	2.14	
H.18 to H.17	109 109		0.0	0.75			9.000	150	26.151 0.0			
H.17 to H.16	109 109		2.36	0.671			9.000	0.0146	0.131	Vel =	2.14	
H.17 to H.16	109 109		0.0	0.75	Utr	0.0	10.000 2.000	150	26.282 0.0			
H.16 to T.44	109 109		2.36	0.671			12.000	0.0146	0.175	Vel =	2.14	
H.16 to T.44	109 109		0.0	0.75	Utb	0.0	11.000 17.000	150	26.457 0.0			
T.44 to T.43	109 109		2.36	0.671			28.000	0.0146	0.409	Vel =	2.14	
T.44 to T.43	109 109		7.65	1.25			3.000	150	26.866 0.0			
T.43	109		10.01	1.054			3.000	0.0233	0.070	Vel =	3.68	

Final Calculations : Hazen-Williams

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - One Head Calculation (H.29)

Page 7
Date 7/22/2022

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
T.43 to T.49	109 109		0.0 10.01	1.25 1.054	Utr Uel	0.0 0.0	3.000 15.000 18.000	150 0.0234	26.936 0.0 0.421		Vel = 3.68	
T.49 to T.50	109 109		3.43 13.44	1.25 1.054	Utr	0.0	1.000 4.000 5.000	150 0.0402	27.357 0.0 0.201		Vel = 4.94	
T.50 to T.54	109 109		3.53 16.97	1.25			4.000 4.000	150 0.0622	27.558 0.0 0.249		Vel = 6.24	
T.54 to S.1	109 109		0.0 16.97	1.25 1.054	Uel T	0.0 2.44	7.000 13.440 20.440	150 0.0621	27.807 0.0 1.269		Vel = 6.24	
S.1 to PRV	109 97		0.0 16.97	1.25 1.245	E T	2.746 5.492	5.000 8.237 13.237	150 0.0276	29.076 33.197 0.366		* * Fixed Loss = 28 Vel = 4.47	
PRV to SOV	97 97		0.0 16.97	1.25			2.000 2.000	150 0.0275	62.639 0.0 0.055		Vel = 4.47	
SOV to MTR	97 97		0.0 16.97	1.25 1.054	2E	2.44	60.000 2.440 62.440	150 0.0621	62.694 3.000 3.879		* * Fixed Loss = 3 Vel = 6.24	
MTR to STR	97 97		0.0 16.97	1 0.995	2E G	4.673 0.0	40.000 5.841 45.841	150 0.0822	69.573 1.000 3.770		* * Fixed Loss = 1 Vel = 7.00	
STR			0.0 16.97						74.343		K Factor = 1.97	
*New Path												
H.29 to H.30	109 109		8.00 8.0	0.75			10.000 10.000	150 0.1393	12.000 0.0 1.393		Vel = 7.26	
H.30 to H.28	109 109		0.0 8.0	0.75	Utr	0.0	13.000 2.000 15.000	150 0.1393	13.393 0.0 2.089		Vel = 7.26	
H.28 to T.57	109 109		0.0 8.0	0.75	Utr	0.0	8.000 2.000 10.000	150 0.1393	15.482 0.0 1.393		Vel = 7.26	
T.57 to T.51	109 109		0.0 8.0	0.75	Utr	0.0	13.000 2.000 15.000	150 0.1393	16.875 0.0 2.089		Vel = 7.26	
T.51 to T.48	109 109		-0.36 7.64	0.75	Utr	0.0	5.000 2.000 7.000	150 0.1280	18.964 0.0 0.896		Vel = 6.93	
T.48 to T.47	109 109		-1.58 6.06	0.75	Utr	0.0	2.000 2.000 4.000	150 0.0832	19.860 0.0 0.333		Vel = 5.50	
T.47 to H.23	109 109		1.58 7.64	0.75			6.000 6.000	150 0.1280	20.193 0.0 0.768		Vel = 6.93	

Final Calculations : Hazen-Williams

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - One Head Calculation (H.29)

Page 8
Date 7/22/2022

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
H.23 to H.22	109 109		0.0 7.64	0.75 0.671	Utr	0.0	9.000 2.000 11.000	150 0.1280	20.961 0.0 1.408		Vel = 6.93	
H.22 to T.46	109 109		0.0 7.64	0.75 0.671	Utr	0.0	9.000 2.000 11.000	150 0.1280	22.369 0.0 1.408		Vel = 6.93	
T.46 to T.45	109 109		-1.29 6.35	0.75 0.671	Utr	0.0	1.000 2.000 3.000	150 0.0910	23.777 0.0 0.273		Vel = 5.76	
T.45 to H.21	109 109		1.29 7.64	0.75 0.671			1.000 1.000	150	24.050 0.0		Vel = 6.93	
H.21 to T.44	109 109		0.0 7.64	0.75 0.671	Utb Utr	0.0 0.0	2.000 19.000 21.000	150 0.1280	24.178 0.0 2.688		Vel = 6.93	
T.44			0.0 7.64						26.866		K Factor = 1.47	
*New Path												
T.56 to H.27	109 109		2.01 2.01	0.75 0.671	Utb	0.0	2.000 17.000 19.000	150 0.0108	15.274 0.0 0.205		Vel = 1.82	
H.27 to T.55	109 109		0.0 2.01	0.75 0.671	Utb Utr	0.0 0.0	2.000 19.000 21.000	150 0.0108	15.479 0.0 0.227		Vel = 1.82	
T.55			0.0 2.01						15.706		K Factor = 0.51	
*New Path												
T.51 to T.52	109 109		0.36 0.36	0.75 0.671	2Utb	0.0	1.000 34.000 35.000	150 0.0004	18.964 0.0 0.015		Vel = 0.33	
T.52			0.0 0.36						18.979		K Factor = 0.08	
*New Path												
T.48 to H.24	109 109		1.58 1.58	0.75 0.671	Utb Utr	0.0 0.0	6.000 19.000 25.000	150 0.0070	19.860 0.0 0.174		Vel = 1.43	
H.24 to T.47	109 109		0.0 1.58	0.75 0.671	Utb	0.0	6.000 17.000 23.000	150 0.0069	20.034 0.0 0.159		Vel = 1.43	
T.47			0.0 1.58						20.193		K Factor = 0.35	
*New Path												
T.46 to H.26	109 109		1.29 1.29	0.75 0.671	Utb Utr	0.0 0.0	11.000 19.000 30.000	150 0.0048	23.777 0.0 0.144		Vel = 1.17	
H.26 to T.45	109 109		0.0 1.29	0.75 0.671	Utb	0.0	10.000 17.000 27.000	150 0.0048	23.921 0.0 0.129		Vel = 1.17	

Final Calculations : Hazen-Williams

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - One Head Calculation (H.29)

Page 9
Date 7/22/2022

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
T.45			0.0 1.29						24.050		K Factor = 0.26	
*New Path												
T.42 to T.36	109 118		6.56	1			11.000	150	24.350 -3.898 0.314		Vel = 3.61	
T.36 to H.12	118 118		-3.45	0.75	Utb Utr	0.0 0.0	10.000 19.000 29.000	150	20.766 0.0 0.705		Vel = 2.82	
H.12 to H.11	118 118		0.0	0.75	Utr	0.0	5.000 2.000 7.000	150	21.471 0.0 0.170		Vel = 2.82	
H.11 to H.13	118 118		0.0	0.75	Utr	0.0	20.000 2.000 22.000	150	21.641 0.0 0.535		Vel = 2.82	
H.13 to T.39	118 118		0.0	0.75			12.000	150	22.176 0.0 0.292		Vel = 2.82	
T.39 to H.9	118 118		0.0	0.75	Utr	0.0	6.000 2.000 8.000	150	22.468 0.0 0.194		Vel = 2.82	
H.9 to T.37	118 118		0.0	0.75	Utb Utr	0.0 0.0	5.000 19.000 24.000	150	22.662 0.0 0.584		Vel = 2.82	
T.37 to T.50	118 109		0.43	1	Utb	0.0	31.625 14.000 45.625	150	23.246 3.898 0.414		Vel = 1.95	
T.50			0.0 3.54						27.558		K Factor = 0.67	
*New Path												
T.36 to T.34	118 118		3.45	0.75	Utb	0.0	6.000 17.000 23.000	150	20.766 0.0 0.676		Vel = 3.13	
T.34 to H.5	118 118		-1.47	0.75	Utb Utr	0.0 0.0	1.000 19.000 20.000	150	21.442 0.0 0.210		Vel = 1.80	
H.5 to H.6	118 118		0.0	0.75			10.000	150	21.652 0.0 0.105		Vel = 1.80	
H.6 to H.4	118 118		0.0	0.75	Utr	0.0	11.000 2.000 13.000	150	21.757 0.0 0.136		Vel = 1.80	
H.4 to H.7	118 118		0.0	0.75	Utr	0.0	11.000 2.000 13.000	150	21.893 0.0 0.137		Vel = 1.80	
H.7 to H.8	118 118		0.0	0.75			10.000	150	22.030 0.0 0.105		Vel = 1.80	

Final Calculations : Hazen-Williams

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - One Head Calculation (H.29)

Page 10
Date 7/22/2022

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
H.8 to T.35	118 118		0.0 1.98	0.75 0.671	Utb Utr	0.0 0.0	1.000 19.000 20.000	150 0.0104	22.135 0.0 0.209		Vel = 1.80	
T.35 to T.38	118 118		1.88 3.86	0.75 0.671	Utb	0.0	7.000 17.000 24.000	150 0.0361	22.344 0.0 0.866		Vel = 3.50	
T.38 to T.49	118 109		-0.43 3.43	1 0.862	Utb	0.0	14.848 14.000 28.848	150 0.0086	23.210 3.898 0.249		Vel = 1.89	
T.49			0.0 3.43						27.357		K Factor = 0.66	
*New Path												
T.34 to H.1	118 118		1.47 1.47	0.75 0.671	Utr	0.0	13.000 2.000 15.000	150 0.0061	21.442 0.0 0.092		Vel = 1.33	
H.1 to T.32	118 118		0.0 1.47	0.75 0.671	Utb Utr	0.0 0.0	6.000 19.000 25.000	150 0.0061	21.534 0.0 0.152		Vel = 1.33	
T.32 to T.33	118 118		0.41 1.88	0.75 0.671	Utr Utb	0.0 0.0	7.000 19.000 26.000	150 0.0095	21.686 0.0 0.248		Vel = 1.71	
T.33 to H.2	118 118		0.0 1.88	0.75 0.671	Utr	0.0	1.000 2.000 3.000	150 0.0097	21.934 0.0 0.029		Vel = 1.71	
H.2 to H.3	118 118		0.0 1.88	0.75 0.671	Utr	0.0	20.000 2.000 22.000	150 0.0095	21.963 0.0 0.210		Vel = 1.71	
H.3 to T.35	118 118		0.0 1.88	0.75 0.671	Utr	0.0	16.000 2.000 18.000	150 0.0095	22.173 0.0 0.171		Vel = 1.71	
T.35			0.0 1.88						22.344		K Factor = 0.40	
*New Path												
T.41 to T.32	109 118		0.40 0.4	1 0.862			11.000 11.000	150 0.0002	25.582 -3.898 0.002		Vel = 0.22	
T.32			0.0 0.40						21.686		K Factor = 0.09	
*New Path												
T.38 to H.10	118 118		0.42 0.42	0.75 0.671	Utb Utr	0.0 0.0	10.000 19.000 29.000	150 0.0006	23.210 0.0 0.018		Vel = 0.38	
H.10 to T.37	118 118		0.0 0.42	0.75 0.671	Utb	0.0	13.000 17.000 30.000	150 0.0006	23.228 0.0 0.018		Vel = 0.38	
T.37			0.0 0.42						23.246		K Factor = 0.09	

Final Calculations : Hazen-Williams

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - One Head Calculation (H.29)

Page 11
Date 7/22/2022

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
----------------------	----------------	-----------	----------	------------	------------------------	-----	------------------------	----------------	----------------	-------	-------	-------

I hereby certify that this plan, specification, or report was prepared by me or under my direct supervision and that I am NICET Certified.



Tim W McDonald Date: 07/22/2022

NICET Certification No. 150393
Water-Based Systems Layout - Level III
Certification Expires: June 1, 2025

Uponor

AquaSAFE™ Fire Safety System

Hydratec Incorporated
64 Haverhill Road
Route 111
Windham, NH 03087
603-434-0502

Job Name : HAWTHORNE ESTATES - CAMBRIDGE - One Head Calculation (H.29)
Drawing : RESIDENTIAL
Location : SE HAWTHORNE MEADOWS ST PORTLAND OR 97236
Remote Area : 1
Contract : 42892F 004
Data File : 42892F 004 Hawthorne Estates - Cambridge.wx1
Date/Time : 07/22/2022 - 12:55 PM

HYDRAULIC DESIGN INFORMATION SHEET

Name - HAWTHORNE ESTATES - CAMBRIDGE Date - 7/21/2022
Location - PORTLAND OR 97236
Building - RESIDENTIAL System No. - 1
Contractor - WOLCOTT PLUMBING Contract No. - 42892F 004
Calculated By - SILVIU RADES Drawing No. - F100
Construction: (X) Combustible () Non-Combustible Ceiling Height VARIES
OCCUPANCY - RESIDENTIAL


S Type of Calculation: () NFPA 13 Residential () NFPA 13R (X) NFPA 13D
Y Number of Sprinklers Flowing: (X) 1 () 2 () 4 ()
S () Other
T () Specific Ruling Made by Date
E
M Listed Flow at Start Point - 17 Gpm System Type
Listed Pres. at Start Point - 12 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 18 x 18 () Deluge () PreAction
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
S Additional Flow Added - Gpm Make SENJU Model RC-RES
I Elevation at Highest Outlet - 109 Feet Size 7/16 K-Factor 4.9
G Note: Temperature Rating 162
N

Calculation Gpm Required 17 Psi Required 74.34 At Ref Pt STR
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - x Rated Cap. Cap.
T Time of Test - x @ Psi Elev.
E Static (Psi) - 112 Elev.
R Residual (Psi) - 97 Other Well
Flow (Gpm) - 300 Proof Flow Gpm
S Elevation - 97
P Location: STREET
P
L Source of Information: CONTRACTOR
Y

Water Supply Curve

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - One Head Calculation (H.29)



Fittings Used Summary

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - One Head Calculation (H.29)

Fitting Legend Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

- Diameter Units Inches
- Length Units Feet
- Flow Units US Gallons per Minute
- Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - One Head Calculation (H.29)

Page 4
Date 7/22/2022

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
STR	112.0	97	300.0	111.926	16.97	74.343

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>		<i>Notes</i>
H.29	109.0	4.9	12.0	16.97	0.05	324
T.56	109.0		15.27			
T.55	109.0		15.71			
H.25	109.0		17.43			
T.53	109.0		18.46			
T.52	109.0		18.98			
H.20	109.0		20.09			
T.42	109.0		24.35			
H.19	109.0		24.86			
H.15	109.0		25.11			
T.41	109.0		25.58			
H.14	109.0		25.96			
H.18	109.0		26.15			
H.17	109.0		26.28			
H.16	109.0		26.46			
T.44	109.0		26.87			
T.43	109.0		26.94			
T.49	109.0		27.36			
T.50	109.0		27.56			
T.54	109.0		27.81			
S.1	109.0		29.08			
PRV	97.0		62.64			
SOV	97.0		62.69			
MTR	97.0		69.57			
STR	97.0		74.34			
H.30	109.0		13.39			
H.28	109.0		15.48			
T.57	109.0		16.88			
T.51	109.0		18.96			
T.48	109.0		19.86			
T.47	109.0		20.19			
H.23	109.0		20.96			
H.22	109.0		22.37			
T.46	109.0		23.78			
T.45	109.0		24.05			
H.21	109.0		24.18			
H.27	109.0		15.48			
H.24	109.0		20.03			
H.26	109.0		23.92			
T.36	118.0		20.77			
H.12	118.0		21.47			
H.11	118.0		21.64			

Flow Summary - NFPA

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - One Head Calculation (H.29)

Page 5
Date 7/22/2022

NODE ANALYSIS (cont.)

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
H.13	118.0		22.18		
T.39	118.0		22.47		
H.9	118.0		22.66		
T.37	118.0		23.25		
T.34	118.0		21.44		
H.5	118.0		21.65		
H.6	118.0		21.76		
H.4	118.0		21.89		
H.7	118.0		22.03		
H.8	118.0		22.14		
T.35	118.0		22.34		
T.38	118.0		23.21		
H.1	118.0		21.53		
T.32	118.0		21.69		
T.33	118.0		21.93		
H.2	118.0		21.96		
H.3	118.0		22.17		
H.10	118.0		23.23		

Final Calculations : Hazen-Williams

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - One Head Calculation (H.29)

Page 6
Date 7/22/2022

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
*Remote Head to Supply												
H.29 to T.56	109 109	4.90	8.98	0.75	Utr	0.0	17.000 2.000	150	12.000 0.0			
T.56 to T.55	109 109		8.98	0.671			19.000	0.1723	3.274	Vel =	8.15	
T.55 to T.52	109 109		-2.01	0.75	Utr	0.0	2.000 2.000	150	15.274 0.0			
T.52 to H.25	109 109		6.97	0.671			4.000	0.1080	0.432	Vel =	6.32	
H.25 to H.25	109 109		2.01	0.75	Utr	0.0	8.000 2.000	150	15.706 0.0			
H.25 to T.53	109 109		8.98	0.671			10.000	0.1723	1.723	Vel =	8.15	
T.53 to T.52	109 109		0.0	0.75	Utr	0.0	4.000 2.000	150	17.429 0.0			
T.52 to H.20	109 109		8.98	0.671			6.000	0.1722	1.033	Vel =	8.15	
H.20 to T.42	109 109		0.0	0.75	Utr	0.0	1.000 2.000	150	18.462 0.0			
T.42 to H.19	109 109		8.98	0.671			3.000	0.1723	0.517	Vel =	8.15	
H.19 to H.15	109 109		0.35	0.75	Utr	0.0	4.000 2.000	150	18.979 0.0			
H.15 to T.41	109 109		9.33	0.671			6.000	0.1853	1.112	Vel =	8.46	
T.41 to H.14	109 109		0.0	0.75	Utb Utr	0.0 0.0	4.000 19.000	150	20.091 0.0			
H.14 to H.18	109 109		9.33	0.671			23.000	0.1852	4.259	Vel =	8.46	
H.18 to H.17	109 109		-6.56	0.75	Utb	0.0	9.000 17.000	150	24.350 0.0			
H.17 to H.16	109 109		2.77	0.671			26.000	0.0196	0.509	Vel =	2.51	
H.16 to T.44	109 109		0.0	0.75	Utr	0.0	11.000 2.000	150	24.859 0.0			
T.44 to T.43	109 109		2.77	0.671			13.000	0.0195	0.254	Vel =	2.51	
T.43 to T.43	109 109		0.0	0.75	Utb Utr	0.0 0.0	5.000 19.000	150	25.113 0.0			
T.43 to T.43	109 109		2.77	0.671			24.000	0.0195	0.469	Vel =	2.51	
T.43 to T.43	109 109		-0.41	0.75	Utb Utr	0.0 0.0	7.000 19.000	150	25.582 0.0			
T.43 to T.43	109 109		2.36	0.671			26.000	0.0146	0.379	Vel =	2.14	
T.43 to T.43	109 109		0.0	0.75	Utr	0.0	11.000 2.000	150	25.961 0.0			
T.43 to T.43	109 109		2.36	0.671			13.000	0.0146	0.190	Vel =	2.14	
T.43 to T.43	109 109		0.0	0.75			9.000	150	26.151 0.0			
T.43 to T.43	109 109		2.36	0.671			9.000	0.0146	0.131	Vel =	2.14	
T.43 to T.43	109 109		0.0	0.75	Utr	0.0	10.000 2.000	150	26.282 0.0			
T.43 to T.43	109 109		2.36	0.671			12.000	0.0146	0.175	Vel =	2.14	
T.43 to T.43	109 109		0.0	0.75	Utb	0.0	11.000 17.000	150	26.457 0.0			
T.43 to T.43	109 109		2.36	0.671			28.000	0.0146	0.409	Vel =	2.14	
T.43 to T.43	109 109		7.65	1.25			3.000	150	26.866 0.0			
T.43 to T.43	109 109		10.01	1.054			3.000	0.0233	0.070	Vel =	3.68	

Final Calculations : Hazen-Williams

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - One Head Calculation (H.29)

Page 7
Date 7/22/2022

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
T.43 to T.49	109 109		0.0 10.01	1.25 1.054	Utr Uel	0.0 0.0	3.000 15.000 18.000	150 0.0234	26.936 0.0 0.421		Vel = 3.68	
T.49 to T.50	109 109		3.43 13.44	1.25 1.054	Utr	0.0	1.000 4.000 5.000	150 0.0402	27.357 0.0 0.201		Vel = 4.94	
T.50 to T.54	109 109		3.53 16.97	1.25 1.054			4.000 4.000	150 0.0622	27.558 0.0 0.249		Vel = 6.24	
T.54 to S.1	109 109		0.0 16.97	1.25 1.054	Uel T	0.0 2.44	7.000 13.440 20.440	150 0.0621	27.807 0.0 1.269		Vel = 6.24	
S.1 to PRV	109 97		0.0 16.97	1.25 1.245	E T	2.746 5.492	5.000 8.237 13.237	150 0.0276	29.076 33.197 0.366		** Fixed Loss = 28 Vel = 4.47	
PRV to SOV	97 97		0.0 16.97	1.25 1.245			2.000 2.000	150 0.0275	62.639 0.0 0.055		Vel = 4.47	
SOV to MTR	97 97		0.0 16.97	1.25 1.054	2E	2.44	60.000 2.440 62.440	150 0.0621	62.694 3.000 3.879		** Fixed Loss = 3 Vel = 6.24	
MTR to STR	97 97		0.0 16.97	1 0.995	2E G	4.673 0.0	40.000 5.841 45.841	150 0.0822	69.573 1.000 3.770		** Fixed Loss = 1 Vel = 7.00	
STR			0.0 16.97						74.343		K Factor = 1.97	
*New Path												
H.29 to H.30	109 109		8.00 8.0	0.75 0.671			10.000 10.000	150 0.1393	12.000 0.0 1.393		Vel = 7.26	
H.30 to H.28	109 109		0.0 8.0	0.75 0.671	Utr	0.0	13.000 2.000 15.000	150 0.1393	13.393 0.0 2.089		Vel = 7.26	
H.28 to T.57	109 109		0.0 8.0	0.75 0.671	Utr	0.0	8.000 2.000 10.000	150 0.1393	15.482 0.0 1.393		Vel = 7.26	
T.57 to T.51	109 109		0.0 8.0	0.75 0.671	Utr	0.0	13.000 2.000 15.000	150 0.1393	16.875 0.0 2.089		Vel = 7.26	
T.51 to T.48	109 109		-0.36 7.64	0.75 0.671	Utr	0.0	5.000 2.000 7.000	150 0.1280	18.964 0.0 0.896		Vel = 6.93	
T.48 to T.47	109 109		-1.58 6.06	0.75 0.671	Utr	0.0	2.000 2.000 4.000	150 0.0832	19.860 0.0 0.333		Vel = 5.50	
T.47 to H.23	109 109		1.58 7.64	0.75 0.671			6.000 6.000	150 0.1280	20.193 0.0 0.768		Vel = 6.93	

Final Calculations : Hazen-Williams

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - One Head Calculation (H.29)

Page 8
Date 7/22/2022

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
H.23 to H.22	109 109		0.0 7.64	0.75 0.671	Utr	0.0	9.000 2.000 11.000	150 0.1280	20.961 0.0 1.408		Vel = 6.93	
H.22 to T.46	109 109		0.0 7.64	0.75 0.671	Utr	0.0	9.000 2.000 11.000	150 0.1280	22.369 0.0 1.408		Vel = 6.93	
T.46 to T.45	109 109		-1.29 6.35	0.75 0.671	Utr	0.0	1.000 2.000 3.000	150 0.0910	23.777 0.0 0.273		Vel = 5.76	
T.45 to H.21	109 109		1.29 7.64	0.75 0.671			1.000 1.000	150	24.050 0.0		Vel = 6.93	
H.21 to T.44	109 109		0.0 7.64	0.75 0.671	Utb Utr	0.0 0.0	2.000 19.000 21.000	150 0.1280	24.178 0.0 2.688		Vel = 6.93	
T.44			0.0 7.64						26.866		K Factor = 1.47	
*New Path												
T.56 to H.27	109 109		2.01 2.01	0.75 0.671	Utb	0.0	2.000 17.000 19.000	150 0.0108	15.274 0.0 0.205		Vel = 1.82	
H.27 to T.55	109 109		0.0 2.01	0.75 0.671	Utb Utr	0.0 0.0	2.000 19.000 21.000	150 0.0108	15.479 0.0 0.227		Vel = 1.82	
T.55			0.0 2.01						15.706		K Factor = 0.51	
*New Path												
T.51 to T.52	109 109		0.36 0.36	0.75 0.671	2Utb	0.0	1.000 34.000 35.000	150 0.0004	18.964 0.0 0.015		Vel = 0.33	
T.52			0.0 0.36						18.979		K Factor = 0.08	
*New Path												
T.48 to H.24	109 109		1.58 1.58	0.75 0.671	Utb Utr	0.0 0.0	6.000 19.000 25.000	150 0.0070	19.860 0.0 0.174		Vel = 1.43	
H.24 to T.47	109 109		0.0 1.58	0.75 0.671	Utb	0.0	6.000 17.000 23.000	150 0.0069	20.034 0.0 0.159		Vel = 1.43	
T.47			0.0 1.58						20.193		K Factor = 0.35	
*New Path												
T.46 to H.26	109 109		1.29 1.29	0.75 0.671	Utb Utr	0.0 0.0	11.000 19.000 30.000	150 0.0048	23.777 0.0 0.144		Vel = 1.17	
H.26 to T.45	109 109		0.0 1.29	0.75 0.671	Utb	0.0	10.000 17.000 27.000	150 0.0048	23.921 0.0 0.129		Vel = 1.17	

Final Calculations : Hazen-Williams

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - One Head Calculation (H.29)

Page 9
Date 7/22/2022

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
T.45			0.0 1.29						24.050		K Factor = 0.26	
*New Path												
T.42 to T.36	109 118		6.56	1			11.000	150	24.350 -3.898 0.314		Vel = 3.61	
T.36 to H.12	118 118		-3.45	0.75	Utb Utr	0.0 0.0	10.000 19.000 29.000	150	20.766 0.0 0.705		Vel = 2.82	
H.12 to H.11	118 118		0.0	0.75	Utr	0.0	5.000 2.000 7.000	150	21.471 0.0 0.170		Vel = 2.82	
H.11 to H.13	118 118		0.0	0.75	Utr	0.0	20.000 2.000 22.000	150	21.641 0.0 0.535		Vel = 2.82	
H.13 to T.39	118 118		0.0	0.75			12.000	150	22.176 0.0 0.292		Vel = 2.82	
T.39 to H.9	118 118		0.0	0.75	Utr	0.0	6.000 2.000 8.000	150	22.468 0.0 0.194		Vel = 2.82	
H.9 to T.37	118 118		0.0	0.75	Utb Utr	0.0 0.0	5.000 19.000 24.000	150	22.662 0.0 0.584		Vel = 2.82	
T.37 to T.50	118 109		0.43	1	Utb	0.0	31.625 14.000 45.625	150	23.246 3.898 0.414		Vel = 1.95	
T.50			0.0 3.54						27.558		K Factor = 0.67	
*New Path												
T.36 to T.34	118 118		3.45	0.75	Utb	0.0	6.000 17.000 23.000	150	20.766 0.0 0.676		Vel = 3.13	
T.34 to H.5	118 118		-1.47	0.75	Utb Utr	0.0 0.0	1.000 19.000 20.000	150	21.442 0.0 0.210		Vel = 1.80	
H.5 to H.6	118 118		0.0	0.75			10.000	150	21.652 0.0 0.105		Vel = 1.80	
H.6 to H.4	118 118		0.0	0.75	Utr	0.0	11.000 2.000 13.000	150	21.757 0.0 0.136		Vel = 1.80	
H.4 to H.7	118 118		0.0	0.75	Utr	0.0	11.000 2.000 13.000	150	21.893 0.0 0.137		Vel = 1.80	
H.7 to H.8	118 118		0.0	0.75			10.000	150	22.030 0.0 0.105		Vel = 1.80	

Final Calculations : Hazen-Williams

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - One Head Calculation (H.29)

Page 10
Date 7/22/2022

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
H.8 to T.35	118 118		0.0 1.98	0.75 0.671	Utb Utr	0.0 0.0	1.000 19.000 20.000	150 0.0104	22.135 0.0 0.209		Vel = 1.80	
T.35 to T.38	118 118		1.88 3.86	0.75 0.671	Utb	0.0	7.000 17.000 24.000	150 0.0361	22.344 0.0 0.866		Vel = 3.50	
T.38 to T.49	118 109		-0.43 3.43	1 0.862	Utb	0.0	14.848 14.000 28.848	150 0.0086	23.210 3.898 0.249		Vel = 1.89	
T.49			0.0 3.43						27.357		K Factor = 0.66	
*New Path												
T.34 to H.1	118 118		1.47 1.47	0.75 0.671	Utr	0.0	13.000 2.000 15.000	150 0.0061	21.442 0.0 0.092		Vel = 1.33	
H.1 to T.32	118 118		0.0 1.47	0.75 0.671	Utb Utr	0.0 0.0	6.000 19.000 25.000	150 0.0061	21.534 0.0 0.152		Vel = 1.33	
T.32 to T.33	118 118		0.41 1.88	0.75 0.671	Utr Utb	0.0 0.0	7.000 19.000 26.000	150 0.0095	21.686 0.0 0.248		Vel = 1.71	
T.33 to H.2	118 118		0.0 1.88	0.75 0.671	Utr	0.0	1.000 2.000 3.000	150 0.0097	21.934 0.0 0.029		Vel = 1.71	
H.2 to H.3	118 118		0.0 1.88	0.75 0.671	Utr	0.0	20.000 2.000 22.000	150 0.0095	21.963 0.0 0.210		Vel = 1.71	
H.3 to T.35	118 118		0.0 1.88	0.75 0.671	Utr	0.0	16.000 2.000 18.000	150 0.0095	22.173 0.0 0.171		Vel = 1.71	
T.35			0.0 1.88						22.344		K Factor = 0.40	
*New Path												
T.41 to T.32	109 118		0.40 0.4	1 0.862			11.000 11.000	150 0.0002	25.582 -3.898 0.002		Vel = 0.22	
T.32			0.0 0.40						21.686		K Factor = 0.09	
*New Path												
T.38 to H.10	118 118		0.42 0.42	0.75 0.671	Utb Utr	0.0 0.0	10.000 19.000 29.000	150 0.0006	23.210 0.0 0.018		Vel = 0.38	
H.10 to T.37	118 118		0.0 0.42	0.75 0.671	Utb	0.0	13.000 17.000 30.000	150 0.0006	23.228 0.0 0.018		Vel = 0.38	
T.37			0.0 0.42						23.246		K Factor = 0.09	

Final Calculations : Hazen-Williams

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - One Head Calculation (H.29)

Page 11
Date 7/22/2022

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****

I hereby certify that this plan, specification, or report was prepared by me or under my direct supervision and that I am NICET Certified.



Tim W McDonald Date: 07/22/2022

NICET Certification No. 150393
Water-Based Systems Layout - Level III
Certification Expires: June 1, 2025

Uponor

AquaSAFE™ Fire Safety System

Hydratec Incorporated
64 Haverhill Road
Route 111
Windham, NH 03087
603-434-0502

SUBMITTED
09/15/2022

Job Name : HAWTHORNE ESTATES - CAMBRIDGE - Two Head Calculation (H.6 & H.5)
Drawing : RESIDENTIAL
Location : SE HAWTHORNE MEADOWS ST PORTLAND OR 97236
Remote Area : 1
Contract : 42892F 004
Data File : 42892F 004 Hawthorne Estates - Cambridge.wx2
Date/Time : 07/22/2022 - 12:54 PM

HYDRAULIC DESIGN INFORMATION SHEET

Name - HAWTHORNE ESTATES - CAMBRIDGE Date - 7/21/2022
Location - PORTLAND OR 97236
Building - RESIDENTIAL System No. - 1
Contractor - WOLCOTT PLUMBING Contract No. - 42892F 004
Calculated By - SILVIU RADES Drawing No. - F100
Construction: (X) Combustible () Non-Combustible Ceiling Height VARIES
OCCUPANCY - RESIDENTIAL


S Type of Calculation: () NFPA 13 Residential () NFPA 13R (X) NFPA 13D
Y Number of Sprinklers Flowing: () 1 (X) 2 () 4 ()
S () Other
T () Specific Ruling Made by Date
E
M Listed Flow at Start Point - 13 Gpm System Type
Listed Pres. at Start Point - 7.04 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
S Additional Flow Added - Gpm Make SENJU Model RC-RES
I Elevation at Highest Outlet - 118 Feet Size 7/16 K-Factor 4.9
G Note: Temperature Rating 162
N

Calculation Gpm Required 26.1335 Psi Required 90.23 At Ref Pt STR
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - x Rated Cap. Cap.
T Time of Test - x @ Psi Elev.
E Static (Psi) - 112 Elev.
R Residual (Psi) - 97 Other Well
Flow (Gpm) - 300 Proof Flow Gpm
S Elevation - 97
P Location: STREET
P
L Source of Information: CONTRACTOR
Y

Water Supply Curve

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - Two Head Calculation (H.6 & H.5)



Fittings Used Summary

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - Two Head Calculation (H.6 & H.5)

Fitting Legend Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

- Diameter Units Inches
- Length Units Feet
- Flow Units US Gallons per Minute
- Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - Two Head Calculation (H.6 & H.5)

Page 4
Date 7/22/2022

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
STR	112.0	97	300.0	111.836	26.13	90.226

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>		<i>Notes</i>
H.6	118.0	4.9	7.04	13.0	0.05	256
H.4	118.0		10.12			
H.7	118.0		13.21			
H.8	118.0		15.58			
T.35	118.0		20.32			
T.38	118.0		25.99			
T.49	109.0		31.33			
T.50	109.0		31.73			
T.54	109.0		32.28			
S.1	109.0		35.1			
PRV	97.0		69.11			
SOV	97.0		69.23			
MTR	97.0		80.85			
STR	97.0		90.23			
H.5	118.0	4.9	7.18	13.13	0.05	256
T.34	118.0		16.62			
T.36	118.0		20.64			
H.12	118.0		22.3			
H.11	118.0		22.7			
H.13	118.0		23.96			
T.39	118.0		24.65			
H.9	118.0		25.11			
T.37	118.0		26.48			
H.1	118.0		18.01			
T.32	118.0		20.32			
T.41	109.0		24.52			
H.14	109.0		26.37			
H.18	109.0		27.3			
H.17	109.0		27.94			
H.16	109.0		28.79			
T.44	109.0		30.79			
T.43	109.0		30.86			
H.3	118.0		20.32			
H.2	118.0		20.32			
T.33	118.0		20.32			
H.15	109.0		24.58			
H.19	109.0		24.61			
T.42	109.0		24.67			
H.20	109.0		26.0			
T.52	109.0		26.35			
T.51	109.0		27.21			
T.48	109.0		27.61			

Flow Summary - NFPA

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - Two Head Calculation (H.6 & H.5)

Page 5
Date 7/22/2022

NODE ANALYSIS (cont.)

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
T.47	109.0		27.76		
H.23	109.0		28.11		
H.22	109.0		28.75		
T.46	109.0		29.39		
T.45	109.0		29.51		
H.21	109.0		29.57		
T.53	109.0		26.38		
H.25	109.0		26.44		
T.55	109.0		26.53		
T.56	109.0		26.56		
H.29	109.0		26.73		
H.30	109.0		26.83		
H.28	109.0		26.97		
T.57	109.0		27.06		
H.27	109.0		26.54		
H.24	109.0		27.69		
H.26	109.0		29.45		
H.10	118.0		26.23		

Final Calculations : Hazen-Williams

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - Two Head Calculation (H.6 & H.5)

Page 6
Date 7/22/2022

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
*Remote Head to Supply												
H.6 to H.4	118 118	4.90	10.67	0.75	Utr	0.0	11.000 2.000	150	7.040 0.0			
H.4 to H.7	118 118		10.67	0.671			13.000	0.2372	3.083	Vel =	9.68	
H.7 to H.8	118 118		0.0	0.75	Utr	0.0	11.000 2.000	150	10.123 0.0			
H.8 to H.8	118 118		10.67	0.671			13.000	0.2372	3.083	Vel =	9.68	
H.8 to T.35	118 118		0.0	0.75	Utb Utr	0.0 0.0	10.000 1.000	150	13.206 15.578			
T.35 to T.38	118 118		10.67	0.671			10.000	0.2372	2.372	Vel =	9.68	
T.38 to T.49	118 109		0.0	0.75	Utb	0.0	19.000 7.000	150	0.0 20.322			
T.49 to T.50	109 109		10.67	0.671			20.000	0.2372	4.744	Vel =	9.68	
T.50 to T.54	109 109		-0.03	0.75	Utb	0.0	17.000 24.000	150	0.0 5.665			
T.54 to S.1	109 109		10.64	0.671			24.000	0.2360	5.665	Vel =	9.65	
S.1 to PRV	109 97		-1.75	1	Utb	0.0	14.848 14.000	150	25.987 3.898			
PRV to SOV	97 97		8.89	0.862			28.848	0.0500	1.443	Vel =	4.89	
SOV to MTR	97 97		10.55	1.25	Utr	0.0	1.000 4.000	150	31.328 0.0			
MTR to STR	97 97		19.44	1.054			5.000	0.0798	0.399	Vel =	7.15	
STR to STR	97 97		6.69	1.25			4.000	150	31.727 0.0			
STR to STR	97 97		26.13	1.054			4.000	0.1380	0.552	Vel =	9.61	
STR to STR	97 97		0.0	1.25	Uel T	0.0 2.44	7.000 13.440	150	32.279 0.0			
STR to STR	97 97		26.13	1.054			20.440	0.1380	2.821	Vel =	9.61	
STR to STR	97 97		0.0	1.25	E T	2.746 5.492	5.000 8.237	150	35.100 33.197		** Fixed Loss = 28	
STR to STR	97 97		26.13	1.245			13.237	0.0613	0.812	Vel =	6.89	
STR to STR	97 97		0.0	1.25			2.000	150	69.109 0.0			
STR to STR	97 97		26.13	1.245			2.000	0.0615	0.123	Vel =	6.89	
STR to STR	97 97		0.0	1.25	2E	2.44	60.000 2.440	150	69.232 3.000		** Fixed Loss = 3	
STR to STR	97 97		26.13	1.054			62.440	0.1380	8.618	Vel =	9.61	
STR to STR	97 97		0.0	1	2E G	4.673 0.0	40.000 5.841	150	80.850 1.000		** Fixed Loss = 1	
STR to STR	97 97		26.13	0.995			45.841	0.1827	8.376	Vel =	10.78	
STR to STR	97 97		0.0 26.13						90.226	K Factor =	2.75	
*New Path												
H.6 to H.5	118 118		2.34	0.75			10.000	150	7.040 0.0			
H.5 to T.34	118 118	4.90	2.34	0.671			10.000	0.0143	0.143	Vel =	2.12	
T.34 to T.34	118 118		13.13	0.75	Utb Utr	0.0 0.0	1.000 19.000	150	7.183 0.0			
T.34 to T.34	118 118		15.47	0.671			20.000	0.4716	9.433	Vel =	14.04	

Final Calculations : Hazen-Williams

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - Two Head Calculation (H.6 & H.5)

Page 7
Date 7/22/2022

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
T.34 to T.36	118 118		-6.42 9.05	0.75 0.671	Utb	0.0	6.000 17.000 23.000	150 0.1750	16.616 0.0 4.025		Vel = 8.21	
T.36 to H.12	118 118		-4.10 4.95	0.75 0.671	Utb Utr	0.0 0.0	10.000 19.000 29.000	150 0.0572	20.641 0.0 1.660		Vel = 4.49	
H.12 to H.11	118 118		0.0 4.95	0.75 0.671	Utr	0.0	5.000 2.000 7.000	150 0.0573	22.301 0.0 0.401		Vel = 4.49	
H.11 to H.13	118 118		0.0 4.95	0.75 0.671	Utr	0.0	20.000 2.000 22.000	150 0.0572	22.702 0.0 1.259		Vel = 4.49	
H.13 to T.39	118 118		0.0 4.95	0.75 0.671			12.000 12.000	150 0.0572	23.961 0.0 0.687		Vel = 4.49	
T.39 to H.9	118 118		0.0 4.95	0.75 0.671	Utr	0.0	6.000 2.000 8.000	150 0.0572	24.648 0.0 0.458		Vel = 4.49	
H.9 to T.37	118 118		0.0 4.95	0.75 0.671	Utb Utr	0.0 0.0	5.000 19.000 24.000	150 0.0572	25.106 0.0 1.374		Vel = 4.49	
T.37 to T.50	118 109		1.74 6.69	1 0.862	Utb	0.0	31.625 14.000 45.625	150 0.0296	26.480 3.898 1.349		Vel = 3.68	
T.50			0.0 6.69						31.727		K Factor = 1.19	
*New Path												
T.34 to H.1	118 118		6.42 6.42	0.75 0.671	Utr	0.0	13.000 2.000 15.000	150 0.0927	16.616 0.0 1.390		Vel = 5.82	
H.1 to T.32	118 118		0.0 6.42	0.75 0.671	Utb Utr	0.0 0.0	6.000 19.000 25.000	150 0.0926	18.006 0.0 2.316		Vel = 5.82	
T.32 to T.41	118 109		0.02 6.44	1 0.862			11.000 11.000	150 0.0275	20.322 3.898 0.303		Vel = 3.54	
T.41 to H.14	109 109		-0.88 5.56	0.75 0.671	Utb Utr	0.0 0.0	7.000 19.000 26.000	150 0.0712	24.523 0.0 1.851		Vel = 5.04	
H.14 to H.18	109 109		0.0 5.56	0.75 0.671	Utr	0.0	11.000 2.000 13.000	150 0.0712	26.374 0.0 0.925		Vel = 5.04	
H.18 to H.17	109 109		0.0 5.56	0.75 0.671			9.000 9.000	150 0.0712	27.299 0.0 0.641		Vel = 5.04	
H.17 to H.16	109 109		0.0 5.56	0.75 0.671	Utr	0.0	10.000 2.000 12.000	150 0.0712	27.940 0.0 0.854		Vel = 5.04	

Final Calculations : Hazen-Williams

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - Two Head Calculation (H.6 & H.5)

Page 8
Date 7/22/2022

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
H.16 to T.44	109 109		0.0 5.56	0.75 0.671	Utb	0.0	11.000 17.000 28.000	150 0.0712	28.794 0.0 1.993		Vel = 5.04	
T.44 to T.43	109 109		4.99 10.55	1.25 1.054			3.000 3.000	150 0.0257	30.787 0.0 0.077		Vel = 3.88	
T.43 to T.49	109 109		0.0 10.55	1.25 1.054	Utr Uel	0.0 0.0	3.000 15.000 18.000	150 0.0258	30.864 0.0 0.464		Vel = 3.88	
T.49			0.0 10.55						31.328		K Factor = 1.88	
*New Path												
T.35 to H.3	118 118		0.03 0.03	0.75 0.671	Utr	0.0	16.000 2.000 18.000	150 0	20.322 0.0 0.0		Vel = 0.03	
H.3 to H.2	118 118		0.0 0.03	0.75 0.671	Utr	0.0	20.000 2.000 22.000	150 0	20.322 0.0 0.0		Vel = 0.03	
H.2 to T.33	118 118		0.0 0.03	0.75 0.671	Utr	0.0	1.000 2.000 3.000	150 0	20.322 0.0 0.0		Vel = 0.03	
T.33 to T.32	118 118		0.0 0.03	0.75 0.671	Utr Utb	0.0 0.0	7.000 19.000 26.000	150 0	20.322 0.0 0.0		Vel = 0.03	
T.32			0.0 0.03						20.322		K Factor = 0.01	
*New Path												
T.41 to H.15	109 109		0.88 0.88	0.75 0.671	Utb Utr	0.0 0.0	5.000 19.000 24.000	150 0.0023	24.523 0.0 0.056		Vel = 0.80	
H.15 to H.19	109 109		0.0 0.88	0.75 0.671	Utr	0.0	11.000 2.000 13.000	150 0.0024	24.579 0.0 0.031		Vel = 0.80	
H.19 to T.42	109 109		0.0 0.88	0.75 0.671	Utb	0.0	9.000 17.000 26.000	150 0.0023	24.610 0.0 0.060		Vel = 0.80	
T.42 to H.20	109 109		4.10 4.98	0.75 0.671	Utb Utr	0.0 0.0	4.000 19.000 23.000	150 0.0580	24.670 0.0 1.335		Vel = 4.52	
H.20 to T.52	109 109		0.0 4.98	0.75 0.671	Utr	0.0	4.000 2.000 6.000	150 0.0580	26.005 0.0 0.348		Vel = 4.52	
T.52 to T.51	109 109		-1.86 3.12	0.75 0.671	2Utb	0.0	1.000 34.000 35.000	150 0.0244	26.353 0.0 0.853		Vel = 2.83	
T.51 to T.48	109 109		1.86 4.98	0.75 0.671	Utr	0.0	5.000 2.000 7.000	150 0.0580	27.206 0.0 0.406		Vel = 4.52	

Final Calculations : Hazen-Williams

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - Two Head Calculation (H.6 & H.5)

Page 9
Date 7/22/2022

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
T.48 to T.47	109 109		-1.03 3.95	0.75 0.671	Utr	0.0	2.000 2.000 4.000	150 0.0378	27.612 0.0 0.151		Vel = 3.58	
T.47 to H.23	109 109		1.03 4.98	0.75 0.671			6.000 6.000	150 0.0580	27.763 0.0 0.348		Vel = 4.52	
H.23 to H.22	109 109		0.0 4.98	0.75 0.671	Utr	0.0	9.000 2.000 11.000	150 0.0580	28.111 0.0 0.638		Vel = 4.52	
H.22 to T.46	109 109		0.0 4.98	0.75 0.671	Utr	0.0	9.000 2.000 11.000	150 0.0580	28.749 0.0 0.638		Vel = 4.52	
T.46 to T.45	109 109		-0.84 4.14	0.75 0.671	Utr	0.0	1.000 2.000 3.000	150 0.0410	29.387 0.0 0.123		Vel = 3.76	
T.45 to H.21	109 109		0.84 4.98	0.75 0.671			1.000 1.000	150 0.0580	29.510 0.0 0.058		Vel = 4.52	
H.21 to T.44	109 109		0.0 4.98	0.75 0.671	Utb Utr	0.0 0.0	2.000 19.000 21.000	150 0.0580	29.568 0.0 1.219		Vel = 4.52	
T.44			0.0 4.98						30.787		K Factor = 0.90	
*New Path												
T.36 to T.42	118 109		4.10 4.1	1 0.862			11.000 11.000	150 0.0119	20.641 3.898 0.131		Vel = 2.25	
T.42			0.0 4.10						24.670		K Factor = 0.83	
*New Path												
T.52 to T.53	109 109		1.86 1.86	0.75 0.671	Utr	0.0	1.000 2.000 3.000	150 0.0093	26.353 0.0 0.028		Vel = 1.69	
T.53 to H.25	109 109		0.0 1.86	0.75 0.671	Utr	0.0	4.000 2.000 6.000	150 0.0095	26.381 0.0 0.057		Vel = 1.69	
H.25 to T.55	109 109		0.0 1.86	0.75 0.671	Utr	0.0	8.000 2.000 10.000	150 0.0094	26.438 0.0 0.094		Vel = 1.69	
T.55 to T.56	109 109		-0.41 1.45	0.75 0.671	Utr	0.0	2.000 2.000 4.000	150 0.0058	26.532 0.0 0.023		Vel = 1.32	
T.56 to H.29	109 109		0.41 1.86	0.75 0.671	Utr	0.0	17.000 2.000 19.000	150 0.0094	26.555 0.0 0.179		Vel = 1.69	
H.29 to H.30	109 109		0.0 1.86	0.75 0.671			10.000 10.000	150 0.0095	26.734 0.0 0.095		Vel = 1.69	

Final Calculations : Hazen-Williams

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - Two Head Calculation (H.6 & H.5)

Page 10
Date 7/22/2022

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
H.30 to H.28	109 109		0.0 1.86	0.75 0.671	Utr	0.0	13.000 2.000 15.000	150 0.0094	26.829 0.0 0.141		Vel = 1.69	
H.28 to T.57	109 109		0.0 1.86	0.75 0.671	Utr	0.0	8.000 2.000 10.000	150 0.0094	26.970 0.0 0.094		Vel = 1.69	
T.57 to T.51	109 109		0.0 1.86	0.75 0.671	Utr	0.0	13.000 2.000 15.000	150 0.0095	27.064 0.0 0.142		Vel = 1.69	
T.51			0.0 1.86						27.206		K Factor = 0.36	
*New Path												
T.55 to H.27	109 109		0.42 0.42	0.75 0.671	Utb Utr	0.0 0.0	2.000 19.000 21.000	150 0.0006	26.532 0.0 0.012		Vel = 0.38	
H.27 to T.56	109 109		0.0 0.42	0.75 0.671	Utb	0.0	2.000 17.000 19.000	150 0.0006	26.544 0.0 0.011		Vel = 0.38	
T.56			0.0 0.42						26.555		K Factor = 0.08	
*New Path												
T.48 to H.24	109 109		1.03 1.03	0.75 0.671	Utb Utr	0.0 0.0	6.000 19.000 25.000	150 0.0031	27.612 0.0 0.078		Vel = 0.93	
H.24 to T.47	109 109		0.0 1.03	0.75 0.671	Utb	0.0	6.000 17.000 23.000	150 0.0032	27.690 0.0 0.073		Vel = 0.93	
T.47			0.0 1.03						27.763		K Factor = 0.20	
*New Path												
T.46 to H.26	109 109		0.84 0.84	0.75 0.671	Utb Utr	0.0 0.0	11.000 19.000 30.000	150 0.0022	29.387 0.0 0.065		Vel = 0.76	
H.26 to T.45	109 109		0.0 0.84	0.75 0.671	Utb	0.0	10.000 17.000 27.000	150 0.0021	29.452 0.0 0.058		Vel = 0.76	
T.45			0.0 0.84						29.510		K Factor = 0.15	
*New Path												
T.38 to H.10	118 118		1.75 1.75	0.75 0.671	Utb Utr	0.0 0.0	10.000 19.000 29.000	150 0.0083	25.987 0.0 0.242		Vel = 1.59	
H.10 to T.37	118 118		0.0 1.75	0.75 0.671	Utb	0.0	13.000 17.000 30.000	150 0.0084	26.229 0.0 0.251		Vel = 1.59	
T.37			0.0 1.75						26.480		K Factor = 0.34	

Final Calculations : Hazen-Williams

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - Two Head Calculation (H.6 & H.5)

Page 11
Date 7/22/2022

Node1	Elev1	K	Qa	Nom	Fitting or		Pipe Ftngs	CFact	Pt Pe	*****	Notes	*****
Node2	Elev2	Fact	Qt	Act	Equiv	Len	Total	Pf/Ft	Pf			

I hereby certify that this plan, specification, or report was prepared by me or under my direct supervision and that I am NICET Certified.



Tim W McDonald Date: 07/22/2022

NICET Certification No. 150393
Water-Based Systems Layout - Level III
Certification Expires: June 1, 2025

Uponor

AquaSAFE™ Fire Safety System

Hydratec Incorporated
64 Haverhill Road
Route 111
Windham, NH 03087
603-434-0502

Job Name : HAWTHORNE ESTATES - CAMBRIDGE - Two Head Calculation (H.6 & H.5)
Drawing : RESIDENTIAL
Location : SE HAWTHORNE MEADOWS ST PORTLAND OR 97236
Remote Area : 1
Contract : 42892F 004
Data File : 42892F 004 Hawthorne Estates - Cambridge.wx2
Date/Time : 07/22/2022 - 12:54 PM

HYDRAULIC DESIGN INFORMATION SHEET

Name - HAWTHORNE ESTATES - CAMBRIDGE Date - 7/21/2022
Location - PORTLAND OR 97236
Building - RESIDENTIAL System No. - 1
Contractor - WOLCOTT PLUMBING Contract No. - 42892F 004
Calculated By - SILVIU RADES Drawing No. - F100
Construction: (X) Combustible () Non-Combustible Ceiling Height VARIES
OCCUPANCY - RESIDENTIAL


S Type of Calculation: () NFPA 13 Residential () NFPA 13R (X) NFPA 13D
Y Number of Sprinklers Flowing: () 1 (X) 2 () 4 ()
S () Other
T () Specific Ruling Made by Date
E
M Listed Flow at Start Point - 13 Gpm System Type
Listed Pres. at Start Point - 7.04 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
S Additional Flow Added - Gpm Make SENJU Model RC-RES
I Elevation at Highest Outlet - 118 Feet Size 7/16 K-Factor 4.9
G Note: Temperature Rating 162
N

Calculation Gpm Required 26.1335 Psi Required 90.23 At Ref Pt STR
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - x Rated Cap. Cap.
T Time of Test - x @ Psi Elev.
E Static (Psi) - 112 Elev.
R Residual (Psi) - 97 Other Well
Flow (Gpm) - 300 Proof Flow Gpm
S Elevation - 97
P Location: STREET
P
L Source of Information: CONTRACTOR
Y

Water Supply Curve

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - Two Head Calculation (H.6 & H.5)



Fittings Used Summary

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - Two Head Calculation (H.6 & H.5)

Fitting Legend		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Abbrev.	Name																				
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

Diameter Units

Length Units

Flow Units

Pressure Units

Inches

Feet

US Gallons per Minute

Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - Two Head Calculation (H.6 & H.5)

Page 4
Date 7/22/2022

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
STR	112.0	97	300.0	111.836	26.13	90.226

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>		<i>Notes</i>
H.6	118.0	4.9	7.04	13.0	0.05	256
H.4	118.0		10.12			
H.7	118.0		13.21			
H.8	118.0		15.58			
T.35	118.0		20.32			
T.38	118.0		25.99			
T.49	109.0		31.33			
T.50	109.0		31.73			
T.54	109.0		32.28			
S.1	109.0		35.1			
PRV	97.0		69.11			
SOV	97.0		69.23			
MTR	97.0		80.85			
STR	97.0		90.23			
H.5	118.0	4.9	7.18	13.13	0.05	256
T.34	118.0		16.62			
T.36	118.0		20.64			
H.12	118.0		22.3			
H.11	118.0		22.7			
H.13	118.0		23.96			
T.39	118.0		24.65			
H.9	118.0		25.11			
T.37	118.0		26.48			
H.1	118.0		18.01			
T.32	118.0		20.32			
T.41	109.0		24.52			
H.14	109.0		26.37			
H.18	109.0		27.3			
H.17	109.0		27.94			
H.16	109.0		28.79			
T.44	109.0		30.79			
T.43	109.0		30.86			
H.3	118.0		20.32			
H.2	118.0		20.32			
T.33	118.0		20.32			
H.15	109.0		24.58			
H.19	109.0		24.61			
T.42	109.0		24.67			
H.20	109.0		26.0			
T.52	109.0		26.35			
T.51	109.0		27.21			
T.48	109.0		27.61			

Flow Summary - NFPA

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - Two Head Calculation (H.6 & H.5)

Page 5
Date 7/22/2022

NODE ANALYSIS (cont.)

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
T.47	109.0		27.76		
H.23	109.0		28.11		
H.22	109.0		28.75		
T.46	109.0		29.39		
T.45	109.0		29.51		
H.21	109.0		29.57		
T.53	109.0		26.38		
H.25	109.0		26.44		
T.55	109.0		26.53		
T.56	109.0		26.56		
H.29	109.0		26.73		
H.30	109.0		26.83		
H.28	109.0		26.97		
T.57	109.0		27.06		
H.27	109.0		26.54		
H.24	109.0		27.69		
H.26	109.0		29.45		
H.10	118.0		26.23		

Final Calculations : Hazen-Williams

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - Two Head Calculation (H.6 & H.5)

Page 6
Date 7/22/2022

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
*Remote Head to Supply												
H.6 to H.4	118 118	4.90	10.67	0.75	Utr	0.0	11.000 2.000	150	7.040 0.0			
H.4 to H.7	118 118		10.67	0.671			13.000	0.2372	3.083	Vel =	9.68	
H.7 to H.8	118 118		0.0	0.75	Utr	0.0	11.000 2.000	150	10.123 0.0			
H.8 to H.8	118 118		10.67	0.671			13.000	0.2372	3.083	Vel =	9.68	
H.8 to T.35	118 118		0.0	0.75	Utb Utr	0.0 0.0	10.000 1.000	150	13.206 15.578			
T.35 to T.38	118 118		10.67	0.671			10.000	0.2372	2.372	Vel =	9.68	
T.38 to T.49	118 109		0.0	0.75	Utb	0.0	19.000 7.000	150	0.0 20.322			
T.49 to T.50	109 109		10.67	0.671			20.000	0.2372	4.744	Vel =	9.68	
T.50 to T.54	109 109		-0.03	0.75	Utb	0.0	17.000 24.000	150	0.0 5.665			
T.54 to S.1	109 109		10.64	0.671			24.000	0.2360	5.665	Vel =	9.65	
S.1 to PRV	109 97		-1.75	1	Utb	0.0	14.848 14.000	150	25.987 3.898			
PRV to SOV	97 97		8.89	0.862			28.848	0.0500	1.443	Vel =	4.89	
SOV to MTR	97 97		10.55	1.25	Utr	0.0	1.000 4.000	150	31.328 0.0			
MTR to STR	97 97		19.44	1.054			5.000	0.0798	0.399	Vel =	7.15	
STR to STR	97 97		6.69	1.25			4.000	150	31.727 0.0			
STR to STR	97 97		26.13	1.054			4.000	0.1380	0.552	Vel =	9.61	
STR to STR	97 97		0.0	1.25	Uel T	0.0 2.44	7.000 13.440	150	32.279 0.0			
STR to STR	97 97		26.13	1.054			20.440	0.1380	2.821	Vel =	9.61	
STR to STR	97 97		0.0	1.25	E T	2.746 5.492	5.000 8.237	150	35.100 33.197			
STR to STR	97 97		26.13	1.245			13.237	0.0613	0.812	** Fixed Loss = 28 Vel =	6.89	
STR to STR	97 97		0.0	1.25			2.000	150	69.109 0.0			
STR to STR	97 97		26.13	1.245			2.000	0.0615	0.123	Vel =	6.89	
STR to STR	97 97		0.0	1.25	2E	2.44	60.000 2.440	150	69.232 3.000			
STR to STR	97 97		26.13	1.054			62.440	0.1380	8.618	** Fixed Loss = 3 Vel =	9.61	
STR to STR	97 97		0.0	1	2E G	4.673 0.0	40.000 5.841	150	80.850 1.000			
STR to STR	97 97		26.13	0.995			45.841	0.1827	8.376	** Fixed Loss = 1 Vel =	10.78	
STR to STR	97 97		0.0 26.13						90.226	K Factor =	2.75	
*New Path												
H.6 to H.5	118 118		2.34	0.75			10.000	150	7.040 0.0			
H.5 to T.34	118 118	4.90	2.34	0.671			10.000	0.0143	0.143	Vel =	2.12	
T.34 to T.34	118 118		13.13	0.75	Utb Utr	0.0 0.0	1.000 19.000	150	7.183 0.0			
T.34 to T.34	118 118		15.47	0.671			20.000	0.4716	9.433	Vel =	14.04	

Final Calculations : Hazen-Williams

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - Two Head Calculation (H.6 & H.5)

Page 7
Date 7/22/2022

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
T.34 to T.36	118 118		-6.42 9.05	0.75 0.671	Utb	0.0	6.000 17.000 23.000	150 0.1750	16.616 0.0 4.025		Vel = 8.21	
T.36 to H.12	118 118		-4.10 4.95	0.75 0.671	Utb Utr	0.0 0.0	10.000 19.000 29.000	150 0.0572	20.641 0.0 1.660		Vel = 4.49	
H.12 to H.11	118 118		0.0 4.95	0.75 0.671	Utr	0.0	5.000 2.000 7.000	150 0.0573	22.301 0.0 0.401		Vel = 4.49	
H.11 to H.13	118 118		0.0 4.95	0.75 0.671	Utr	0.0	20.000 2.000 22.000	150 0.0572	22.702 0.0 1.259		Vel = 4.49	
H.13 to T.39	118 118		0.0 4.95	0.75 0.671			12.000 12.000	150 0.0572	23.961 0.0 0.687		Vel = 4.49	
T.39 to H.9	118 118		0.0 4.95	0.75 0.671	Utr	0.0	6.000 2.000 8.000	150 0.0572	24.648 0.0 0.458		Vel = 4.49	
H.9 to T.37	118 118		0.0 4.95	0.75 0.671	Utb Utr	0.0 0.0	5.000 19.000 24.000	150 0.0572	25.106 0.0 1.374		Vel = 4.49	
T.37 to T.50	118 109		1.74 6.69	1 0.862	Utb	0.0	31.625 14.000 45.625	150 0.0296	26.480 3.898 1.349		Vel = 3.68	
T.50			0.0 6.69						31.727		K Factor = 1.19	
*New Path												
T.34 to H.1	118 118		6.42 6.42	0.75 0.671	Utr	0.0	13.000 2.000 15.000	150 0.0927	16.616 0.0 1.390		Vel = 5.82	
H.1 to T.32	118 118		0.0 6.42	0.75 0.671	Utb Utr	0.0 0.0	6.000 19.000 25.000	150 0.0926	18.006 0.0 2.316		Vel = 5.82	
T.32 to T.41	118 109		0.02 6.44	1 0.862			11.000 11.000	150 0.0275	20.322 3.898 0.303		Vel = 3.54	
T.41 to H.14	109 109		-0.88 5.56	0.75 0.671	Utb Utr	0.0 0.0	7.000 19.000 26.000	150 0.0712	24.523 0.0 1.851		Vel = 5.04	
H.14 to H.18	109 109		0.0 5.56	0.75 0.671	Utr	0.0	11.000 2.000 13.000	150 0.0712	26.374 0.0 0.925		Vel = 5.04	
H.18 to H.17	109 109		0.0 5.56	0.75 0.671			9.000 9.000	150 0.0712	27.299 0.0 0.641		Vel = 5.04	
H.17 to H.16	109 109		0.0 5.56	0.75 0.671	Utr	0.0	10.000 2.000 12.000	150 0.0712	27.940 0.0 0.854		Vel = 5.04	

Final Calculations : Hazen-Williams

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - Two Head Calculation (H.6 & H.5)

Page 8
Date 7/22/2022

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
H.16 to T.44	109 109		0.0 5.56	0.75 0.671	Utb	0.0	11.000 17.000 28.000	150 0.0712	28.794 0.0 1.993		Vel = 5.04	
T.44 to T.43	109 109		4.99 10.55	1.25 1.054			3.000 3.000	150 0.0257	30.787 0.0 0.077		Vel = 3.88	
T.43 to T.49	109 109		0.0 10.55	1.25 1.054	Utr Uel	0.0 0.0	3.000 15.000 18.000	150 0.0258	30.864 0.0 0.464		Vel = 3.88	
T.49			0.0 10.55						31.328		K Factor = 1.88	
*New Path												
T.35 to H.3	118 118		0.03 0.03	0.75 0.671	Utr	0.0	16.000 2.000 18.000	150 0	20.322 0.0 0.0		Vel = 0.03	
H.3 to H.2	118 118		0.0 0.03	0.75 0.671	Utr	0.0	20.000 2.000 22.000	150 0	20.322 0.0 0.0		Vel = 0.03	
H.2 to T.33	118 118		0.0 0.03	0.75 0.671	Utr	0.0	1.000 2.000 3.000	150 0	20.322 0.0 0.0		Vel = 0.03	
T.33 to T.32	118 118		0.0 0.03	0.75 0.671	Utr Utb	0.0 0.0	7.000 19.000 26.000	150 0	20.322 0.0 0.0		Vel = 0.03	
T.32			0.0 0.03						20.322		K Factor = 0.01	
*New Path												
T.41 to H.15	109 109		0.88 0.88	0.75 0.671	Utb Utr	0.0 0.0	5.000 19.000 24.000	150 0.0023	24.523 0.0 0.056		Vel = 0.80	
H.15 to H.19	109 109		0.0 0.88	0.75 0.671	Utr	0.0	11.000 2.000 13.000	150 0.0024	24.579 0.0 0.031		Vel = 0.80	
H.19 to T.42	109 109		0.0 0.88	0.75 0.671	Utb	0.0	9.000 17.000 26.000	150 0.0023	24.610 0.0 0.060		Vel = 0.80	
T.42 to H.20	109 109		4.10 4.98	0.75 0.671	Utb Utr	0.0 0.0	4.000 19.000 23.000	150 0.0580	24.670 0.0 1.335		Vel = 4.52	
H.20 to T.52	109 109		0.0 4.98	0.75 0.671	Utr	0.0	4.000 2.000 6.000	150 0.0580	26.005 0.0 0.348		Vel = 4.52	
T.52 to T.51	109 109		-1.86 3.12	0.75 0.671	2Utb	0.0	1.000 34.000 35.000	150 0.0244	26.353 0.0 0.853		Vel = 2.83	
T.51 to T.48	109 109		1.86 4.98	0.75 0.671	Utr	0.0	5.000 2.000 7.000	150 0.0580	27.206 0.0 0.406		Vel = 4.52	

Final Calculations : Hazen-Williams

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - Two Head Calculation (H.6 & H.5)

Page 9
Date 7/22/2022

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
T.48 to T.47	109 109		-1.03 3.95	0.75 0.671	Utr	0.0	2.000 2.000 4.000	150 0.0378	27.612 0.0 0.151		Vel = 3.58	
T.47 to H.23	109 109		1.03 4.98	0.75 0.671			6.000 6.000	150 0.0580	27.763 0.0 0.348		Vel = 4.52	
H.23 to H.22	109 109		0.0 4.98	0.75 0.671	Utr	0.0	9.000 2.000 11.000	150 0.0580	28.111 0.0 0.638		Vel = 4.52	
H.22 to T.46	109 109		0.0 4.98	0.75 0.671	Utr	0.0	9.000 2.000 11.000	150 0.0580	28.749 0.0 0.638		Vel = 4.52	
T.46 to T.45	109 109		-0.84 4.14	0.75 0.671	Utr	0.0	1.000 2.000 3.000	150 0.0410	29.387 0.0 0.123		Vel = 3.76	
T.45 to H.21	109 109		0.84 4.98	0.75 0.671			1.000 1.000	150 0.0580	29.510 0.0 0.058		Vel = 4.52	
H.21 to T.44	109 109		0.0 4.98	0.75 0.671	Utb Utr	0.0 0.0	2.000 19.000 21.000	150 0.0580	29.568 0.0 1.219		Vel = 4.52	
T.44			0.0 4.98						30.787		K Factor = 0.90	
*New Path												
T.36 to T.42	118 109		4.10 4.1	1 0.862			11.000 11.000	150 0.0119	20.641 3.898 0.131		Vel = 2.25	
T.42			0.0 4.10						24.670		K Factor = 0.83	
*New Path												
T.52 to T.53	109 109		1.86 1.86	0.75 0.671	Utr	0.0	1.000 2.000 3.000	150 0.0093	26.353 0.0 0.028		Vel = 1.69	
T.53 to H.25	109 109		0.0 1.86	0.75 0.671	Utr	0.0	4.000 2.000 6.000	150 0.0095	26.381 0.0 0.057		Vel = 1.69	
H.25 to T.55	109 109		0.0 1.86	0.75 0.671	Utr	0.0	8.000 2.000 10.000	150 0.0094	26.438 0.0 0.094		Vel = 1.69	
T.55 to T.56	109 109		-0.41 1.45	0.75 0.671	Utr	0.0	2.000 2.000 4.000	150 0.0058	26.532 0.0 0.023		Vel = 1.32	
T.56 to H.29	109 109		0.41 1.86	0.75 0.671	Utr	0.0	17.000 2.000 19.000	150 0.0094	26.555 0.0 0.179		Vel = 1.69	
H.29 to H.30	109 109		0.0 1.86	0.75 0.671			10.000 10.000	150 0.0095	26.734 0.0 0.095		Vel = 1.69	

Final Calculations : Hazen-Williams

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - Two Head Calculation (H.6 & H.5)

Page 10
Date 7/22/2022

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
H.30 to H.28	109 109		0.0 1.86	0.75 0.671	Utr	0.0	13.000 2.000 15.000	150 0.0094	26.829 0.0 0.141		Vel = 1.69	
H.28 to T.57	109 109		0.0 1.86	0.75 0.671	Utr	0.0	8.000 2.000 10.000	150 0.0094	26.970 0.0 0.094		Vel = 1.69	
T.57 to T.51	109 109		0.0 1.86	0.75 0.671	Utr	0.0	13.000 2.000 15.000	150 0.0095	27.064 0.0 0.142		Vel = 1.69	
T.51			0.0 1.86						27.206		K Factor = 0.36	
*New Path												
T.55 to H.27	109 109		0.42 0.42	0.75 0.671	Utb Utr	0.0 0.0	2.000 19.000 21.000	150 0.0006	26.532 0.0 0.012		Vel = 0.38	
H.27 to T.56	109 109		0.0 0.42	0.75 0.671	Utb	0.0	2.000 17.000 19.000	150 0.0006	26.544 0.0 0.011		Vel = 0.38	
T.56			0.0 0.42						26.555		K Factor = 0.08	
*New Path												
T.48 to H.24	109 109		1.03 1.03	0.75 0.671	Utb Utr	0.0 0.0	6.000 19.000 25.000	150 0.0031	27.612 0.0 0.078		Vel = 0.93	
H.24 to T.47	109 109		0.0 1.03	0.75 0.671	Utb	0.0	6.000 17.000 23.000	150 0.0032	27.690 0.0 0.073		Vel = 0.93	
T.47			0.0 1.03						27.763		K Factor = 0.20	
*New Path												
T.46 to H.26	109 109		0.84 0.84	0.75 0.671	Utb Utr	0.0 0.0	11.000 19.000 30.000	150 0.0022	29.387 0.0 0.065		Vel = 0.76	
H.26 to T.45	109 109		0.0 0.84	0.75 0.671	Utb	0.0	10.000 17.000 27.000	150 0.0021	29.452 0.0 0.058		Vel = 0.76	
T.45			0.0 0.84						29.510		K Factor = 0.15	
*New Path												
T.38 to H.10	118 118		1.75 1.75	0.75 0.671	Utb Utr	0.0 0.0	10.000 19.000 29.000	150 0.0083	25.987 0.0 0.242		Vel = 1.59	
H.10 to T.37	118 118		0.0 1.75	0.75 0.671	Utb	0.0	13.000 17.000 30.000	150 0.0084	26.229 0.0 0.251		Vel = 1.59	
T.37			0.0 1.75						26.480		K Factor = 0.34	

Final Calculations : Hazen-Williams

Hydratec Incorporated
HAWTHORNE ESTATES - CAMBRIDGE - Two Head Calculation (H.6 & H.5)

Page 11
Date 7/22/2022

Node1	Elev1	K	Qa	Nom	Fitting or		Pipe Ftngs	CFact	Pt Pe	*****	Notes	*****
Node2	Elev2	Fact	Qt	Act	Equiv	Len	Total	Pf/Ft	Pf			

Plumbing Checksheet Response

Permit #: 21-085113-REV-01-RS

Date: 9/15/22

Customer name and phone number: Bradlee Hersey 503-913-8811

Note: In the spaces below, please provide specific information concerning the changes that you have made in response to the checklist. Note the checklist item number, your response or a description of the revision, and the location of the change on the plans (i.e. page number and/or detail number). Use as many lines as needed. *If the item is not in response to a checklist, write “Applicant” in the column labeled “Checklist item number.”*

[illegible]

(for office use only)

RESIDENTIAL FIRE SPRINKLER CHECKSHEET

Application # **21-085113-REV-01-RS**

Residential 1 & 2 Family Permit

Review Date **August 25, 2022**

To:	OWNER	LENNAR NORTHWEST INC 11807 NE 99TH ST #1170 VANCOUVER, WA 98682-2350		
-----	--------------	--	--	--

From:	BDS Senior Plumbing Inspector	James Bechtel	Phone Fax Email	503-823-6363 503 823-5433 Jim.Bechtels@portlandoregon.gov
-------	--	---------------	-----------------------	---

cc:	OWNER	LENNAR NORTHWEST INC 11807 NE 99TH ST #1170 VANCOUVER, WA 98682-2350		
-----	--------------	--	--	--

PROJECT INFORMATION

Street Address: 15421 SE FLAVEL ST

Description of Work: SINGLEPDF - REVISION TO THE FIRE SPRINKLERS PLANS

Item #	Location on Plans	Clarification / Correction Required
1		Provide scaled drawing with head locations per NFPA 13D
2		Provide sprinkler head cut sheets per NFPA 13D
3		Provide hydraulic calculations per NFPA 13D
4		

To respond to this Checksheet, you may need to revise your plans, your supporting documents, or provide additional information. When you finish with your changes, please submit your updated plans and supporting documents. Make sure to include the attached Checksheet Response Form. Visit the BDS Permit Review Process website for more helpful information and available services: <https://www.portland.gov/bds/permit-review-process>

If you want to report a delay, a regulatory conflict or other issue that you have been unable to resolve with your City review team, please visit <https://www.portland.gov/bds/development-permit-processes/report-problem>

If you have questions about this Checksheet, please contact me at the email address or phone number listed above. To check the status of your project, go to <https://www.portlandmaps.com/advanced/?action=permits>. Or you may request the status to be faxed to you, by calling 503.823.7000 and selecting option 4. Please have your IVR number and fax number available.

PLUMBING CHECKSHEET

Application # **21-085113-REV-01-RS**

Review Date **August 25, 2022**

Application fees cover an initial plan review and two checksheets. Starting with the third checksheet, additional fees will be added. These fees are based on the current Fee Schedule: <https://www.portland.gov/bds/current-fee-schedules#toc-city-of-portland-fee-schedules>

Appeals: Pursuant to City Code Chapters 24.10, 25.07, 26.03, 27.02, and 28.03, you may appeal any code provision cited in this Checksheet to the BDS Administrative Board of Appeal within 180 calendar days of the review date. For information on the appeals process and costs, including forms, appeal fee, payment methods and fee waivers, go to www.portland.gov/bds/file-appeal or call (503) 823-7300 for assistance. Permit application expiration will not be extended pending resolution of any administrative appeal.