Life Safety Checksheet Response

Permit #: **22-197446-000-00-RS** **Date:** 2/23/2023

Customer name and phone number: Theo Cirstean (971) 678-6930

Note: In the spaces below, please provide specific information concerning the changes that you have made in response to the checksheet. Note the checksheet item number, your response or a description of the revision, and the location of the change on the plans (i.e. page number and/or detail number). Use as many lines as needed. *If the item is not in response to a checksheet, write **"Applicant"** in the column labeled "Checksheet item number."*

Checksheet item number	Description of changes, corrections, additions, etc.	Location on plans
1	Plans to state 2021 ORSC.	Revised plans page 2
2	Plans state that energy measures are designed in accordance	Revised plans page 2
	with 2021 ORSC.	
3	The plans are updated with the proper safety glazing.	Revised plans page 3
4	Plans do notate plan specific crawl space ventilation square	Revised plans page 4
	footage requirement and the calculation showing how that number	
	came to be.	
5	Plans do provide plan specific attic ventilation square footage	Revised plans page 1
	and the calculation showing how that number came to be.	
6	Mechanical connection for 2-ply girder truss that can withstand	Replacement roof truss
	2,400 pounds of uplift potential on truss A03.	engineering page 4
7	Full size structural plan sheets within the plan submittal.	Supplemental Structural
		plans S1.0; S1.1; S5.0
8	Current roof truss engineering with updated stamp.	Replacement Roof truss eng.
9	Specification of the roof over framing behind truss A03 (size, grade,	Replacement Roof truss
	and species).	engineering page 4
10	Truss submittal accounts for the shed porch roof rafter overlay	Revised plans page 6
	found in building sections 2.	
11	Porch roof beam connections (beam to wall, beam to post, post to	Revised plans page 5
	footing) found in building sections.	

Plan Bin Location: SINGLE PDF

SUBMITTED 4/12/2023