

ACCEPTANCE

Portland, Oregon, February 21 1964


RAY SMITH
Auditor of the City of Portland,
Room 202, City Hall
Portland 4, Oregon
Dear Sir:

This is to advise the City of Portland, Oregon, that I hereby accept the terms and provisions of Ordinance No. 118096 granting a revocable permit to Union Oil Company of California, to enlarge its lube oil storage facilities at its Portland terminal at 5500 N. W. Doane Street, by the installation of three (3) twenty-thousand-gallon lube oil storage tanks, under certain terms and conditions, and declaring an emergency,

and in consideration of the benefits to be received thereunder by me I hereby agree to abide by and perform each and all of the terms and provisions thereof applicable to me.

Very truly yours,

[CORPORATE
SEAL]


Union Oil Company of California

E. J. Johnson

P.O. Box 3458, Address Portland, Ore. 97208

Approved as to form:


City Attorney

*When an acceptance is required from a firm or corporation the Acceptance must be signed by an officer of the firm or corporation stating his or her official title, and corporations must affix the corporate seal.

ORDINANCE NO. 118096

An Ordinance granting a revocable permit to Union Oil Company of California, to enlarge its lube oil storage facilities at its Portland terminal at 5500 N.W. Doane Street, by the installation of three (3) twenty-thousand-gallon lube oil storage tanks, under certain terms and conditions, and declaring an emergency.

The City of Portland ordains:

Section 1. The Council finds that on February 10, 1964, the Union Oil Company of California, by R. H. Grocock, Regional Engineer, applied for permission to enlarge its lubricating oil storage facilities at its Portland terminal at 5500 N.W. Doane Street by the installation of three (3) twenty-thousand-gallon lube oil storage tanks as shown on Union Oil Company of California Drawings Nos. F1B423, dated December 14, 1948; L2C285, Revision 3, sheet No. 5, dated April 15, 1949; L2C347, dated February 7, 1964; L2C347 Sheet No. 6 of Project 2/1/64, Flow Diagram Project 2/1/64 and L2C348, sheet No. 4, dated February 1, 1964, all of which were attached to the request for permit, that inspection has been made of said premises by the Bureau of Buildings and the Fire Marshal, and the Bureau of Buildings has recommended that the permit be granted pursuant to the recommendation of the Fire Marshal; that the report of the Fire Marshal, dated February 14, 1964, states that the proposed installation so closely conforms with the requirements of Ordinance No. 114851, Fire Code, as to not currently present any hazard and recommends that the installation be permitted, subject to the following conditions:

1. That one copy of Union Oil Company of California Drawing No. L2C285, Revision 3, sheet No. 5, dated April 15, 1949, and one copy of Union Oil Company of California Drawing No. L2C347, dated February 7, 1964, be filed as a part of the permit request.

2. That the tanks shall not be used at any time for the storage of a product having a flash point below that of ordinary motor lubricating oil.

3. That the tanks shall be built in accordance with the American Petroleum Institute, Standard No. 650, entitled, "Welded Steel Tanks for Oil Storage, First Edition, Dec. 1961 and Supplement February 1963", and shall bear the American Petroleum Institute's monogram.

4. That all pipes, valves and fittings shall be equal to the requirements of Chapter IV, Volume 1 of the National Fire Codes, "Flammable Liquids 1963-64 Edition" (NFPA Pamphlet No. 30).

ORDINANCE No.


5. That all construction, including tanks, tank pads, pipe supports, pumps, and walkways shall be accomplished under permit from the Bureau of Buildings of the City of Portland, and be in accordance with detailed drawings submitted to and approved by that Bureau.

now, therefore, a revocable permit hereby is granted to the Union Oil Company of California, By R. H. Grocock, Regional Engineer, to enlarge its lubricating oil storage facilities at its Portland terminal at 5500 N.W. Doane Street by the installation of three (3) twenty-thousand-gallon lubricating oil storage tanks and said construction and maintenance shall be in strict compliance with the conditions recommended by the Fire Marshal set forth above in this ordinance.

Section 2. Nothing contained herein shall be deemed or taken to exempt said Union Oil Company of California from compliance with any other applicable provisions of the Portland Fire Code and other ordinances of the City of Portland, nor shall anything contained herein be taken or deemed to create any vested or property right and no expenditure of money, lapse of time or any act or thing shall prevent the Council from at any time revoking this permit and requiring full compliance with the applicable provisions of law, codes and ordinances of the City of Portland. This permit shall not become effective until such time as a suitable document approved as to form by the City Attorney shall have been signed and filed with the Auditor of the City of Portland by said Union Oil Company of California, which document shall accept and agree to the terms, provisions and conditions of this ordinance.

Section 3. Inasmuch as this ordinance is necessary for the immediate preservation of the public health peace and safety of the City of Portland in this: The needs of the City for facilities for storing and distributing lubricating oil are such that there should be no unnecessary delay in increase in such facilities; therefore, an emergency hereby is declared to exist, and this ordinance shall be in force and effect from and after its passage by the Council.

Passed by the Council, FEB 20 1964



Mayor of the City of Portland

Attest:



Auditor of the City of Portland

ORDINANCE No. **118996**

INTRODUCED BY
Commissioner Earl

DRAWN BY

ENC:rf

Date Feb. 19, 1964

NOTED BY THE COMMISSIONER

Affairs *W. Earl*

Finance

Safety

Utilities

Works

City Attorney *WLB*

NOTED FOR CITY AUDITOR

WLB
Enc

APPROVED

City Engineer

Title

An Ordinance Granting a revocable permit to Union Oil Company of California, to enlarge its lube oil storage facilities at its Portland terminal at 5500 N.W. Doane Street, by the installation of three (3) twenty-thousand-gallon lube oil storage tanks, under certain terms and conditions, and declaring an emergency.

Filed FEB 19 1964

RAY SMITH
Auditor of the CITY OF PORTLAND

By *W. Earl*
Deputy

THE COMMISSIONERS VOTED
AS FOLLOWS:

	Yeas	Nays
Bean	1	
Bowes	1	
Earl	1	
Grayson	1	
Schrunk	1	

FOUR FIFTHS CALENDAR

Bean	
Bowes	<i>WLB</i>
Earl	<i>WLB</i>
Grayson	<i>WLB</i>
Schrunk	<i>WLB</i>