

File Data Search Edit Actions Reports Window Help



4632 91ST AVE [FD]

Folder | Property (1) | People (2) | Info (4) | Process (9) | Process Select (3) | Document | Inspection Req. | Comment (2)

| Folder# | Ref |
|-----------------------|-----|
| 2007 153578 000 00 FD | |

Folder: 07 153578 000 00 FD

8/23/07 PERMIT INFO Residential structural and electrical permits required for fire starting at exterior chicken coop w/ extension into roof attic area. Smoke and water damage to kitchen, bathroom and rear bedroom. No plans required for permit - repair per Dang. Building inspection and 1&2 family code. Scrape and seal all fire/smoke damaged members not removed by demolition. Replace or double from bearing to bearing 4-6 2X4 roof rafters and 2-4 2X4 ceiling joists over bathroom and bedroom at rear wall as needed where char exceeds 1/4" or cut by firefighters. Provide fire blocking per code in all opened wall areas. Remove all smoke damaged insulation and replace with wall insulation to be R-15, attic R38. Windows to be CL65, doors CL54. Provide smoke detectors to code. Electrical for 2-4 fire damaged circuits. Repair damaged electrical branch circuits, including treatment of knob and tube wiring per amended Article 394 of 2005 NEC. CAS

Reminder Date Mon Aug 27, 2007


Made On Mon Aug 27, 2007

Comment Date Mon Aug 27, 2007

Remind STRUEMPC

Made By STRUEMPC

Include ☐



List View | Related View

☒ Show no. of rows on tabs

2 Rows Returned

Ready



11:25 AM
8/15/2016

16 - 164638 REVIEWS 2



City of Portland, Oregon - Bureau of Development Services

1900 SW Fourth Avenue • Portland, Oregon 97201 | 503-823-7300 | www.portlandoregon.gov/bds



Permit Revision Submittal Requirements and Application

A Permit Revision is required when there are proposed changes to the project after the permit has been issued. This may arise due to discrepancies between the city-approved permit drawings and actual field conditions, or the customer has changed their mind about an aspect of the project. In all cases, a revision to the existing permit must be submitted, reviewed and approved.

Applicants will provide:

☐ A copy of this application

☐ Three (3) sets of plans that clearly reflect the proposed change(s).

Drawings and calculations must be stamped and signed by the Architect and/or the Engineer of Record, if applicable.

☐ One (1) copy of the original city approved permit drawings. (NOTE: If your project has an assigned process manager please contact them regarding submittal of the revision).

☐ Two (2) sets of calculations, if applicable

☐ Inspector's correction notice, if revision is due to an inspection correction

☐ Revision fee (paid at time of submittal)

Contact Information:

Contact name

Matthew Anderson

Address

4632 NE 91st Ave.

City

Portland

State

OR

Zip Code

97229

Phone

206/883-0987

Email

MTANDERSON02@hotmail.com

Value of proposed revision

~~5000.00~~ 3000.00

Issued permit #

Job site address

4632 NE 91st Ave.

Description of revision

Permit required for fire starting at exterior and extension into roof attic area.

Fees:

The Permit Revisions are subject to fees associated with plan review, processing and any increase in project value. Additional fees may apply if adding plumbing fixtures.

The Bureau of Development Services fee schedule is available under the fees tab on the BDS web site at: www.portlandoregon.gov/bds. Fees are updated annually on July 1st.

Helpful Information:

Bureau of Development Services

City of Portland, Oregon

1900 SW 4th Avenue, Portland, OR 97201

www.portlandoregon.gov/bds

Submit your plans in person to:

Development Services Center (DSC), First Floor,
For Hours Call 503-823-7310

Important Telephone Numbers:

BDS main number503-823-7300

DSC automated information line503-823-7310

Building code information503-823-1456

BDS 24 hour inspection request line503-823-7000

Residential information for

one and two family dwelling503-823-7388

General Permit Processing and

Fee Estimate info503-823-7357

City of Portland TTY503-823-6868